



Recommended criteria for thermal comfort and indoor air quality in International standards (ASHRAE-ISO-CEN)


Professor Bjarne W. Olesen, Ph.D., FASHRAE

bwo@byg.dtu.dk

[Society President](#)

International Center for Indoor Environment and
Energy

Technical University of Denmark



INDOOR ENVIRONMENT

- THERMAL
- AIR QUALITY
- ACOUSTIC
- LIGHT

EVALUATION OF THE INDOOR ENVIRONMENT

- DESIGN LEVEL
- COMMISSIONING
- TESTING
- COMPLAINTS

STANDARDS

- **ISO EN 7730-2005**

- Ergonomics of the thermal environment – Analytical determination and interpretation of thermal comfort using calculation of the PMV and PPD indices and local thermal comfort effects.

- **ASHRAE 55-2016**

- Thermal environment conditions for human occupancy

- **ASHRAE 62.1 and 62.2 -2016**

- Ventilation and indoor air quality

- **EN15251**

- Indoor environmental input parameters for design and assessment of energy performance of buildings- addressing indoor air quality, thermal environment, lighting and acoustic

- **EN 13779**

- Ventilation for non-residential buildings - performance requirements for ventilation and room-conditioning systems

International Standards

Indoor Environmental Quality

- **prEN16798-1 and ISO 17772-1:**
 - Indoor environmental input parameters for the design and assessment of energy performance of buildings.
- **TR16798-2 and ISO TR 17772-2:**
 - Guideline for using indoor environmental input parameters for the design and assessment of energy performance of buildings.
- **EN 16798-3 and TR 16798-4**
 - Ventilation for non-residential buildings - performance requirements for ventilation and room-conditioning systems

MODERATE ENVIRONMENTS

- **GENERAL THERMAL COMFORT**
 - PMV / PPD, OPERATIVE TEMPERATURE
- **LOCAL THERMAL DISCOMFORT**
 - Radiant temperature asymmetry
 - Draught
 - Vertical air temperature difference
 - Floor surface temperature

THERMAL COMFORT

- OPERATIVE TEMPERATURE
- $-0,5 < PMV < +0,5$; $PPD < 10 \%$
- SPACES WITH MAINLY SEDENTARY OCCUPANTS :
 - SUMMER CLOTHING 0,5 clo
 - ACTIVITY LEVEL 1,2 met
- $23\text{ }^{\circ}\text{C} < t_o < 26\text{ }^{\circ}\text{C}.$

GENERAL THERMAL COMFORT

- **Personal factors**
 - Clothing
 - Activity
- **Environmental factors**
 - Air temperature
 - Mean radiant temperature
 - Air velocity
 - Humidity

Categories

| Category | Explanation |
|----------|--|
| I | High level of expectation and also recommended for spaces occupied by very sensitive and fragile persons with special requirements like some disabilities, sick, very young children and elderly persons, to increase accessibility. |
| II | Normal level of expectation |
| III | An acceptable, moderate level of expectation |
| IV | Low level of expectation. This category should only be accepted for a limited part of the year |

Recommended categories for design of mechanical heated and cooled buildings

| Category | Thermal state of the body as a whole | |
|----------|--------------------------------------|----------------------|
| | PPD % | Predicted Mean Vote |
| I | < 6 | $-0.2 < PMV < + 0.2$ |
| II | < 10 | $-0.5 < PMV < + 0.5$ |
| III | < 15 | $-0.7 < PMV < + 0.7$ |
| III | < 25 | $-1.0 < PMV < + 1.0$ |

Evaluation standard for indoor thermal environment in civil buildings

Chinese standard


Table 4.2.4-1 overall thermal comfort index value


| Grade | Overall thermal comfort index | |
|-------|-------------------------------|--|
| I | $PPD \leq 10\%$ | $-0.5 \leq PMV \leq +0.5$ |
| II | $10\% < PPD \leq 25\%$ | $-1 \leq PMV < -0.5$ or $+0.5 < PMV \leq +1$ |
| III | $PPD > 25\%$ | $PMV < -1$ or $PMV > +1$ |

Temperature ranges for hourly calculation of cooling and heating energy in three categories of indoor environment


| Type of building/ space | Category | Operative Temperature for Energy Calculations °C | |
|---|------------|---|------------------------------------|
| | | Heating (winter season), ~ 1,0 clo | Cooling (summer season), ~ 0,5 clo |
| Offices and spaces with similar activity (single offices, open plan offices, conference rooms, auditorium, cafeteria, restaurants, class rooms, Sedentary activity ~1,2 met | I | 21,0 – 23,0 | 23,5 - 25,5 |
| | II | 20,0 – 24,0 | 23,0 - 26,0 |
| | III | 19,0 – 25,0 | 22,0 - 27,0 |
| | IV | 17,0 – 26,0 | 21,0 - 28,0 |

Humidity limits according to ASHRAE-55-2016





ISO DIS 17772-1



$$\Theta_{rm} = (\Theta_{ed-1} + 0,8 \Theta_{ed-2} + 0,6 \Theta_{ed-3} + 0,5 \Theta_{ed-4} + 0,4 \Theta_{ed-5} + 0,3 \Theta_{ed-6} + 0,2 \Theta_{ed-7})/3,8$$

Natural ventilated buildings- without mechanical cooling

- activity levels lie most of the time in the range of 1,2 - 1,6 met
- clothing insulation can be varied according to momentary preferences from 0,5 to 1,0 clo
- access to operable windows
- less than 4 persons per room
- such as dwellings and office buildings.

GENERAL THERMAL COMFORT

- **AIR VELOCITY**
 - Draught
 - Preferred air velocity at increased temperature
 - Direction of air velocity
 - Large individual differences
 - Personal control (fans, windows)

ASHRAE 55-2016




FIGURE 5.3.3A Acceptable ranges of operative temperature (t_o) and average air speed (V_a) for the 1.0 and 0.5 clo comfort zone presented in Figure 5.3.1.1, at humidity ratio 0.010.

LOCAL THERMAL DISCOMFORT

- FLOOR SURFACE TEMPERATURE
- VERTICAL AIR TEMPERATURE DIFFERENCE
- DRAUGHT
- RADIANT TEMPERATUR ASYMMETRI

CRITERIA FOR INDOOR AIR QUALITY ~VENTILATION RATES

- **COMFORT** (Perceived Air Quality)
- HEALTH
- PRODUCTIVITY
- **ENERGY**

Concept for calculation of design ventilation rate


People Component

Building Component


Breathing Zone
Outdoor Airflow



PERCEIVED AIR QUALITY
% DISSATISFIED (PD)



CO₂ as reference



ASHRAE 62.1

TABLE 6-1 MINIMUM VENTILATION RATES IN BREATHING ZONE
(This table is not valid in isolation; it must be used in conjunction with the accompanying notes.)

| Occupancy Category | People Outdoor | Area Outdoor | Notes | Default Values | | Air Class |
|-----------------------|----------------|---------------------|-------|------------------------|-----------------------|--------------|
| | Air Rate | Air Rate | | Occupant Density | Combined Outdoor | |
| | R_p | R_a | | (see Note 4) | Air Rate (see Note 5) | |
| | cfm/person | cfm/ft ² | | #/1000 ft ² | cfm/person | |
| Office Buildings | | | | | | |
| Office space | 5 | 0.06 | | 5 | 17 | 1 |
| Reception areas | 5 | 0.06 | | 30 | 7 | 1 |

MINIMUM VENTILATION RATES IN BREATHING ZONE

| | | | | | | Default Values | | |
|------------------------------|---|------------|--------------------------------------|--------------------|-------|---|--|------------|
| Occupancy Category | People Outdoor Air Rate R _P | | Area Outdoor Air Rate R _A | | Notes | Occupant Density (see Note 4) | Combined Outdoor Air Rate (see Note 5) | |
| | cfm/person | L/s•person | cfm/ft ² | L/s•m ² | | #/1000 ft ² (#/100 m ²) | cfm/person | L/s•person |
| Correctional | | | | | | | | |
| Cell | 5 | 2.5 | 0.12 | 0.6 | | 25 | 10 | 4.9 |
| Day room | 5 | 2.5 | 0.06 | 0.3 | | 30 | 7 | 3.5 |
| Guard stations | 5 | 2.5 | 0.06 | 0.3 | | 15 | 9 | 4.5 |
| Booking/waiting | 7.5 | 3.8 | 0.06 | 0.3 | | 50 | 9 | 4.4 |
| Educational Facilities | | | | | | | | |
| Daycare (through age 4) | 10 | 5 | 0.18 | 0.9 | | 25 | 17 | 8.6 |
| Classrooms (ages 5-8) | 10 | 5 | 0.12 | 0.6 | | 25 | 15 | 7.4 |
| Classrooms (age 9-12) | 10 | 5 | 0.12 | 0.6 | | 35 | 13 | 6.7 |
| Lecture classroom | 7.5 | 3.8 | 0.06 | 0.3 | | 65 | 8 | 4.3 |
| Lecture hall (fixed seating) | 7.5 | 3.8 | 0.06 | 0.3 | | 150 | 8 | 4.0 |
| Art classroom | 10 | 5.0 | 0.18 | 0.9 | | 20 | 19 | 9.5 |

Basic required ventilation rates for diluting emissions (bio effluents) from people for different categories

| Category | Expected Percentage Dissatisfied | Airflow per non-adapted person l/(s.pers) |
|----------|----------------------------------|---|
| I | 15 | 10 |
| II | 20 | 7 |
| III | 30 | 4 |
| IV | 40 | 2,5* |

***The total ventilation rate must never be lower than 4 l/s per person**

ASHRAE Standard 62.1 : Adapted persons 2,5 l/s person (Cat. II)

Design ventilation rates for diluting emissions from buildings

| Category | Very low polluting building l/(s m ²) | Low polluting building l/(s m ²) | Non low- polluting building l/(s m ²) |
|---|--|--|--|
| I | 0,5 | 1,0 | 2,0 |
| II | 0,35 | 0,7 | 1,4 |
| III | 0,2 | 0,4 | 0,8 |
| IV | 0,15 | 0,3 | 0,6 |
| Minimum total ventilation rate for health | 4 l/s person | 4 l/s person | 4 l/s person |

Example on how to define low and very low polluting buildings

| SOURCE | Low emitting products for low polluted buildings | Very low emitting products for very low polluted buildings |
|--|--|--|
| Total VOCs TVOC (as in CEN/TS 16516) | $< 1.000 \mu\text{g}/\text{m}^3$ | $< 300 \mu\text{g}/\text{m}^3$ |
| Formaldehyde | $< 100 \mu\text{g}/\text{m}^3$ | $< 30 \mu\text{g}/\text{m}^3$ |
| Any C1A or C1B classified carcinogenic VOC | $< 5 \mu\text{g}/\text{m}^3$ | $< 5 \mu\text{g}/\text{m}^3$ |
| R value (as in CEN/TS16516) | < 1.0 | < 1.0 |

Total ventilation rate

$$q_{tot} = n \cdot q_p + A_R \cdot q_B$$

$$q_{supply} = q_{tot} / \varepsilon_v$$

- Where
- ε_v = the ventilation effectiveness (EN13779)
- q_{supply} = ventilation rate supplied by the ventilation system
- q_{tot} = total ventilation rate for the breathing zone, l/s
- n = design value for the number of the persons in the room,
- q_p = ventilation rate for occupancy per person, l/s, pers
- A_R = room floor area, m²
- q_B = ventilation rate for emissions from building, l/s,m²

Example of design ventilation air flow rates for a single-person office of 10 m² in a low polluting building (un-adapted person)

| Category | Low-polluting building l/(s*m ²) | Airflow per non-adapted person l/(s*person) | Total design ventilation air flow rate for the room | | |
|----------|---|--|---|--------------|------------------------|
| | | | l/s | l/(s*person) | l/(s* m ²) |
| I | 1,0 | 10 | 20 | 20 | 2 |
| II | 0,7 | 7 | 14 | 14 | 1,4 |
| III | 0,4 | 4 | 8 | 8 | 0,8 |
| IV | 0,3 | 2,5 | 5,5 | 5,5 | 0,55 |

| Type of building/ space | Occu- pancy person/m ² | Cate- gory CEN | Occupants only l/s person | | Additional ventilation for building (add only one) l/s·m ² | | | Total l/s·m ² | |
|--|---|----------------------|---------------------------------|-----|---|---|-------------------|-----------------------------|-------------|
| | | | ASH- RAE Rp | CEN | CEN low- polluting building | CEN <i>Non-low-</i> polluting building | ASH- RAE Ra | CEN Low Pol. | ASH- RAE |
| Single office (cellular office) | 0,1 | A | | 10 | 1,0 | 2,0 | | 2 | |
| | | B | 2,5 | 7 | 0,7 | 1,4 | 0,3 | 1,4 | 0,55 |
| | | C | | 4 | 0,4 | 0,8 | | 0,8 | |
| Land- scaped office | 0,07 | A | | 10 | 1,0 | 2,0 | | 1,7 | |
| | | B | 2,5 | 7 | 0,7 | 1,4 | 0,3 | 1,2 | 0,48 |
| | | C | | 4 | 0,4 | 0,8 | | 0,7 | |
| Confe- rence room | 0,5 | A | | 10 | 1,0 | 2,0 | | 6 | |
| | | B | 2,5 | 7 | 0,7 | 1,4 | 0,3 | 4,2 | 1,55 |
| | | C | | 4 | 0,4 | 0,8 | | 2,4 | |

1 l/s m² = 0.2 cfm/ft²

The design *zone outdoor airflow* (V_{oz})

The outdoor airflow that must be provided to the zone by the supply air distribution system, shall be determined in accordance:

$$V_{oz} = V_{bz}/E_z$$

| Air Distribution Configuration | E_z |
|--|-------|
| Ceiling supply of cool air | 1.0 |
| Ceiling supply of warm air and floor return | 1.0 |
| Ceiling supply of warm air 15°F (8°C) or more above space temperature and ceiling return. | 0.8 |
| Ceiling supply of warm air less than 15°F (8°C) above space temperature and ceiling return provided that the 150 fpm (0.8 m/s) supply air jet reaches to within 4.5 ft (1.4 m) of floor level. Note: For lower velocity supply air, $E_z= 0.8$. | 1.0 |
| Floor supply of cool air and ceiling return provided that the 150 fpm (0.8 m/s) supply jet reaches 4.5 ft (1.4 m) or more above the floor. Note: Most underfloor air distribution systems comply with this proviso. | 1.0 |
| Floor supply of cool air and ceiling return, provided low- velocity displacement ventilation achieves unidirectional flow and thermal stratification | 1.2 |
| Floor supply of warm air and floor return | 1.0 |
| Floor supply of warm air and ceiling return | 0.7 |
| Makeup supply drawn in on the opposite side of the room from the exhaust and/or return | 0.8 |
| Makeup supply drawn in near to the exhaust and/or return location | 0.5 |

ASHRAE 62.1

TABLE 6-2
Zone Air Distribution
Effectiveness

HEALTH CRITERIA FOR VENTILATION

ISO 17772-1 and prEN16798-1

Minimum 4 l/s/person

Indoor Air Quality Procedure

The required ventilation rate is calculated as:

$$Q = \frac{G}{(C_i - C_o) \cdot E_v} \quad \text{l/s}$$

where

| | | |
|---------|------------------------------|------|
| $G =$ | Total emission rate | mg/s |
| $C_i =$ | Concentration limit | mg/l |
| $C_o =$ | Concentration in outside air | mg/l |
| $E_v =$ | Ventilation effectiveness | |

| EPA Ambient-Air Quality Standards | Long Term | | | Short Term | | |
|--------------------------------------|----------------------------|-------|-----------------------|-------------------------|-------------------|----------|
| | Concentration Averaging | | | Concentration Averaging | | |
| | µg/m ³ ppm | | | µg/m ³ ppm | | |
| Sulfur dioxide | 80 | 0.03 | 1 year | 365 ^a | 0.14 ^a | 24 hours |
| Particles (PM 10) | 50 ^b | — | 1 year | 150 ^a | — | 24 hours |
| Carbon monoxide | | | | 40,000 ^a | 35 ^a | 1 hour |
| Carbon monoxide | | | | 10,000 ^a | 9 ^a | 8 hours |
| Oxidants (ozone) | | | | 235 ^c | 0.12 ^c | 1 hour |
| Nitrogen dioxide | 100 | 0.055 | 1 year | | | |
| Lead | 1.5 | — | 3 months ^d | | | |

a Not to be exceeded more than once per year.

b Arithmetic mean.

c Standard is attained when expected number of days per calendar year with maximal hourly average concentrations above 0.12 ppm (235 µg/m³) is equal to or less than 1, as determined by Appendix H to subchapter C, 40 CFR 50.

d Three-month period is a calendar quarter.

| Pollutant | WHO Indoor Air Quality guidelines 2010 | WHO Air Quality guidelines 2005 |
|---|--|---|
| Benzene | No safe level can be determined | - |
| Carbon monoxide | 15 min. mean: 100 mg/m ³ 1h mean: 35 mg/m ³ 8h mean: 10 mg/m ³ 24h mean: 7 mg/m ³ | - |
| Formaldehyde | 30 min. mean: 100 µg/m ³ | - |
| Naphthalene | Annual mean: 10 µg/m ³ | - |
| Nitrogen dioxide | 1h mean: 200 µg/m ³ Annual mean: 40 mg/m ³ | - |
| Polyaromatic Hydrocarbons (e.g. Benzo Pyrene A B[a]P) | No safe level can be determined | - |
| Radon | 100 Bq/m ³ (sometimes 300 mg/m ³ , country-specific) | - |
| Trichlorethylene | No safe level can be determined | - |
| Tetrachloroethylene | Annual mean: 250 µg/m ³ | |
| Sulfure dioxide | - | 10 min. mean: 500 µg/m ³ 24h mean: 20 mg/m ³ |
| Ozone | - | 8h mean: 100 µg/m ³ |
| Particulate Matter PM 2,5 | - | 24h mean: 25 µg/m ³ Annual mean: 10 µg/m ³ |
| Particulate Matter PM 10 | - | 24h mean: 50 µg/m ³ Annual mean: 20 µg/m ³ |

WHO guidelines values for indoor and outdoor air pollutants

INDIA-Indoor Environmental Quality

Table3 Threshold values for indoor air quality parameters

| Parameters | Units | Classification | | |
|-----------------------|--------------------|------------------|------------------|---------------|
| | | Class A | Class B | Class C |
| CO ₂ | ppm | Ambient + 350 | Ambient + 500 | Ambient + 800 |
| PM 2.5 | µg/m ³ | <15 | <25 | <60 |
| PM 10 | µg/m ³ | <50 | <100 | <100 |
| CO | ppm | <9 | <9 | < 9 |
| TVOC | µg/m ³ | <200 | <400 | <600 |
| CH ₂ O | µg/m ³ | <30 | <100 | - |
| SO ₂ | µg/m ³ | <40 | <80 | - |
| NO ₂ | µg/m ³ | <40 | <80 | - |
| O ₃ | µg/m ³ | <50 | <100 | - |
| Total Microbial Count | CFU/m ³ | Indoor ≤ ambient | Indoor ≤ ambient | - |
| User Satisfaction | % | 90 | 80 | - |

Residential buildings

| Category | Total ventilation including infiltration air (1) | | Supply air flow per person (2) | Supply air flow based on perceived IAQ for adapted persons (3) | | Supply air flow based on room level (4) | | Exhaust air flow, l/s peak or boost flow for high demand | | |
|----------|--|-----|--------------------------------|--|-----------------------------|---|-----------------------|--|-------------------|-----------------|
| | l/s,m ² | ach | l/s*per | q_p l/s*per | q_B l/s,m ² | Master bed-room l/s | Other bed-room l/s | Kitchen (3a) | Bathrooms (3b) | Toilets (3c) |
| I | 0,49 | 0,7 | 10 | 3,5 | 0,25 | 20 | 10 | 28 | 20 | 14 |
| II | 0,42 | 0,6 | 7 | 2,5 | 0,15 | 14 | 8 | 20 | 15 | 10 |
| III | 0,35 | 0,5 | 4 | 1,5 | 0,1 | 8 | 4 | 14 | 10 | 7 |
| IV* | 0,23 | 0,4 | | | | 5 | 2,5* | 10 | 6 | 4 |

$$Q_{tot} = 0.15A_{floor} + 3.5(N_{br} + 1) \quad (\text{SI}) \quad (4.1b)$$

where

Q_{tot} = total required ventilation rate, L/s

A_{floor} = dwelling-unit floor area, m²

N_{br} = number of bedrooms (not to be less than 1)

ASHRAE 62.2 Residential

Occupant density:

Two persons (studio, one-bedroom)

Plus one person i.e. plus 3.5 L/s for
each additional bedroom

TABLE 4.1b (SI) Ventilation Air Requirements, L/s

| Floor Area, m ² | Bedrooms | | | | |
|----------------------------|----------|----|----|----|----|
| | 1 | 2 | 3 | 4 | 5 |
| <47 | 14 | 18 | 21 | 25 | 28 |
| 47–93 | 21 | 24 | 28 | 31 | 35 |
| 94–139 | 28 | 31 | 35 | 38 | 42 |
| 140–186 | 35 | 38 | 42 | 45 | 49 |
| 187–232 | 42 | 45 | 49 | 52 | 56 |
| 233–279 | 49 | 52 | 56 | 59 | 63 |
| 280–325 | 56 | 59 | 63 | 66 | 70 |
| 326–372 | 63 | 66 | 70 | 73 | 77 |
| 373–418 | 70 | 73 | 77 | 80 | 84 |
| 419–465 | 77 | 80 | 84 | 87 | 91 |

Example criteria for personalized systems

| Aspect | Requirement |
|------------------------------|---|
| 'Temperature' control winter | At workstation level, the (operative/equivalent) temperature is adjustable with a response speed of at least 0,5 K/minute within a range of 5 K, from 18 °C to 23 °C. |
| 'Temperature' control summer | At workstation level, the (equivalent) temperature is adjustable (with a response speed of at least 0,5 K/minute within a range of 5 K, from 22 °C to 27 °C. |
| Fresh air supply control | Local fresh air supply (per workstation) is adjustable from around 0 to at least 7 l/s. |
| Delivered air quality | For requirements related to air cleaning technology: see Annex K. |
| Installation noise | Noise level – with the personalized system in the highest setting – should not be higher than 35 dB(A). |
| | |





This is a topic under IEA -EBC Annex 69 “Thermal Comfort”

Air Distribution Effectiveness

$$\varepsilon_V = \frac{C_E - C_S}{C_I - C_S}$$

Concentrations: C_E exhaust air
 C_S supply air
 C_I breathing zone

CEN Report CR 1752 (1998)

| Mixing ventilation | | Mixing ventilation | | Displacement ventilation | | Personalized ventilation | |
|---|---------------|---|---------------|---|---------------|---|---------------|
|  | |  | |  | |  | |
| T supply - T inhal °C | Vent. effect. | T supply - T inhal °C | Vent. effect. | T supply - T inhal °C | Vent. effect. | T supply - T room °C | Vent. effect. |
| < 0 | 0,9 - 1,0 | < -5 | 0,9 | <0 | 1,2 - 1,4 | -6 | 1,2 - 2,2 |
| 0 - 2 | 0,9 | -5 - 0 | 0,9 - 1,0 | 0-2 | 0,7 - 0,9 | -3 | 1,3 - 2,3 |
| 2 - 5 | 0,8 | > 0 | 1 | >2 | 0,2 - 0,7 | 0 | 1,6 - 3,5 |
| > 5 | 0,4 - 0,7 | | | | | | |

COMFORT-PRODUCTIVITY

Building costs

| | |
|-------------|-----|
| People | 100 |
| Maintenance | 10 |
| Financing | 10 |
| Energy | 1 |

This clearly show that buildings are for people
not for saving energy