


**Digital Analogue
for Natural
Ventilation Calculations**

R E Bilborrow



Department of Building Science
Faculty of Architectural Studies
University of Sheffield
April 1973

REPORT NO. BS6

A DIGITAL ANALOGUE FOR NATURAL VENTILATION CALCULATIONS.

R.E. BILSBORROW

APRIL 1973

Air Infiltration and Ventilation Centre
University of Warwick Science Park
Barclays Venture Centre
Sir William Lyons Road
Coventry CV4 7EZ
Great Britain
Telephone: (0203) 692050
Telex: 312401
Fax: (0203) 410156

Please return by date below:

11.5.89		
---------	--	--

SUMMARY

The report describes a digital analogue written in 1900 Fortran, which is suitable for computing natural ventilation rates in multi-storey buildings. The assumptions made, data requirements and output available are listed. A print-out of the programme is given.

1. INTRODUCTION

1.1. Digital analogue techniques are being used to produce design information on infiltration and natural ventilation in buildings. This is being done despite the lack of any comparative studies to establish the accuracy of the assumptions and data used in the analogue techniques. A major part of the work in the thesis was concerned with comparative studies between a digital analogue model and full scale and model scale studies. From these studies it was hoped to gain information on the inherent accuracy of the digital analogue method and the data requirements in order to improve design methods. Consequently a programme was written which calculates natural ventilation or infiltration rates in a simple building.

1.2. The programme used the same basic assumptions as used by other natural ventilation prediction programmes. These are:

- (1) that the building is considered as a series of compartments, each of which has a limited number of air flow paths into and out of it through which natural ventilation or infiltration may occur.
- (2) that each flow path has a characteristic flow resistance, representing a doorway, window, air duct or open area, which may be expressed by an equation relating air flow through it to pressure difference acting across it.
- (3) that there is no resistance to air flow inside each compartment of the building.
- (4) that wind forces and stack effect produce external pressures outside each external opening in the building which are time-invariant over the period of time considered in the calculation.
- (5) that the internal air temperature in the building is uniform throughout the building.

2. PROGRAMME SPECIFICATION

2.1. In the programme the maximum number of compartments which may be analysed was 211. These consisted of a maximum of 200 single rooms, up to 10 corridors, one for each floor of the building, and one common stairwell. The single rooms were assumed to be distributed as a maximum of 20 on each of up to 10 floors, each floor being able to have a unique number of rooms. The rooms could be of any required size as ventilation rates were expressed directly in m^3/hr from a knowledge of the room opening characteristics. Each single room was assumed to have two ventilation openings, one connecting it with the exterior of the building and one connecting it with the corridor on that floor. The stairwell compartment was assumed to be linked to each corridor and to have no other ventilation openings. The stairwell compartment could be used to represent either one or several stairwells all opening onto the central corridor. Some representative building plans suitable for analysis by this type of programme are shown in Figure 2.

2.2. Each room in the building, and the openings in and out of that room, were identified by a floor number and room number. The lowest floor is taken to be floor 1. The rooms could be numbered in any order, thus allowing the user to choose a numbering system suited to the building plan. Each opening in the building was assumed to have air flow resistance characteristic values which were used in an equation of the form:

$$V = C.L. (dP)^{1/n} \quad \dots 1.$$

The values of the total leakage coefficient, $C \times L$, and flow exponent, n , could be unique for each opening in the building.

2.3. The input information required by the programme consisted of the following values:

- (1) number of floors in the building,
- (2) floor to floor height, m,
- (3) number of rooms on each floor (even number),
- (4) values of total leakage coefficient for exterior/room opening and room/corridor opening for each room, $\text{m}^3/\text{hr}/\text{mm wg}^{0.6}$.
- (5) values of flow exponent for interior/room opening and room/corridor opening for each room,
- (6) values of total leakage coefficient and flow exponent for each corridor/stairwell opening,
- (7) wind pressure outside each opening expressed as a pressure coefficient with respect to free stream wind speed at building roof height,
- (8) assumed meteorological wind speed, m/s,
- (9) assumed mean internal/external temperature difference, $^{\circ}\text{C}$.

One significant limitation of the programme is that corner rooms with windows opening onto two facades at two different external pressures are not accurately modelled. In these situations a representative external pressure should be taken. If this factor is likely to be important the flow from one window to the other could be considered separately and an estimation of the extra flow found.

2.4. The programme was designed to compute ventilation rate either for one specified set of design meteorological conditions or for an array of meteorological conditions covering the combinations of wind speed and temperature difference normally encountered. The array of meteorological values used consisted of wind speeds 0.001, 1.0, 2.0,

4.0, 6.0, 8.0 m/s and temperature differences of 0.0, 8.0, 16.0 and 24.0 °C. The design meteorological values may be any values of wind speed or temperature difference which do not occur in the array. The meteorological wind speed input was an assumed wind speed from a remote site in open country at a height of 10 m., which was then converted to the site wind speed, assuming the site to be in an urban area. This form of input may easily be altered as was done in the comparative tests, to use the site wind speed as a direct input, or to produce site wind speeds characteristic of suburban or open sites.

2.5. The output information given by the programme consisted of the following values:

- (1) review of the input information used in the programme,
- (2) meteorological wind speed, m/s,
- (3) interior/exterior temperature difference, °F,
- (4) total infiltration rate for the building, m³/hr (total of all air flow rates entering the building through external openings).
- (5) average room ventilation rate, m³/hr,
- (6) standard deviation of room ventilation rates, m³/hr,
- (7) for each room:
 - pressure differences acting across the external and internal ventilation openings, expressed in mm.wg. and as pressure coefficient values,
 - flow rate and direction of flow, m³/hr
- (8) flow rate and direction of flow from the stairwell to the corridor at each floor level, m³/hr,
- (9) pressures in the stairwell and each internal corridor, mm.wg.

The sign convention used for air flow rates and pressure differences in the programme was:

All flows towards the central corridor on that floor level, from

any other part of the floor, are taken to be positive.

All pressure differences which would act to cause positive flow rates are taken to be positive.

3. PROGRAMME DESCRIPTION

3.1. The programme was written in Fortran 1900 language for use on the Sheffield University I.C.L. 1907 computer. The programme works on the basis of making successive approximations of the ventilation rates occurring throughout the building until the estimated rates are within the required accuracy limits. The approximation techniques used in the programme are illustrated by the flow charts shown in Figure 1. These are discussed in more detail in the following section and related to the appropriate steps in the full programme. A print-out of the full programme is given in Appendix A1. In the following paragraphs figures in parentheses refer to line numbers of the programme shown in Appendix A1.

3.2. The analysis is carried out in three main consecutive steps in the programme. These are shown in Figure 1. Initially the external pressures outside each of the external openings, caused by wind pressure alone, are found. Each floor is analysed separately, considering it to be isolated from the rest of the building. The pattern of ventilation for the floor is found, and also the absolute pressure on the corridor of each floor. A flow diagram of this section may be seen in Figure 1(a). The detailed operations are noted below:

- (1) Each floor is considered in turn, (74, 152).
- (2) The convergency rate figure is set to one, (75).
- (3) Initial internal pressures are set up (76 - 85):

the corridor pressure is set to the average of all the external pressures acting outside that floor,

the room pressures are set to half the difference between the corridor pressure and the appropriate external pressure.

- (4) The accuracy limits are set up, (86-7):

the current values of two pressure differences are set to LIM1, LIM2; at the end of the cycle the current values are compared with LIM1, LIM2. If the pressure difference values have changed by more than 1/1000 of their value during the cycle LIM1 and LIM2 are set to the new current values and the cycle repeated.

- (5) The ventilation rates are calculated through all openings on the floor and are balanced, (88-104):

for each room in turn the flow rates in and out are equated, each being set at the average of the two flow rates,

for the corridor, the net flow is found and the room/corridor flow rates altered proportionally so that the net flow is made zero.

the balance of air flow through each room is checked and if necessary adjusted,

the balance of air flow into the corridor is checked and if necessary adjusted.

- (6) The pressure differences are re-calculated and balanced, (105-134):

they are correlated with the values of the external pressures and altered so that they are in agreement with these values.

- (7) The number of cycles carried out is checked. If this is over 50 the analysis is stopped, the number of cycles and current values being written out, (135-6, 141-2).

- (8) The relevant pressure differences are checked against LIM1, LIM2 and if not sufficiently accurate the approximation cycle is repeated, (137-140).

- (9) The variable values used to calculate the combined ventilation rates are set up (143-151).

3.3. In the second section of the analysis the stack effect, assumed to be acting alone, is considered. A neutral zone height is found such that the net flow from all corridors to the stairwell is zero. The corridors are assumed to be at zero pressure relative to each other from forces other than stack effect. The stack pressures found by this analysis are added to all relevant wind induced pressures found in the initial analysis step. Figure 1(b) shows a flow diagram for

this section and the detailed steps are again noted below:

- (1) Assume an initial neutral zone height of half of the building height, and calculate the pressures due to stack effect, (157-160).
- (2) Calculate the net flow into the corridor from each stairwell (161-5).
- (3) If the net flow into the stairwell is zero add the relevant stack pressures to each level of the building assuming the current value of neutral zone height (166, 189-195).
- (4) If the net flow into the stairwell is positive, decrease the neutral zone height progressively, in steps of 1/500 building height, until the net flow becomes zero or negative, (166-177, 189-195)

if the net flow becomes zero assume the current neutral zone height value,

if the net flow becomes negative assume a value half way between the current value and the value used in the previous cycle,

add the relevant stack pressures to each level of the building.

- (5) If the net flow into the stairwell is negative increase the neutral zone height progressively, in steps of 1/500 building height, until the net flow becomes zero or positive, (166, 178-195):

if the net flow becomes zero assume the current neutral zone height value,

if the net flow becomes positive assume a value half way between the current value and the value used in the previous cycle,

add the relevant stack pressures to each level of the building.

3.4. The combined ventilation rates, assuming both wind and stack effect to be acting simultaneously, are calculated in the third section of the programme. Each floor is analysed again, this time with the presence of the stairwell, at the appropriate pressure taken into account. Flow rates are balanced until the net flow into each central corridor from the rooms on the floor and the stairwell is again zero. These results are taken to represent the final estimated ventilation pattern for the building. Once again a flow diagram is given, (see in Figure 1(c)) and the detailed steps noted below:

- (1) Each floor is considered in turn (200, 256)

(2) The pressure difference between the relevant corridor and the stairwell is calculated (201, 202).

(3) The increment value is set, (203):

the ventilation pattern is found by a series of approximations, altering the corridor pressure by increments; the incremental values are made progressively smaller and the accuracy limits are assumed to be met when the incremental values become equal to preset limiting values.

(4) The stairwell to corridor pressure difference is decreased by a factor of one increment, (204-5):

as the flow pattern for each floor was previously balanced, the introduction of the stairwell at a different pressure will cause the corridor pressure to be altered, the corridor pressure becoming nearer in value to the stairwell pressure.

(5) All pressure differences on the floor are re-calculated, (206-219):

this procedure is carried out by a series of approximations; the pressures cannot be simply altered in proportion due to the different possible flow exponent values of the openings.

(6) The flow rates are calculated for these new pressure differences, the flow for each room balanced, and the pressure differences re-calculated from the balanced flows (220-239).

(7) The net flow into the central corridor is calculated, (240-250):

if the net flow is positive and the stairwell to corridor pressure difference is positive or if the net flow is negative and the stairwell to corridor pressure difference is negative then the corridor pressure has not been altered sufficiently to balance the total flow on the floor; the stairwell to corridor pressure difference is reduced further, if these conditions are not met then the corridor pressure has been compensated at least enough and the accuracy check is made.

(8) The value of the increment is checked, (251-254):

if this is larger than the preset limiting value then the value of the increment is reduced by a factor of ten, the corridor pressure reset to its previous value and the calculation repeated from step 4,

if the incremental value is sufficiently small the analysis is stopped.


3.5. Summary ventilation rate values are calculated from the final calculated detailed ventilation rates (257-274). and the results are

printed (275-306). The values of temperature difference and wind speed assumed in the input are cycled in turn, and in that order, if this type of analysis is required (308-327). Each time the temperature difference is changed the second and third steps are repeated. Only when the wind speed is changed is the first step repeated in addition.

3.6. One further approximation is made in the programme which has not been discussed. The stairwell pressure in the final analysis is set to the mean wind-induced corridor pressure and the flow rates into and out of the stairwell are not balanced by the programme. However the stack pressures are calculated from the estimated neutral zone height so that the stack induced ventilation through the staircase would be balanced (paragraph 3.5.). As these ventilation forces are likely to produce the major part of the vertical air movement it was decided that the added accuracy which might be achieved in balancing the stairwell air flow system would not justify the increase in computing time required.

Figure 1. Flow chart for building ventilation prediction program, BT5VENT4.

Symbols used in flow diagram.



See Figure 5.1(a) for detailed flow chart for this section.

See Figure 5.1(b) for detailed flow chart for this section.

See Figure 5.1(c) for detailed flow chart for this section..

Flow diagram, summary chart.




Figure 1(a).

Calculation of ventilation rates due to wind alone, floors considered in isolation.




Figure 1(b). Calculation of neutral zone height.




Figure .1(c).

Calculation of combined ventilation rates.





Figure 2.


Typical plan forms suitable for analysis by
BT5VENT4

S Stairwell
C Corridor


Slab block:



Uniformly glazed building:



Courtyard building:



The following are the major abbreviations used in the programme:

N(J)	Number of rooms on floor J
M	Room number
K	Number of floors in building
J	Floor number
FLTOFL	Floor to floor height, m
HT	Building height, m
WINDMET	Meteorological wind speed, m/s, at 10 m height in open country
WIND	Site wind speed, at building roof height, m/s
TDIFF	Interior/exterior temperature difference, °C
SP	Pressures generated by stack effect, mm.wg./m/°C
VE(J,M) or VEI(J,M)	Volumetric flow rate through the external opening in room M, floor J, m ³ /hr
PDE(J,M) or PDEI(J,M)	Pressure difference acting across the external opening in room M, floor J, mm.wg
PCOEFEE(J,M)	Pressure difference acting across the external opening in room M, floor J, expressed as a pressure coefficient
CLI(J,M)	Total leakage coefficient for the external opening in room M, floor J, m ³ /hr/mm.wg ^{1/n}
ZI(J,M)	Reciprocal of the flow exponent for the external opening in room M, floor J
PE(J,M)	External pressure outside room M, floor J, caused by the wind speed, mm.wg
CE(J,M)	External pressure outside room M, floor J, caused by the wind, expressed as a pressure coefficient

relative to the free stream wind speed at the building roof height

VC(J,M) or Volumetric flow rate through the internal opening
 VCI(J,M) in room M, floor J, m^3/hr

PDC(J,M) or Pressure difference acting across the internal
 PDCI(J,M) opening in room M, floor J, m^3/hr

PCOEFFC(J,M) Pressure difference acting across the internal opening in room M, floor J, expressed as a pressure coefficient

CL2(J,M) Total leakage coefficient for the internal opening in room M, floor J, $m^3/hr/mm.wg^{1/n}$

Z2(J,M) Reciproval of the flow exponent for the internal opening in room M, floor J

VSTAIR(J) Volumetric flow rate through the corridor/stairwell opening, floor J, m^3/hr

PSTAIR(J) Pressure difference in the stairwell, mm.wg

CLS(J) Total leakage coefficient for the corridor/stairwell opening, $m^3/hr/mm.wg^{1/n}$

ZS(J) Reciprocal of flow exponent for the corridor/stairwell opening, floor J.

PDCS(J) Pressure difference acting across the corridor/stairwell opening, floor J, mm.wg

PC(J) Corridor pressure, floor J, mm.wg

ZTOTVENT Sum of ventilation rates for all rooms, m^3/hr

ZINFILT Sum of ventilation rates for all rooms where the flow direction is into the building, m^3/hr

ZAVVENT Average room ventilation rate, m^3/hr

ZSTDEV Standard deviation of all room ventilation rates, m^3/hr

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line. Column. 10 20 30 40 50 60 70 80

```

1
2 JOB RTSVENT4, 18078T5C, RILSROR:R0W
3 FORTRAN 1, CR0(BTSVENT4PROG), CRJ(BTSVENT4DATA), 500, 5000

```

```

4 ***
5 DOCUMENT BTSVENT4PR0G
6 PROGRAM(BTSV18078T5C)
7 INPUT 1=CR0
8 OUTPUT 2=LPR0
9 END

```

```

10
11 MASTER VENTPL0T4
12 C THE PROGRAM COMPUTES VENTILATION RATES AND PRESSURES BASED ON THE
13 C EQUATION FOR FLOW THROUGH AN ORIFICE V=CL * ((P/D) ** 1/2)
14 C EITHER FOR AN ARRAY OF CLIMATIC VARIABLES OF VALUE?
15 C WIND SPEED 0.001 1.0 2.0 4.0 6.0 8.0 TEMP DIFF 0.0 8.0 16.0 24.0
16 C WHERE INITIAL VALUES SHOULD BE 0.001 M/S. AND 8.0 DC.
17 C OR FOR ANY SPECIFIC CASE WHERE THE VALUES OF THE VARIABLES ARE NOT
18 C ANY OF THOSE OCCURRING IN THE CLIMATIC ARRAY

```

INDEPENDENT FLOOR BY FLOOR ANALYSIS GIVING P(C,J)

```

19 C
20 C
21 C N(J) IS NO. OF ROOMS ON FLOOR J M IS ROOM NUMBER
22 C K IS NO. OF FLOORS J IS FLOOR NUMBER
23 C VE OR VE1 IS VOLUME FLOW CMH, FROM EXTERIOR TO ROOM M
24 C VC OR VC1 IS VOLUME FLOW CMH, FROM ROOM M TO CORRIDOR
25 C VSTAIR IS VOLUME FLOW RATE CMH, FROM STAIR TO CORRIDOR
26 C PE IS EXTERNAL PRESSURE MM.WG, OUTSIDE ROOM M
27 C CE IS PRESSURE COEFFICIENT OUTSIDE ROOM M
28 C PDE OR PDE1 IS PRESSURE DIFFERENCE MM.WG, FROM EXTERIOR TO ROOM M
29 C PCOEFFC IS PRESSURE DIFFERENCE FROM OUTSIDE TO ROOM M
30 C PCOEFFE IS PRESSURE DIFFERENCE FROM OUTSIDE TO ROOM M
31 C IN PRESSURE COEFFICIENT FURN
32 C PDC OR PDC1 IS PRESSURE DIFFERENCE MM.WG, FROM ROOM M TO CORRIDOR
33 C PCOEFFC IS PRESSURE DIFFERENCE ROOM M TO CORRIDOR
34 C IN PRESSURE COEFFICIENT FURN
35 C PC IS PRESSURE IN CORRIDOR MM.WG.
36 C PSTAIR OR PSTAIR1 IS PRESSURE IN STAIRWELL MM.WG.

```

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line.	Column.	Code
37	10	PGCS OR PDGS1 TS PRESSURE DIFFERENCE MMWG. BETWEEN CORRIDOR AND STAIR
38	20	DIMENSION VE(10,20),PDE(10,20),PDC(10,20),VC(10,20),PF(10,20)
39	30	DIMENSION VE1(10,20),PDE1(10,20),PDC1(10,20),VC1(10,20),CF(10,20)
40	40	DIMENSION Z1(10,20),CL1(10,20),Z2(10,20),C12(10,20),PC(10),N(10)
41	50	DIMENSION PSTAIR(10),VSTAIR(10),CLS(10),ZS(10),PDGS(10)
42	60	DIMENSION PSTAIR1(10),PDGS1(10),PCOEFFC(10,20)
43	70	READ(1,101)K
44	80	READ(1,104)FLTTOFL
45		HT=FLTTOFL*K
46		FORMAT(12)
47	101	D) 40 J=1,K
48		READ(1,101)N(J)
49		D) 41 M=1,N(J)
50		READ(1,102)CL1(J,N),CL2(J,M),Z1(J,M),Z2(J,M)
51	102	FORMAT(4F0.0)
52	41	CONTINUE
53		READ(1,103)CLS(J),ZS(J)
54	40	CONTINUE
55		READ(1,104)((CE(J,M),M=1,N(J)),J=1,K)
56	104	FORMAT(200F0.0)
57		READ(1,103)WINDMFT,TDIFF
58	103	FORMAT(2F0.0)
59		D) 44 J=1,K
60		WRITE(2,105)J,CLS(J),ZS(J)
61		WRITE(2,106)
62		D) 45 M=1,N(J)
63	45	WRITE(2,107)CE(J,N),CL1(J,M),CL2(J,M),Z1(J,M),Z2(J,M)
64	44	CONTINUE
65	105	FORMAT(1H0,10HFLNOR NU.=,12,10X,4HCLS=,F6.1,5X,3HZS=,F5.2)
66	106	FORMAT(20X,2HPE,10X,3HCL1,10X,3HCL2,10X,2HZ1,10X,2HZ2)
67	107	FORMAT(20X,F4.2,F4X,F7.1,6X,F7.1,8X,F4.2,8X,F4.2)
68		WIND=WINDMET*1.62*((HT/500.0)**0.33)
69		PCTOT=0.0
70		D) 46 J=1,K
71		D) 47 M=1,N(J)
72	47	PE(J,M)=CE(J,N)*0.0624*WIND*WIND

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line.	Column.	Code
73	46	CONTINUE
74		D) 29 J=1,K
75		CYCLE=1.0
76		PETOT=0.0
77		D) 18 M=1,N(J)
78	18	PETOT=PETOT+PE(J,11)
79		PEAVG=PETOT/N(J)
80		D) 27 M=1,N(J)
81		PDE(J,M)=(PE(J,M)-PEAVG)/2.0
82		PDC(J,M)=(PE(J,M)-PEAVG)/2.0
83		IF(PDE(J,M).EQ.0.0)PDE(J,11)=0.01
84		IF(PDC(J,M).EQ.0.0)PDC(J,11)=0.01
85	27	CONTINUE
86	17	ALIM1=PDE(J,1)
87		ALIM2=PDE(J,N(J))
88		D) 11 M=1,N(J)
89		IF(PDE(J,M).GE.0.0)VE(J,M)=CL1(J,M)+(PDE(J,M)**(1/Z1(J,M)))
90		IF(PDE(J,M).LT.0.0)VE(J,M)=-CL1(J,M)+
91		((ABS(PDE(J,M)))**((1/Z1(J,M))))
92		IF(PDC(J,M).GE.0.0)VC(J,M)=CL2(J,M)+(PDC(J,M)**(1/Z2(J,M)))
93	11	IF(PDC(J,M).LT.0.0)VC(J,M)=-CL2(J,M)+
94		((ABS(PDC(J,M)))**((1/Z2(J,M))))
95	20	D) 12 M=1,N(J)
96		VE(J,M)=(VE(J,M)+VC(J,M))/2.0
97	12	VC(J,M)=VE(J,11)
98		H=0.0
99		D) 23 M=1,N(J)
100	23	H=H+VC(J,M)
101		D) 19 M=1,N(J)
102	19	VC(J,M)=VC(J,11)-H/N(J)
103		IF(ABS(VC(J,1))-ABS(VE(J,1)))<.GT.
104		(ABS(VC(J,1))/10000.0))GO TO 20
105		D) 13 M=1,N(J)
106		IF(VE(J,M).GE.0.0)PDE(J,M)=(VE(J,M)/CL1(J,M))**Z1(J,M)
107		IF(VE(J,M).LT.0.0)PDE(J,M)=-((ABS(VE(J,M)))/CL1(J,M))**Z1(J,M)
108		IF(VC(J,M).GE.0.0)PDC(J,M)=(VC(J,M)/CL2(J,M))**Z2(J,M)

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line.	Column.	
109	10	IF(VC(J,M),T,0.0)PDC(J,M)=-((ABS(VC(J,M)))/CI2(J,M))*72(J,M)
110	13	D) 14 M=1,N(J)/2
111		F1=PDE(J,M)+PDC(J,M)-PDC(J,N(J)/2+M)
112		F2=PE(J,M)-PE(J,N(J)/2+M)
113		IF(F1.E0.0)F1=F1+0.001
114		IF(PE(J,M)-PE(J,N(J)/2+M))21,22,21
115	22	PDE(J,M)=PDE(J,N(J)/2+M)/(PDE(J,M)+PDC(J,M))*2.0)
116		PDC(J,M)=PDC(J,M)-F1*PDC(J,M)/(PDE(J,M)+PDC(J,M))*2.0)
117		PDC(J,N(J)/2+M)=PDC(J,N(J)/2+M)+F1*PDC(J,N(J)/2+M)/
118		((PDE(J,N(J)/2+M)+PDC(J,N(J)/2+M))*2.0)
119		PDE(J,N(J)/2+M)=PDE(J,N(J)/2+M)+F1*PDE(J,N(J)/2+M)/
120		((PDE(J,N(J)/2+M)+PDC(J,N(J)/2+M))*2.0)
121		GO TO 24
122	21	F=F2/F1
123		PDE(J,M)=PDE(J,M)*F
124		PDC(J,M)=PDC(J,M)*F
125		PDC(J,N(J)/2+M)=PDC(J,N(J)/2+M)*F
126		PDE(J,N(J)/2+M)=PDE(J,N(J)/2+M)*F
127	24	CONTINUE
128	14	CONTINUE
129		D) 15 M=1,N(J)-1
130		G=(PE(J,M)-PDE(J,M))-PDC(J,M)-PE(J,M+1)+PDE(J,M+1)+PDC(J,M+1))/2.0
131		PDE(J,M)=PDF(J,M)+G*PDE(J,M)/(PDE(J,M)+PDC(J,M))
132		PDC(J,M)=PDC(J,M)+G*PDC(J,M)/(PDE(J,M)+PDC(J,M))
133		PDC(J,M+1)=PDC(J,M+1)-G*PDC(J,M+1)/(PDC(J,M+1)+PDE(J,M+1))
134	15	PDE(J,M+1)=PDE(J,M+1)-G*PDE(J,M+1)/(PDC(J,M+1)+PDE(J,M+1))
135		CYCLE=CYCLE+1.0
136		IF(CYCLE.GT.50.5)GO TO 31
137		IF(ABS(ALIM1-PDE(J,1)).LT.ABS(PDE(J,1)/1000.0))GO TO 16
138		G) TO 17
139	16	IF(ABS(ALIM2-PDE(J,N(J))).LT.ABS(PDE(J,N(J))/1000.0))GO TO 28
140		G) TO 17
141	31	WRITE(2,108)
142	108	F)RMAT(1H1,30HCURRENT VALUES AFTER 50 CYCLES)
143	28	PC(J)=((PE(J,1)-PDE(J,1)-PDC(J,1))+PE(J,N(J))
144		-PDE(J,N(J))-PDC(J,N(J)))/2.0

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line. Column. 10 20 30 40 50 60 70 80

```

145 PCTOT=PCTOT+PC(J)
146 PCAVG=PCTOT/K
147 D) 30 M=1,N(J)
148 VE1(J,M)=VE(J,M)
149 PUE1(J,M)=PNE(J,M)
150 PDC1(J,M)=PDC(J,M)
151 VC1(J,M)=VC(J,M)
152 CUNTINUE
153 C
154 C
155 C
156 C
157 C
158 C
159 C
160 C
161 C
162 C
163 C
164 C
165 C
166 C
167 C
168 C
169 C
170 C
171 C
172 C
173 C
174 C
175 C
176 C
177 C
178 C
179 C
180 C

```

CALCULATION OF NEUTRAL ZONE HEIGHT

```

218 ZN=HT/2.0
    SP=0.0044*TDIFF
D) 211 J=1,K
PSTAIR(J)=-((ZN-((J-1)*FLTJFL)-1.0)*SP
VSTOT=0.0
D) 212 J=1,K
IF(PSTAIR(J).GE.0.0)VSTAIR(J)=CLS(J)*(PSTAIR(J)**((1/7S(J))))
IF(PSTAIR(J).LT.0.0)VSTAIR(J)=-CLS(J)*(ABS(PSTAIR(J))**((1/7S(J))))
VSTOT=VSTOT+VSTAIR(J)
IF(VSTOT)240,299,242
ZN=ZN-(HT/500.0)
D) 213 J=1,K
PSTAIR(J)=-((ZN-((J-1)*FLTJFL)-1.0)*SP
VSTOT=0.0
D) 214 J=1,K
IF(PSTAIR(J).GE.0.0)VSTAIR(J)=CLS(J)*(PSTAIR(J)**((1/7S(J))))
IF(PSTAIR(J).LT.0.0)VSTAIR(J)=-CLS(J)*(ABS(PSTAIR(J))**((1/7S(J))))
VSTOT=VSTOT+VSTAIR(J)
IF(VSTOT)240,299,243
ZN=ZN+(HT/1000.0)
G) TO 299
ZN=ZN+(HT/500.0)
D) 215 J=1,K
PSTAIR(J)=-((ZN-((J-1)*FLTJFL)-1.0)*SP

```


Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line. Column.

10 20 30 40 50 60 70 80

VSTOT=0.0

181 D) 216 J=1,K

182 IF(PSTAIR(J),GE,0.0)VSTAIR(J)=CLS(J)*(PSTAIR(J)**(1/ZS(J)))

183 IF(PSTAIR(J),LT,0.0)VSTAIR(J)=-CLS(J)*(ABS(PSTAIR(J))**(1/ZS(J)))

184 VSTOT=VSTOT+VSTAIR(J)

185 IF(VSTOT)244,209,242

186 ZN=ZN-(HT/1000.0)

187 G) TO 299

188 DO 217 J=1,K

189 PC(J)=PC(J)+(ZN-((J-1)*FLTOFL)-1.0)*SP

190 PSTAIR(J)=PCAVG

191 DO 220 J=1,K

192 D) 219 M=1,N(J)

193 PE(J,M)=PE(J,M)+(ZN-((J-1)*FLTOFL)-1.0)*SP

194 C) CONTINUE

195

196

197

198

199

200

201 DU 320 J=1,K

202 PSTAIR1(J)=PSTAIR(J)

203 PDCS(J)=PSTAIR1(J)-PC(J)

204 DENOM=10.0

205 PC(J)=PC(J)+PDCS(J)/DENOM

206 PDCS1(J)=PSTAIR1(J)-PC(J)

207 D) 321 M=1,N(J)

208 PDE1(J,M)=(PDE(J,M))/(PDE(J,M)+PDC(J,M))*(PE(J,M)-PC(J))

209 RATIO=PDE1(J,M)/PDE(J,M)

210 IF(RATIO,LT,0.0)GO TO 340

211 PDC1(J,M)=PDC(J,M)*(RATIO*(Z2(J,M)/Z1(J,M)))

212 G) TO 338

213 PDC1(J,M)=-PDC(J,M)*(ABS(RATIO))*(Z2(J,M)/Z1(J,M))

214 PDE1(J,M)=(PDE1(J,M))/(PDE1(J,M)+PDC1(J,M))*(PF(J,M)-PC(J))

215 RATIO=PDE1(J,M)/PDE(J,M)

216 IF(RATIO,LT,0.0)GO TO 341

PDC1(J,M)=PDC(J,M)*(RATIO*(Z2(J,M)/Z1(J,M)))

|||||

|||||

|||||

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line. Column. 10 20 30 40 50 60 70 80

```

217      GO TO 342
218      PDC1(J,M)=- (PDC(J,M)*((ABS(RATIO))** (Z2(J,M)/Z1(J,M))))
219      C)NTINUE
220      IF(PDE1(J,M).GE.0.0)GO TO 322
221      VE1(J,M)=-CL1(J,M)*((ABS(PDE1(J,M))))** (1/Z1(J,M))
222      G) TO 323
223      VE1(J,M)=CL1(J,M)* (PDE1(J,M))* (1/Z1(J,M))
224      IF(PDC1(J,M).GF.0.0)GO TO 324
225      VC1(J,M)=-CL2(J,M)* ((ABS(PDC1(J,M))))** (1/Z2(J,M))
226      G) TO 325
227      VC1(J,M)=CL2(J,M)* (PDC1(J,M))* (1/Z2(J,M))
228      VE1(J,M)=(VE1(J,M)+VC1(J,M))/2.0
229      VC1(J,M)=VE1(J,M)
230      DO 326 M=1,N(J)
231      IF (VE1(J,M).GE.0.0)GO TO 327
232      PDE1(J,M)=- ((ABS(VE1(J,M)))/CL1(J,M))*Z1(J,M)
233      GO TO 328
234      PDE1(J,M)=(VE1(J,M)/CL1(J,M))*Z1(J,M)
235      IF(VC1(J,M).GE.0.0)GO TO 329
236      PDC1(J,M)=- ((ABS(VC1(J,M)))/CL2(J,M))*Z2(J,M)
237      GO TO 326
238      PDC1(J,M)=(VC1(J,M)/CL2(J,M))*Z2(J,M)
239      C)NTINUE
240      WTOT=0.0
241      DO 330 M=1,N(J)
242      WTOT=WTOT+VE1(J,M)
243      IF(PDCS1(J).GE.0.0)GO TO 331
244      VSTAIR(J)=-CLS(J)* ((ABS(PDCS1(J))))** (1/ZS(J))
245      G) TO 332
246      VSTAIR(J)=CLS(J)* (PDCS1(J))* (1/ZS(J))
247      C)NTINUE
248      WTOT=WTOT+VSTAIR(J)
249      IF(PDCS(J).GE.0.0.AND.WTOT.GE.0.0)GO TO 399
250      IF(PDCS(J).LT.0.0.AND.WTOT.LT.0.0)GO TO 399
251      PC(J)=PC(J)-PDCS(J)/DENOM
252      IF(DENOM.GE.999.0)GO TO 308

```

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line. Column.

```

253 DENOM=DENOM*10.0
254 GO TO 399
255 PC(J)=PC(J)+PDCS(J)/DENOM
256 C=INTINUE
257 VELHEAD=0.0624*WIND*WIND
258 ZINFILT=0.0
259 ZNOROOM=0.0
260 ZTOTVENT2=0.0
261 ZTOTVENT=0.0
262 ZAVVENT=0.0
263 DO 336 J=1,K
264 DO 335 M=1,N(J)
265 PCOEFFE(J,M)=PDE1(J,M)/VELHEAD
266 IF(ABS(PCOEFFE(J,H)).GE.10.0)PCOEFFE(J,M)=0.0
267 PCOEFFC(J,M)=PDC1(J,M)/VELHEAD
268 IF(ABS(PCOEFFC(J,H)).GE.10.0)PCOEFFC(J,M)=0.0
269 ZTOTVENT2=ZTOTVENT2+(VF1(J,M)**2)
270 ZTOTVENT=ZTOTVENT+ABS(VE1(J,M))
271 IF(VE1(J,M).GT.0.0)ZINFILT=ZINFILT+VE1(J,M)
272 ZNOROOM=ZNOROOM+N(J)
273 ZAVVENT=ZTOTVENT/ZNOROOM
274 ZSTDEV=SQRT((ZTOTVENT2/ZNOROOM)-(ZAVVENT*ZAVVENT))
275 C
276 C
277 C
278 C
279 PRINTOUT OF RESULTS
280 WRITE(2,301)WINDMET,TDIFF
281 WRITE(2,302)ZINFILT
282 WRITE(2,303)ZAVVENT
283 WRITE(2,304)ZSTDEV
284 DO 310 J=1,K
285 WRITE(2,305)
286 DO 311 M=1,N(J)-1,2
287 M4=M+1
288 WRITE(2,306)J,M,VE1(J,M),PCOEFFE(J,M),PDE1(J,M),PDC1(J,M)
289 MM=VF1(J,MM)} PCJEFFC(J,MM)} PDE1(J,MM)} PDC1(J,MM)}
290 MM=VE1(J,MM)} PCJEFFC(J,MM)} PDE1(J,MM)} PDC1(J,MM)}

```

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line.	Column.	10	20	30	40	50	60	70	80	
289	310	CONTINUE								
290		WRITE(2,307)								
291		D) 339 J=1,K								
292	339	WRITE(2,308)J,VSTAIR(J),PSTAIR(J),PC(J)								
293	301	FORMAT(1H1,22HRESULTS FOR WIND SPEED,F5.2,								
294	1	29HM/S. TEMPERATURE DIFFERENCE,F5.2,3HDC.)								
295	302	FORMAT(1H0,29HTOTAL INFILTRATION RATE, CMH.,21X,F8.2)								
296	303	FORMAT(1H0,35HAVERAGE ROOM VENTILATION RATE, CMH.,15X,F8.2)								
297	304	FORMAT(1H0,46HSTANDARD DEIN. OF ROOM VENTILATION RATES, CMH.,								
298	1	4X,F8.2)								
299	305	FORMAT(1H0,10HFLOOR ROOM,5X,7HVE(CMH),5X,7HPDE(CP.,5X,3HMM),5X,								
300	1	7HPDC(MM),9X,10HFLOOR ROOM,5X,7HVF(CMH),5X,7HPDE(CP.,5X,3HMM),								
301	2	5X,7HPDC(MM))								
302	306	FORMAT(I4,3X,I2,5X,F8.2,5X,F5.2,3X,F7.3,5X,F7.3,9X,I4,3X,I2,5X,								
303	1	F8.2,5X,F5.2,3X,F7.3,5X,F7.3)								
304	307	FORMAT(1H0,5HFLOOR,10X,6HVSTAIR,6X,6HPSTAIR,12X,9HPCORRIDOR)								
305	308	FORMAT(I4,10X,F8.2,4X,F7.3,13X,F7.3)								
306	C									
307	C									
308	C	RECYCLING OF WIND AND TEMPERATURE VALUES								
309	C									
310		TDIFF1=1000.0								
311		IF(TDIFF.EQ.0.0)TDIFF1=8.0								
312		IF(TDIFF.EQ.8.0)TDIFF1=16.0								
313		IF(TDIFF.EQ.16.0)TDIFF1=24.0								
314		IF(TDIFF.EQ.24.0)GO TO 337								
315		TDIFF=TDIFF1								
316		IF(TDIFF.EQ.8.0.OR.TDIFF.EQ.16.0.OR.TDIFF.EQ.24.0)GO TO 218								
317		WIND1=1000.0								
318	337	TDIFF=0.0								
319		IF(WINDMET.EQ.0.001)WIND1=1.00								
320		IF(WINDMET.EQ.1.00)WIND1=2.00								
321		IF(WINDMET.EQ.2.00)WIND1=3.00								
322		IF(WINDMET.EQ.4.00)WIND1=6.00								
323		IF(WINDMET.EQ.6.0)WIND1=8.00								
324		IF(WINDMET.EQ.8.00)GO TO 400								

Appendix A1 Digital analogue programme to determine natural ventilation in buildings.

Line.	Column.	
		10 20 30 40 50 60 70 80
325		WINDMET=WIND1
326		IF(WINDMET.EQ.1.00.OR.WINDMET.EQ.2.00.OR.WINDMET.EQ.3.00)GO TO 44
327		IF(WINDMET.EQ.6.00.OR.WINDMET.EQ.8.00)GO TO 44
328	400	STOP
329		END
330		FINISH
331		*****

