

NATIONAL RESEARCH COUNCIL OF CANADA
DIVISION OF BUILDING RESEARCH

FORTRAN IV PROGRAM TO CALCULATE
AIR INFILTRATION IN BUILDINGS

by

D. M. Sander

Computer Program No. 37
of the
Division of Building Research

OTTAWA
May 1974

FORTRAN IV PROGRAM TO CALCULATE AIR INFILTRATION IN BUILDINGS.

by

D. M. Sander

Air leakage through the exterior envelope of a building is an important factor in calculating heating and cooling loads and in considering moisture problems. The purpose of this program is to calculate the air flows and pressure differentials that will occur in a building as a result of a combination of wind effect, stack action and operation of air handling systems.

MATHEMATICAL MODEL OF BUILDING

The building model has previously been described by Tamura (1). It is represented by a set of compartments stacked one on top of another and by a set of shafts that pass through all the compartments. Leakage openings are present in each outside wall of each compartment and in all the floors and shaft walls so that air can pass from every compartment to adjacent compartments and to each of the vertical shafts. Each compartment may represent a number of building storeys in order to save computation time. Each shaft may have two vents to outside. Vent openings are designated "top" and "bottom," but they may be located at any level. The effects of the air handling systems are accounted for by specifying the net quantity of air supplied to each vertical shaft and to each compartment. Stack effect is calculated for the given outdoor temperature.

The flow equation used is

$$F = EA (\Delta P)^x \quad (1)$$

where F = flow rate through a leakage opening (cfm)

EA = flow coefficient (cfm/in.^x) *

ΔP = pressure differential (in.)

x = flow exponent ($0.5 \leq x \leq 1.0$)

In order to account for the effects of wind, the pressures due to wind on each face of the building at each level must be determined. This may be done by specifying a matrix of wind pressure

* inch = 5.2 lb/ft², which is the pressure of one inch head of water

coefficients that relate the wind pressures at each level to the ambient wind velocity pressure, based on the wind speed at a height of 30 ft as measured by a meteorological station. These wind pressure coefficients account for wind velocity profile, ground effect, and shading effect by other buildings. (They would generally be obtained from wind tunnel tests on a model of the building.) Wind pressure coefficients for each level and for sixteen directions must be specified along with the other data.

ASSUMPTIONS AND LIMITATIONS

- 1) Frictional resistance of vertical shafts is neglected.
- 2) Net air supplied by the air handling system is assumed to be constant and independent of building pressures.
- 3) The building has an open floor plan with no provision for separate rooms or vestibules.
- 4) Pressures, flows, and leakage openings are assumed to occur at mid-height of each level.
- 5) Temperature inside compartments and shafts is assumed to be 75°F.

DESCRIPTION OF PROGRAM

Flow balance equations for each compartment and for each shaft are:

for the i th compartment,

$$\sum_{k=1}^4 F_{o(i,k)} + F_{b(i)} - F_{a(i)} - \sum_{j=1}^{JJ} F_{s(i,j)} + F_{ac(i)} = 0 \quad (2)$$

and for the j th shaft,

$$\sum_{i=1}^{NN} F_{s(i,j)} + F_{bv(j)} + F_{tv(j)} + F_{sh(j)} = 0 \quad (3)$$

where $F_{o(i,k)}$ = flow from outside through side (k) to compartment (i)

$F_{b(i)}$ = flow from compartment below to compartment (i)

$F_{a(i)}$ = flow from compartment (i) to compartment above

$F_{s(i,j)}$ = flow from compartment (i) to shaft (j)

$F_{ac(i)}$ = net flow of air supplied to compartment (i) by air handling system

$F_{bv(j)}$ = flow into shaft (j) through bottom vent

$F_{tv(j)}$ = flow into shaft (j) through top vent

$F_{sh(j)}$ = net flow of outside air supplied into shaft (j) by air handling system

NN = number of compartments

JJ = number of shafts

The flows appearing in equations (2) and (3) are indicated in Figure 1. Combination of mass balance equations (2 and 3) with flow equation (1) results in a set of simultaneous non-linear equations. The outside pressures and the pressure differences due to column weight may be calculated from the input data.

These simultaneous non-linear equations are solved by a method of successive linear approximations. The non-linear function described by equation (1) is shown in Figure 2. In the region near point $(\Delta P_t, F_t)$ this function may be approximated by a straight line which is tangent to the curve at this point. The equation of this linear function is

$$F = K' [\Delta P - \Delta P_i] \quad (4a)$$

where
$$K' = K \times \Delta P_t^{x-1} \quad (4b)$$

and
$$\Delta P_i = \Delta P_t - \frac{F_t}{K'} \quad (4c)$$

Each leakage flow in equations (2 and 3) may be expressed by this type of linear approximation. The resulting set of NN + JJ linear equations for the pressures can then be solved by standard methods.

The iteration procedure is as follows: an initial linear approximation is made for each flow and the resulting equations are solved for space and shaft pressures. The flows corresponding to these pressures are then calculated, and the flow through each element is compared with the flow used for linearization of that element. If the difference is greater than the convergence criterion, * that element is re-linearized about the most recently determined flow and the linear simultaneous equations are solved again. This procedure is repeated until the flow through every element satisfies the convergence criterion. A block diagram of the program is given in Figure 3.

* The convergence criterion is specified by variable "error" in subroutine INFILT. The value used is 0.1 cfm.

In order to facilitate use in a load calculation package, this infiltration program has been divided into subroutines. Subroutine INPUT reads building leakage characteristics from fortran device number IIN into common block INPX. Before calling calculations subroutine INFILT the main program must specify outdoor temperature, wind pressures and, if desired, change air-conditioning pressurization flows. These values are in common block INARG. Subroutine INFILT will return with air flow arrays in common block BKARG.

This program was written for IBM 360 model 67. Execution time is approximately 0.9 sec for a building with 10 compartments and two shafts. The program is dimensioned for a maximum of 25 compartments and eight shafts.

INPUT/(See Figure 3)

Input is from punched cards as follows:

- CARD 1 NN - number of compartments (maximum 25)
 JJ - number of shafts (maximum eight, minimum one) (format 2I4)
- CARDS 2 one card per compartment beginning with com-
to NN+1 partment No. 1
 - height (thickness) of compartment, ft, [H(i)]
 - net quantity of air supplied to compartment, cfm,
 [ACPF(I)] (format 2F8.1)
- CARD NN+2 - values of flow exponent (sides 1, 2, 3, 4, between
 levels, and from compartments to shafts ONE to JJ)
 [X(k)] (format 13F6.5)
- CARDS NN+3 one card per level beginning with level No. 1
to 2NN+3 - values of leakage coefficient (sides 1, 2, 3, and 4,
 from compartment to compartment above, and from
 compartment to shafts ONE to JJ, [EA(i,j)]
 units: $\frac{\text{thousand of cfm}}{\text{in.}^x}$
 (format 13F6.2)
- CARDS 2NN+4 one card per shaft beginning with shaft No. 1
to 2NN+JJ+4 - net air supplied to shaft, cfm (FANSH(j))
 - leakage coefficient of bottom vent, $\frac{\text{thousands cfm}}{\text{in.}^x}$

[BV(j)]

- level at which bottom vent located [IBV(j)]
- side of building on which bottom vent located (1, 2, 3 or 4) [JBV(j)]
- leakage coefficient of top vent, $\frac{\text{thousands cfm}}{\text{in.}^x}$

[TV(j)]

- level at which top vent located [ITV(j)]
- side of building on which top vent located (1, 2, 3 or 4) [JTV(j)] (format F12.2, 2(F8.4, 214))

CARDS 2NN+ wind pressure coefficients for four sides of building
JJ+5 to - 16 sets of cards; one set for each wind direction
18NN+JJ+5 each set is NN cards with one card per compartment
beginning at compartment No. 1 (format 4F6.3)

CARDS 18NN+ - Outdoor temperature, °F, wind speed, mph,
JJ+6 to END wind direction (1 to 16) (format 2F8.1, I8)
OF DATA

EXAMPLE

Calculate infiltration and exfiltration rates for a 19-storey building, 120 by 120 by 250 ft high (schematically shown in Figure 4). This building has five elevators and two stairwells. The elevator machine room is in a penthouse and the mechanical equipment room is the top storey. The air supplied to the first storey exceeds the return air by 2000 cfm to produce some positive pressurization of the building. The air supplied to each remaining storey exceeds the return by 200 cfm. The four sides of the building face the cardinal directions.

It is assumed that representation of the building by nine compartments each representing two storeys is adequate for reasonably accurate results without excessive requirement of computer time. Level 10 is the mechanical floor; level 11 is the elevator room penthouse. The stairwells and service shafts are represented by one vertical shaft (shaft 1) and all elevators are represented by one other vertical shaft (shaft 2).

Building Leakage Input Data

The building leakage input data used in this example are based on the information of leakage characteristics of buildings given in References 1 and 2.

The following are the assumed leakage data:

- flow exponents for the outside walls are 0.66
- all other flow exponents are 0.5
- outside wall = $0.7 \text{ cfm/ft}^2 \text{ in.}^{0.66}$
= $2100 \text{ cfm/in.}^{0.66}$ /side of compartment
- mechanical room
(i. e., compartment No. 10) = $10,000 \text{ cfm/in.}^{0.66}$ /side
- elevator penthouse = $10,000 \text{ cfm/in.}^{0.66}$ /side
- stairwell door = $600 \text{ cfm/in.}^{0.66}$ /door
- service shafts at each level = $2400 \text{ cfm/in.}^{0.5}$
- stairwell and service shafts - total = $4800 \text{ cfm/in.}^{0.5}$ /compartment
- stairway to elevator penthouse = $600 \text{ cfm/in.}^{0.5}$
- one elevator door = $2400 \text{ cfm/in.}^{0.5}$
- total elevator door leakage per compartment for compartments 1 to 9 = $24,000 \text{ cfm/in.}^{0.5}$
- compartment No. 10, one elevator door = $2400 \text{ cfm/in.}^{0.5}$
- elevator shaft to elevator penthouse, per elevator = $7200 \text{ cfm/in.}^{0.5}$
- elevator shaft to elevator penthouse, total = 5×7200
= $36,000 \text{ cfm/in.}^{0.5}$
- net air supplied by air handling system to compartments 2 to 9 = $400 \text{ cfm/compartment}$
- net air supplied by air handling system to compartment 1 = 2200 cfm

Wind Pressure Coefficients

The wind pressure coefficients for the 10 levels, four outside building surface orientations, and 16 wind directions are listed on the sample input data sheets. The values of the coefficients are based on the information given in References 3 and 4.

REFERENCES

1. Tamura, G. T. Computer Analysis of Smoke Movement in Buildings. ASHRAE Transactions, Vol. 75, Part II, 1969 (NRCC 11542).
2. C. Y. Shaw, D. M. Sander and G. T. Tamura. Air Leakage Measurements of the Exterior Walls of Tall Buildings. ASHRAE, Paper No. 2280, Presented at Spring Conference in Minneapolis, U. S. A., May 1973.
3. M. Jensen and N. Frauck. Model-Scale Tests in Turbulent Wind. Part II. The Danish Technical Press, Copenhagen 1965.
4. Canadian Structural Design Manual 1970. Supplement No. 4 to the National Building Code of Canada. Associate Committee on the National Building Code, National Research Council of Canada, Ottawa.




FIGURE 1
 AIR FLOWS FOR A TYPICAL COMPARTMENT AND TYPICAL
 SHAFT

BR 5056-1




FIGURE 2

LINEAR APPROXIMATION OF FLOW EQUATION




FIG 3a BLOCK DIAGRAM OF MAIN PROGRAM




FIG 3b BLOCK DIAGRAM OF SUBROUTINE INFILT

FIRE, HEATING AND PLUMBING RESEARCH ASSOCIATION
 BRANCH NO. 1000
 LIBRARY




FIGURE 4

SCHEMATIC DIAGRAM OF THE BUILDING USED IN
 SAMPLE CALCULATIONS

BR 5224

APPENDIX A

EXAMPLE INPUT DATA

EXAMPLE INPUT DATA

11	2							
25.0	2200.							
25.0	400.							
25.0	400.							
25.0	400.							
25.0	400.							
25.0	400.							
25.0	400.							
25.0	400.							
25.0	0.							
10.0	0.							
.66	.66	.66	.66	.50	.50	.50		
7.1	2.1	7.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
2.1	2.1	2.1	2.1	3.0	4.8	24.0		
10.0	10.0	10.0	10.0	0.0	4.8	2.4		
10.0	10.0	10.0	10.0	0.0	0.6	36.0		
	0.0	0.0		1	1	0.0	11	1
	0.0	0.0		1	1	0.0	11	1
+ .39	- .39	- .13	- .39					
+ .39	- .39	- .13	- .39					
+ .39	- .39	- .13	- .39					
+ .45	- .52	- .13	- .52					
+ .52	- .52	- .13	- .52					
+ .58	- .52	- .26	- .52					
+ .65	- .65	- .26	- .65					
+ .71	- .65	- .26	- .65					
+ .78	- .65	- .26	- .65					
+ .58	- .65	- .26	- .65					
0.0	0.0	0.0	0.0					
+ .36	0.0	- .13	- .13					
+ .36	0.0	- .13	- .13					
+ .36	0.0	- .13	- .13					
+ .43	0.0	- .13	- .13					
+ .50	0.0	- .13	- .13					
+ .55	0.0	- .26	- .26					
+ .60	0.0	- .26	- .26					
+ .66	0.0	- .26	- .26					
+ .60	0.0	- .26	- .26					
+ .55	0.0	- .26	- .26					
0.0	0.0	0.0	0.0					

DIRECTION 1

DIRECTION 2

+ .13	+ .13	- .13	- .13
+ .13	+ .13	- .13	- .13
+ .26	+ .26	- .13	- .13
+ .26	+ .26	- .13	- .13
+ .26	+ .26	- .13	- .13
+ .26	+ .26	- .26	- .26
+ .39	+ .39	- .26	- .26
+ .39	+ .39	- .26	- .26
+ .39	+ .39	- .26	- .26
+ .26	+ .26	- .26	- .26
0.0	0.0	0.0	0.0
0.0	+ .36	- .13	- .13
0.0	+ .36	- .13	- .13
0.0	+ .36	- .13	- .13
0.0	+ .43	- .13	- .13
0.0	+ .50	- .13	- .13
0.0	+ .55	- .26	- .26
0.0	+ .60	- .26	- .26
0.0	+ .66	- .26	- .26
0.0	+ .60	- .26	- .26
0.0	+ .55	- .26	- .26
0.0	0.0	0.0	0.0
- .39	+ .39	- .39	- .13
- .39	+ .39	- .39	- .13
- .39	+ .39	- .39	- .13
- .52	+ .45	- .52	- .13
- .52	+ .52	- .52	- .13
- .52	+ .58	- .52	- .26
- .65	+ .65	- .65	- .26
- .65	+ .71	- .65	- .26
- .65	+ .78	- .65	- .26
- .65	+ .58	- .65	- .26
0.0	0.0	0.0	0.0
- .13	+ .36	0.0	- .13
- .13	+ .36	0.0	- .13
- .13	+ .43	0.0	- .13
- .13	+ .50	0.0	- .13
- .13	+ .50	0.0	- .13
- .26	+ .55	0.0	- .26
- .26	+ .60	0.0	- .26
- .26	+ .66	0.0	- .26
- .26	+ .60	0.0	- .26
- .26	+ .55	0.0	- .26
0.0	0.0	0.0	0.0
- .13	+ .13	+ .13	- .13
- .13	+ .13	+ .13	- .13
- .13	+ .26	+ .26	- .13
- .13	+ .26	+ .26	- .13
- .13	+ .26	+ .26	- .13
- .26	+ .26	+ .26	- .26
- .26	+ .39	+ .39	- .26
- .26	+ .39	+ .39	- .26

DIRECTION 3

DIRECTION 4

DIRECTION 5

DIRECTION 6

DIRECTION 7

THE HEATING AND POWERING RESEARCH ASSOCIATION

BRACKNELL, BERKSHIRE

LIBRARY

-0.26	+0.39	+0.39	-0.26
-0.26	+0.26	+0.26	-0.26
0.0	0.0	0.0	0.0
-0.13	0.0	+0.36	-0.13
-0.13	0.0	+0.36	-0.13
-0.13	0.0	+0.36	-0.13
-0.13	0.0	+0.43	-0.13
-0.13	0.0	+0.50	-0.13
-0.26	0.0	+0.55	-0.26
-0.26	0.0	+0.60	-0.26
-0.26	0.0	+0.66	-0.26
-0.26	0.0	+0.60	-0.26
-0.26	0.0	+0.55	-0.26
0.0	0.0	0.0	0.0
-0.13	-0.39	+0.39	-0.39
-0.13	-0.39	+0.39	-0.39
-0.13	-0.39	+0.39	-0.39
-0.13	-0.52	+0.45	-0.52
-0.13	-0.52	+0.52	-0.52
-0.26	-0.52	+0.58	-0.52
-0.26	-0.65	+0.65	-0.65
-0.26	-0.65	+0.71	-0.65
-0.26	-0.65	+0.78	-0.65
-0.26	-0.65	+0.58	-0.65
0.0	0.0	0.0	0.0
-0.13	-0.13	+0.36	0.0
-0.13	-0.13	+0.36	0.0
-0.13	-0.13	+0.36	0.0
-0.13	-0.13	+0.43	0.0
-0.13	-0.13	+0.50	0.0
-0.26	-0.26	+0.55	0.0
-0.26	-0.26	+0.60	0.0
-0.26	-0.26	+0.66	0.0
-0.26	-0.26	+0.60	0.0
-0.26	-0.26	+0.55	0.0
0.0	0.0	0.0	0.0
-0.13	-0.13	+0.13	+0.13
-0.13	-0.13	+0.13	+0.13
-0.13	-0.13	+0.26	+0.26
-0.13	-0.13	+0.26	+0.26
-0.13	-0.13	+0.26	+0.26
-0.26	-0.26	+0.26	+0.26
-0.26	-0.26	+0.39	+0.39
-0.26	-0.26	+0.39	+0.39
-0.26	-0.26	+0.39	+0.39
-0.26	-0.26	+0.26	+0.26
0.0	0.0	0.0	0.0
-0.13	-0.13	0.0	+0.36
-0.13	-0.13	0.0	+0.36
-0.13	-0.13	0.0	+0.36
-0.13	-0.13	0.0	+0.43
-0.13	-0.13	0.0	+0.50
-0.26	-0.26	0.0	+0.55

DIRECTION 8

DIRECTION 9

DIRECTION 10

DIRECTION 11

DIRECTION 12

-.26	-.26	0.0	+.60
-.26	-.26	0.0	+.66
-.26	-.26	0.0	+.60
-.26	-.26	0.0	+.55
0.0	0.0	0.0	0.0
-.39	-.13	-.39	+.39
-.39	-.13	-.39	+.39
-.39	-.13	-.39	+.39
-.52	-.13	-.52	+.45
-.52	-.13	-.52	+.52
-.52	-.26	-.52	+.58
-.65	-.26	-.65	+.65
-.65	-.26	-.65	+.71
-.65	-.26	-.65	+.78
-.65	-.26	-.65	+.58
0.0	0.0	0.0	0.0
0.0	-.13	-.13	+.36
0.0	-.13	-.13	+.36
0.0	-.13	-.13	+.36
0.0	-.13	-.13	+.43
0.0	-.13	-.13	+.50
0.0	-.26	-.26	+.55
0.0	-.26	-.26	+.60
0.0	-.26	-.26	+.66
0.0	-.26	-.26	+.60
0.0	-.26	-.26	+.55
0.0	0.0	0.0	0.0
+.13	-.13	-.13	+.13
+.13	-.13	-.13	+.13
+.26	-.13	-.13	+.26
+.26	-.13	-.13	+.26
+.26	-.13	-.13	+.26
+.26	-.26	-.26	+.26
+.39	-.26	-.26	+.39
+.39	-.26	-.26	+.39
+.39	-.26	-.26	+.39
+.26	-.26	-.26	+.26
0.0	0.0	0.0	0.0
+.36	-.13	-.13	0.0
+.36	-.13	-.13	0.0
+.36	-.13	-.13	0.0
+.43	-.13	-.13	0.0
+.50	-.13	-.13	0.0
+.55	-.26	-.26	0.0
+.60	-.26	-.26	0.0
+.66	-.26	-.26	0.0
+.60	-.26	-.26	0.0
+.55	-.26	-.26	0.0
0.0	0.0	0.0	0.0

DIRECTION 13

DIRECTION 14

DIRECTION 15

DIRECTION 16

APPENDIX B

EXAMPLE PROGRAM OUTPUT

EXAMPLE OUTPUT

SOLUTION FOR 11 LEVELS, 2 SHAFTS

*****INPUT PARAMETERS*****

FLOW EQUATION IS... $F=C\text{OEF}*(\text{DELTA } P)**X$

WHERE:

F =FLOW RATE (CFM)

CDEF =LEAKAGE COEFFICIENT (1000 CFM/INCH

DELTA P =PRESSURE DIFFERENTIAL (INCHES OF WATER)

X =FLOW EXPONENT

***** VALUES OF X *****

OUTSIDE	OUTSIDE	OUTSIDE	OUTSIDE	LEVEL	SHAFT	SHAFT	SHAFT	SHAFT	SHAFT
SIDE 1	SIDE 2	SIDE 3	SIDE 4	ABOVE	1	2	3	4	5
0.660	0.660	0.660	0.660	0.500	0.500	0.500			

VALUE OF X FOR SHAFT VENTS IS 0.5

****LEAKAGE COEFFICIENTS=(1000 SCFM/INCH)****

LEVEL	OUTSIDE SIDE 1	OUTSIDE SIDE 2	OUTSIDE SIDE 3	OUTSIDE SIDE 4	LEVEL ABOVE	SHAFT 1	SHAFT 2	SHAFT 3	SHAFT 4	SHAFT 5
1	7.100	2.100	7.100	2.100	3.000	4.800	24.000			
2	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
3	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
4	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
5	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
6	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
7	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
8	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
9	2.100	2.100	2.100	2.100	3.000	4.800	24.000			
10	10.000	10.000	10.000	10.000	0.000	4.800	2.400			
11	10.000	10.000	10.000	10.000	0.000	0.600	36.000			

*****SHAFT VENTS AND PRESSURIZATION*****

SHAFT	PRESS FLOW (CFM)	****BOTTOM VENT****			****TOP VENT****		
		COEF	LEVEL	SIDE	COEF	LEVEL	SIDE
1	0.00	0.00	1	1	0.00	11	1
2	0.00	0.00	1	1	0.00	11	1

WIND PRESSURE COEFFICIENTS

SIDE 1 SIDE 2 SIDE 3 SIDE 4

LEVEL	WIND DIRECTION= 1			
1	0.3900	-0.3900	-0.1300	-0.3900
2	0.3900	-0.3900	-0.1300	-0.3900
3	0.3900	-0.3900	-0.1300	-0.3900
4	0.4500	-0.5200	-0.1300	-0.5200
5	0.5200	-0.5200	-0.1300	-0.5200
6	0.5800	-0.5200	-0.2600	-0.5200
7	0.6500	-0.6500	-0.2600	-0.6500
8	0.7100	-0.6500	-0.2600	-0.6500
9	0.7800	-0.6500	-0.2600	-0.6500
10	0.5800	-0.6500	-0.2600	-0.6500
11	0.0000	0.0000	0.0000	0.0000
LEVEL	WIND DIRECTION= 2			
1	0.3600	0.0000	-0.1300	-0.1300
2	0.3600	0.0000	-0.1300	-0.1300
3	0.3600	0.0000	-0.1300	-0.1300
4	0.4300	0.0000	-0.1300	-0.1300
5	0.5000	0.0000	-0.1300	-0.1300
6	0.5500	0.0000	-0.2600	-0.2600
7	0.6000	0.0000	-0.2600	-0.2600
8	0.6600	0.0000	-0.2600	-0.2600
9	0.6000	0.0000	-0.2600	-0.2600
10	0.5500	0.0000	-0.2600	-0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL	WIND DIRECTION= 3			
1	0.1300	0.1300	-0.1300	-0.1300
2	0.1300	0.1300	-0.1300	-0.1300
3	0.2600	0.2600	-0.1300	-0.1300
4	0.2600	0.2600	-0.1300	-0.1300
5	0.2600	0.2600	-0.1300	-0.1300
6	0.2600	0.2600	-0.2600	-0.2600
7	0.3900	0.3900	-0.2600	-0.2600
8	0.3900	0.3900	-0.2600	-0.2600
9	0.3900	0.3900	-0.2600	-0.2600

10	0.2600	0.2600	-0.2600	=0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 4		
1	0.0000	0.3600	-0.1300	=0.1300
2	0.0000	0.3600	-0.1300	=0.1300
3	0.0000	0.3600	-0.1300	=0.1300
4	0.0000	0.4300	-0.1300	=0.1300
5	0.0000	0.5000	-0.1300	=0.1300
6	0.0000	0.5500	-0.2600	=0.2600
7	0.0000	0.6000	-0.2600	=0.2600
8	0.0000	0.6600	-0.2600	=0.2600
9	0.0000	0.6000	-0.2600	=0.2600
10	0.0000	0.5500	-0.2600	=0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 5		
1	-0.3900	0.3900	-0.3900	=0.1300
2	-0.3900	0.3900	-0.3900	=0.1300
3	-0.3900	0.3900	-0.3900	=0.1300
4	-0.5200	0.4500	-0.5200	=0.1300
5	-0.5200	0.5200	-0.5200	=0.1300
6	-0.5200	0.5800	-0.5200	=0.2600
7	-0.6500	0.6500	-0.6500	=0.2600
8	-0.6500	0.7100	-0.6500	=0.2600
9	-0.6500	0.7800	-0.6500	=0.2600
10	-0.6500	0.5800	-0.6500	=0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 6		
1	-0.1300	0.3600	0.0000	=0.1300
2	-0.1300	0.3600	0.0000	=0.1300
3	-0.1300	0.4300	0.0000	=0.1300
4	-0.1300	0.5000	0.0000	=0.1300
5	-0.1300	0.5000	0.0000	=0.1300
6	-0.2600	0.5500	0.0000	=0.2600
7	-0.2600	0.6000	0.0000	=0.2600
8	-0.2600	0.6600	0.0000	=0.2600
9	-0.2600	0.6000	0.0000	=0.2600
10	-0.2600	0.5500	0.0000	=0.2600
11	0.0000	0.0000	0.0000	0.0000

LEVEL	WIND DIRECTION= 7			
1	-0.1300	0.1300	0.1300	=0.1300
2	-0.1300	0.1300	0.1300	=0.1300
3	-0.1300	0.2600	0.2600	=0.1300
4	-0.1300	0.2600	0.2600	=0.1300
5	-0.1300	0.2600	0.2600	=0.1300
6	-0.2600	0.2600	0.2600	=0.2600
7	-0.2600	0.3900	0.3900	=0.2600
8	-0.2600	0.3900	0.3900	=0.2600
9	-0.2600	0.3900	0.3900	=0.2600
10	-0.2600	0.2600	0.2600	=0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL	WIND DIRECTION= 8			
1	-0.1300	0.0000	0.3600	=0.1300
2	-0.1300	0.0000	0.3600	=0.1300
3	-0.1300	0.0000	0.3600	=0.1300
4	-0.1300	0.0000	0.4300	=0.1300
5	-0.1300	0.0000	0.5000	=0.1300
6	-0.2600	0.0000	0.5500	=0.2600
7	-0.2600	0.0000	0.6000	=0.2600
8	-0.2600	0.0000	0.6600	=0.2600
9	-0.2600	0.0000	0.6000	=0.2600
10	-0.2600	0.0000	0.5500	=0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL	WIND DIRECTION= 9			
1	-0.1300	-0.3900	0.3900	=0.3900
2	-0.1300	-0.3900	0.3900	=0.3900
3	-0.1300	-0.3900	0.3900	=0.3900
4	-0.1300	-0.5200	0.4500	=0.5200
5	-0.1300	-0.5200	0.5200	=0.5200
6	-0.2600	-0.5200	0.5800	=0.5200
7	-0.2600	-0.6500	0.6500	=0.6500
8	-0.2600	-0.6500	0.7100	=0.6500
9	-0.2600	-0.6500	0.7800	=0.6500
10	-0.2600	-0.6500	0.5800	=0.6500
11	0.0000	0.0000	0.0000	0.0000
LEVFL	WIND DIRECTION= 10			
1	-0.1300	-0.1300	0.3600	0.0000

THE HEATING AND COOLING RESEARCH ASSOCIATION
 BRACKNELL, BERKSHIRE
 LIBRARY

2	-0.1300	-0.1300	0.3600	0.0000
3	-0.1300	-0.1300	0.3600	0.0000
4	-0.1300	-0.1300	0.4300	0.0000
5	-0.1300	-0.1300	0.5000	0.0000
6	-0.2600	-0.2600	0.5500	0.0000
7	-0.2600	-0.2600	0.6000	0.0000
8	-0.2600	-0.2600	0.6600	0.0000
9	-0.2600	-0.2600	0.6000	0.0000
10	-0.2600	-0.2600	0.5500	0.0000
11	0.0000	0.0000	0.0000	0.0000

LEVEL WIND DIRECTION= 11

1	-0.1300	-0.1300	0.1300	0.1300
2	-0.1300	-0.1300	0.1300	0.1300
3	-0.1300	-0.1300	0.2600	0.2600
4	-0.1300	-0.1300	0.2600	0.2600
5	-0.1300	-0.1300	0.2600	0.2600
6	-0.2600	-0.2600	0.2600	0.2600
7	-0.2600	-0.2600	0.3900	0.3900
8	-0.2600	-0.2600	0.3900	0.3900
9	-0.2600	-0.2600	0.3900	0.3900
10	-0.2600	-0.2600	0.2600	0.2600
11	0.0000	0.0000	0.0000	0.0000

LEVEL WIND DIRECTION= 12

1	-0.1300	-0.1300	0.0000	0.3600
2	-0.1300	-0.1300	0.0000	0.3600
3	-0.1300	-0.1300	0.0000	0.3600
4	-0.1300	-0.1300	0.0000	0.4300
5	-0.1300	-0.1300	0.0000	0.5000
6	-0.2600	-0.2600	0.0000	0.5500
7	-0.2600	-0.2600	0.0000	0.6000
8	-0.2600	-0.2600	0.0000	0.6600
9	-0.2600	-0.2600	0.0000	0.6000
10	-0.2600	-0.2600	0.0000	0.5500
11	0.0000	0.0000	0.0000	0.0000

LEVEL WIND DIRECTION= 13

1	-0.3900	-0.1300	-0.3900	0.3900
2	-0.3900	-0.1300	-0.3900	0.3900
3	-0.3900	-0.1300	-0.3900	0.3900

4	-0.5200	-0.1300	-0.5200	0.4500
5	-0.5200	-0.1300	-0.5200	0.5200
6	-0.5200	-0.2600	-0.5200	0.5800
7	-0.6500	-0.2600	-0.6500	0.6500
8	-0.6500	-0.2600	-0.6500	0.7100
9	-0.6500	-0.2600	-0.6500	0.7800
10	-0.6500	-0.2600	-0.6500	0.5800
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 14		
1	0.0000	-0.1300	-0.1300	0.3600
2	0.0000	-0.1300	-0.1300	0.3600
3	0.0000	-0.1300	-0.1300	0.3600
4	0.0000	-0.1300	-0.1300	0.4300
5	0.0000	-0.1300	-0.1300	0.5000
6	0.0000	-0.2600	-0.2600	0.5500
7	0.0000	-0.2600	-0.2600	0.6000
8	0.0000	-0.2600	-0.2600	0.6600
9	0.0000	-0.2600	-0.2600	0.6000
10	0.0000	-0.2600	-0.2600	0.5500
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 15		
1	0.1300	-0.1300	-0.1300	0.1300
2	0.1300	-0.1300	-0.1300	0.1300
3	0.2600	-0.1300	-0.1300	0.2600
4	0.2600	-0.1300	-0.1300	0.2600
5	0.2600	-0.1300	-0.1300	0.2600
6	0.2600	-0.2600	-0.2600	0.2600
7	0.3900	-0.2600	-0.2600	0.3900
8	0.3900	-0.2600	-0.2600	0.3900
9	0.3900	-0.2600	-0.2600	0.3900
10	0.2600	-0.2600	-0.2600	0.2600
11	0.0000	0.0000	0.0000	0.0000
LEVEL		WIND DIRECTION= 16		
1	0.3600	-0.1300	-0.1300	0.0000
2	0.3600	-0.1300	-0.1300	0.0000
3	0.3600	-0.1300	-0.1300	0.0000
4	0.4300	-0.1300	-0.1300	0.0000
5	0.5000	-0.1300	-0.1300	0.0000

*****PRESSURE DIFFERENCES (INCHES OF WATER, REFERENCED TO FLOOR PRESSURE)*****

LEVEL	OUTSIDE SIDE 1	OUTSIDE SIDE 2	OUTSIDE SIDE 3	OUTSIDE SIDE 4	LEVEL ABOVE	SHAFT 1	SHAFT 2	SHAFT 3	SHAFT 4	SHAFT 5
1	0.1127	0.2631	0.1127	0.1628	-0.0380	-0.0506	-0.0506			
2	0.1097	0.2601	0.1097	0.1599	-0.0051	-0.0126	-0.0126			
3	0.0739	0.2243	0.0739	0.1241	-0.0037	-0.0075	-0.0075			
4	0.0116	0.1986	0.0116	0.0868	-0.0026	-0.0039	-0.0039			
5	-0.0267	0.1738	-0.0267	0.0485	-0.0012	-0.0012	-0.0012			
6	-0.0664	0.1456	-0.0664	-0.0163	-0.0004	-0.0001	-0.0000			
7	-0.1320	0.1186	-0.1320	-0.0568	-0.0010	0.0003	0.0004			
8	-0.1720	0.0902	-0.1720	-0.0968	-0.0044	0.0013	0.0013			
9	-0.2085	0.0672	-0.2085	-0.1333	-0.1304	0.0057	0.0057			
10	-0.1191	0.1181	-0.1191	-0.0439	0.0784	0.1361	0.1361			
11	-0.1008	-0.1008	-0.1008	-0.1008	0.0000	0.0577	0.0577			
TOP VENT.....			0.16	0.16					
BOTTOM VENT.....			-0.16	-0.16					

.....VENT PRESSURE DIFFERENCES ARE RELATIVE TO OUTSIDE AT THAT LEVEL.....

****VOLUME FLOW RATE (SCFM)****

LEVEL	OUTSIDE SIDE 1 (1)	OUTSIDE SIDE 2 (1)	OUTSIDE SIDE 3 (1)	OUTSIDE SIDE 4 (1)	LEVEL ABOVE (2)	SHAFT 1 (3)	SHAFT 2 (3)	SHAFT 3 (3)	SHAFT 4 (3)	SHAFT 5 (3)
1	1681.0	870.5	1681.0	633.8	584.8	1079.8	5400.0			
2	488.6	263.1	488.6	626.9	214.5	539.2	2697.3			
3	376.5	782.5	376.5	529.7	181.6	416.5	2080.9			
4	110.8	722.5	110.8	418.3	153.8	299.5	1491.7			
5	-192.3	661.0	-192.3	285.0	103.9	169.6	843.1			
6	-350.8	588.1	-350.8	-138.9	60.3	35.1	157.4			
7	-552.0	513.4	-552.0	-316.5	93.1	-88.8	-450.8			
8	-658.1	428.4	-658.1	-449.8	200.2	-173.1	-868.9			
9	-747.1	353.3	-747.1	-555.5	1083.6	-362.8	-1815.4			
10	-2455.1	2441.1	-2455.1	-1270.7	0.0	-1770.8	-885.4			
11	-2198.9	-2198.9	-2198.9	-2198.9	0.0	-144.2	-8651.3			

.....TOP VENT..(4).
.....BOTTOM VENT..(4).

0.0 0.0
0.0 0.0

.....SUM OF FLOWS.....

+VE	2657.	2224.	2657.	2494.		2540.	12670.			
-VE	-7154.	-2199.	-7154.	-4930.		-2540.	-12672.			

*****SIGN CONVENTIONS*****

- (1) + INDICATES FLOW FROM OUTSIDE TO FLOOR AREA
- (2) + INDICATES FLOW FROM FLOOR SPACE TO FLOOR ABOVE
- (3) + INDICATES FLOW FROM FLOOR SPACE TO SHAFT
- (4) + INDICATES FLOW FROM OUTSIDE TO SHAFT (THROUGH VENT OPENING)

LEVEL

INFILTRATION
THROUGH
WALLS

1	4866.
2	2467.
3	2065.
4	1362.
5	946.
6	588.
7	513.
8	428.
9	353.
10	2441.
11	0.

TOTAL= 16031.

....NUMBER OF ITERATIONS = 6.....

....NUMBER OF UNCONVERGED TERMS= 0

APPENDIX C

PROGRAM LISTING

```

C          MAIN PROGRAM (INFILTRATION)
C
C          TO CALCULATE INFILTRATION FLOW RATES FOR
C          GIVEN OUTDOOR TEMPERATURES AND WIND SPEEDS AND
C          DIRECTIONS
C
C          IMPLICIT REAL*8(A-H,O-Z),INTEGER*4(I-N)
C          COMMON/INARG/TEMP,WP(25,4),ACPF(25),FANSH(8)
C          COMMON/BKARG/NN,JJ,ITERM,KOUNT,F(25,13),FTV(8),FBV(8),C(33)
C          COMMON/INPX/H(25),EA(25,13),X(13),TV(8),BV(8),PRESX(25,13),ITV(8)
1          ,JTV(8),IBV(8),JBV(8)
C          DIMENSION WPCOEF(16,25,4)
C          .....ASSIGN INPUT/OUTPUT DEVICE NUMBERS.....
C          IIN=1
C          IOUT=3
C          CALL INPUT(IIN,IOUT)
C          READ WIND PRESSURE COEFFICIENTS
C          DO 5 K=1,16
C          DO 4 I=1,NN
C          READ (IIN,100)(WPCOEF(K,I,J),J=1,4)
4          CONTINUE
5          CONTINUE
C          WRITE WIND PRESSURE COEFFICIENTS
C          WRITE (IOUT,199)
C          WRITE (IOUT,200)
C          DO 7 K=1,16
C          WRITE (IOUT,201) K
C          DO 6 I=1,NN
C          WRITE (IOUT,202) I,(WPCOEF(K,I,J),J=1,4)
6          CONTINUE
7          CONTINUE
C          READ TEMPERATURE AND WIND
C          READ (IIN,101,FND=99) TEMP,WV,DIR
C          CALCULATE WIND VELOCITY PRESSURE
C          VP=.000482*WV*WV
C          CALCULATE WIND PRESSURES ON BUILDING
C          DO 12 J=1,4

```

```

      DO 11 I=1,NN
      WP(I,J)=VP*WPCOEFF(IDIR,I,J)
11      CONTINUE
12      CONTINUE
C        WRITE TEMPERATURE, WIND, AND PRESSURES
      WRITE (IOUT,207) TEMP
      WRITE (IOUT,208) WV,DIR
      WRITE (IOUT,204)
      WRITE(IOUT,205)
      DO 20 I=1,NN
      WRITE (IOUT,206) I,H(I),WP(I,1),WP(I,2),WP(I,3),WP(I,4),ACPF(I)
20      CONTINUE
C        CALCULATE INFILTRATION
      CALL INFILT (IOUT)
C        OUTPUT INFILTRATION
      CALL OUT1 (IOUT)
      CALL OUT2 (IOUT)
C        TOTAL INFILTRATION THROUGH WALLS
      TFLT=0.
      WRITE (IOUT,209)
      DO 50 I=1,NN
      FLT=0.
      DO 40 J=1,4
      IF (F(I,J)) 40,40,30
30      FLT=FLT+F(I,J)
40      CONTINUE
      WRITE (IOUT,210) I,FLT
      TFLT=TFLT+FLT
50      CONTINUE
      WRITE (IOUT,211) TFLT
      WRITE (IOUT,3001) KOUNT
      WRITE(IOUT,3002) ITERM
      GO TO 9
99      STOP
100     FORMAT (4F6.3)
101     FORMAT (2F8.1,I8)
199     FORMAT ('1',20X,'WIND PRESSURE COEFFICIENTS')
200     FORMAT ('0',15X,'SIDE 1',6X,'SIDE 2',6X,'SIDE 3',6X,'SIDE 4'/)

```



```

201  FORMAT (1X,'LEVEL',22X,'WIND DIRECTION=',I3)
202  FORMAT (1X,I3,6X,4F12.4)
204  FORMAT (///,1X,'FLOOR',8X,'FLOOR HEIGHT',8X,'WIND SIDE 1',
1      5X,'WIND SIDE 2',7X,'WIND SIDE 3',7X,'WIND SIDE 4'
2      ,7X,'A/C/PRESS. FLOW')
205  FORMAT (17X,'(FT)',1X,4(10X,'(INCHES)'),15X,'(SCFM)')
206  FORMAT (3X,I2,11X,F6.1,4(11X,F8.5),11X,F8.0)
207  FORMAT ('1',40X,'0.A. TEMPERATURE=',F5.0,' (DEGREES F.)')
208  FORMAT (////,25X,'WIND SPEED=',F4.0,5X,'DIRECTION=',I3)
209  FORMAT('1','LEVEL',15X,'INFILTRATION'/24X,'THROUGH'/25X,' WALLS'/)
210  FORMAT (2X,I2,14X,F12.0)
211  FORMAT ('0','TOTAL=',F12.0)
3001  FORMAT ('0',20X,'.....NUMBER OF ITERATIONS =',I4,'.....')
3002  FORMAT (///20X,'.....NUMBER OF UNCONVERGED TERMS=',I4)
      END

```

SUBROUTINE INPUT(IIN,IOUT)

INPUT ROUTINE FOR AIR INFILTRATION PROGRAM

INPUTS FROM FORTRAN DEVICE NUMBER IIN INTO COMMON
LISTS INPUT INFORMATION ON FORTRAN DEVICE NUMBER IOUT

INPUTS ARE AS FOLLOWS...

NN -NUMBER OF LEVELS

JJ -NUMBER OF VERTICAL SHAFTS

H -LEVEL HEIGHTS (FT)

ACPF -NET AIR SUPPLIED BY A/C SYSTEM (SUPPLY-RETURN)
FOR PRESSURIZATION (SCFM)

EA -LEAKAGE COEFFICIENTS (1000 SCFM/INCH)

X -FLOW EXPONENT

BV -LEAKAGE COEFFICIENT OF BOTTOM VENT OPENING

TV -LEAKAGE COEFFICIENT OF TOP VENT OPENING

ITV -LEVEL AT WHICH TOP VENT OPENING OCCURS

IBV -LEVEL AT WHICH BOTTOM VENT OPENING OCCURS

JBV -SIDE OF BUILDING AT WHICH BOTTOM VENT OCCURS

JTV -SIDE OF BUILDING AT WHICH TOP VENT OCCURS

FANSH -NET AIR SUPPLIED TO SHAFT FOR PRESSURIZATION

DIMENSIONS ARE FOR MAXIMUM OF 25 LEVELS AND 8 SHAFTS

IMPLICIT REAL*8(A-H,O-Z), INTEGER*4(I-N)

COMMON/INARG/TEMP,WP(25,4),ACPF(25),FANSH(8)

COMMON/BKARG/NN,JJ,ITERM,KOUNT,F(25,13),FTV(8),FBV(8),C(33)

COMMON/INPX/H(25),EA(25,13),X(13),TV(8),BV(8),PRESX(25,13),ITV(8)

1 ,JTV(8),IBV(8),JBV(8)

READ (IIN,100) NN,JJ

```

C
  NNJ=NN+J
  JJ5=JJ+5
C
  READ(IIN,101) (H(I),ACPF(I),I=1,NN)
C
  READ(IIN,105) (X(J),J=1,JJ5)
C
  DO 12 I=1,NN
  READ(IIN,103) (EA(I,J),J=1,JJ5)
12  CONTINUE
C
  READ (IIN,104) (FANSH(J),BV(J),IBV(J),JBV(J),TV(J),ITV(J),
1      JTV(J),J=1,JJ)
C
C
C
C
C
  WRITE INPUT INFORMATION
C
  WRITE (IOUT,200) NN,JJ
C
C
  WRITE (IOUT,201)
  WRITE (IOUT,190)
  WRITE (IOUT,191)
  WRITE (IOUT,192)
  WRITE (IOUT,193)
  WRITE (IOUT,195)
  WRITE (IOUT,196)
  WRITE (IOUT,230)
  WRITE (IOUT,222)
  WRITE (IOUT,213)
  WRITE (IOUT,223) (X(J) ,J=1,JJ5)
  WRITE (IOUT,224)
C
  WRITE (IOUT,211)
  WRITE (IOUT,212)
  WRITE (IOUT,213)

```

```

18  DO 18 I=1,NN
    WRITE (IOUT,214) I,(EA(I,J),J=1,JJ5)
    CONTINUE
C
    WRITE (IOUT,215)
    WRITE (IOUT,216)
    WRITE (IOUT,217)
    DO 20 J=1,JJ
    WRITE(IOUT,219) J,FANSH(J),BV(J),IBV(J),JBV(J),TV(J),ITV(J)
1   ,JTV(J)
20  CONTINUE
C
    AVKS= .1920*.074367/2.
    AVKJ=-.1920*.074367
    NN1=NN-1
C      CALCULATE RH0*H BETWEEN LEVELS
    DO 31 I=1,NN1
    PRESX(I,5)=(H(I)+H(I+1))*AVKS
31  CONTINUE
C      CALCULATE MID-LEVEL HEIGHT ABOVE GROUND
    HX=H(1)/2.
    H(1)=HX
    DO 32 I=2,NN
    HT=H(I-1)+HX
    HX=H(I)/2.
    H(I)=HT+HX
32  CONTINUE
C      CALCULATE RH0*H IN SHAFTS
    DO 34 J=1,JJ
    J5=J+5
    DO 33 I=1,NN
    PRESX(I,J5)=H(I)*AVKJ
33  CONTINUE
34  CONTINUE
C
    RETURN
C
100  FORMAT (2I4)

```

THE HEATING AND COOLING RESEARCH ASSOCIATION
 BRACKNELL, BERKSHIRE
 LIBRARY

```

101  FORMAT (F8.4,F40.1)
103  FORMAT (13F6.2)
104  FORMAT (F12.2,F8.4,2I4,F8.4,2I4)
105  FORMAT (13F6.5)
C
190  FORMAT ('0',35X,'FLOW EQUATION IS...F=CØEF*(DELTA P)**X')
191  FORMAT ('0',30X,'WHERE:')
192  FORMAT (35X,'F =FLOW RATE (CFM)')
193  FORMAT (35X,'CØEF =LEAKAGE CØEFICIENT (1000 CFM/INCH)')
195  FORMAT (35X,'DELTA P =PRESSURE DIFFERENTIAL (INCHES ØF WATER)')
196  FORMAT (35X,'X =FLOW EXPØNENT')
200  FORMAT('1',40X,'SØLUTION FOR ',I4,' LEVELS, ',I4,' SHAFTS')
201  FORMAT ('1',40X,'*****INPUT PARAMETERS*****')
211  FORMAT ('1',40X,'****LEAKAGE CØEFICIENTS=(1000 SCFM/INCH)****')
212  FORMAT ('0','LEVEL',2X,4('ØUTSIDE',3X),
1      'LEVEL',8(5X,'SHAFT'))
213  FORMAT (8X,'SIDE 1',4X,'SIDE 2',4X,'SIDE 3',4X,'SIDE 4',4X,
1      'ABØVE',7X,11,9X,12,9X,13,9X,14,9X,15,9X,16,9X,17,
1      9X,18')
214  FORMAT (1X,I2,13(2X,F8.3))
215  FORMAT ('1',40X,'*****SHAFT VENTS AND PRESSURIZATION*****')
216  FORMAT (1HØ,1X,'SHAFT',10X,'PRESS FLØW',16X,'****BØTTØM VENT****'
1      22X,'****TØP VENT*****')
217  FORMAT (19X,'(SCFM)',11X,2(6X,'CØEF',9X,'LEVEL',8X,'SIDE'))
219  FORMAT (1X,I4,7X,F12.2,10X,F12.2,2(8X,I4),F12.2,2(8X,I4))
222  FORMAT ('0',7X,4('ØUTSIDE',3X),
1      'LEVEL',8(5X,'SHAFT'))
223  FORMAT (3X,13(2X,F8.3))
224  FORMAT (/////40X,'VALUE ØF X FOR SHAFT VENTS IS 0.5 ')
230  FORMAT (/////50X,'***** VALUES ØF X *****')
      END

```

```

SUBROUTINE INFILT (IDIAG)
C
C*****PURPOSE*****
C
C   PROGRAM TO COMPUTE AIR FLOWS AND PRESSURES FOR A BUILDING
C
C   FLOWS AND PRESSURES MAY BE DUE TO ANY COMBINATION OF
C       STACK EFFECT
C       WIND EFFECT
C       NET AIR SUPPLIED BY A/C SYSTEM FOR PRESSURIZATION
C
C*****
C
C       CALLING SEQUENCE:
C           ENTER WITH INPUT VALUES IN COMMON BLOCKS /INPX/ AND
C           IDIAG = FORTRAN DEVICE NUMBER FOR ERROR MESSAGE OUT
C
C*****ASSUMPTIONS AND LIMITATIONS*****
C
C   AIR FLOW EQUATION USED IS       $F=K*(DELTA P)^X$ 
C       WHERE  F= VOLUME FLOW RATE
C              K= LEAKAGE COEFFICIENT
C              X= LEAKAGE EXPONENT
C              DELTA P= PRESSURE DIFFERENTIAL
C
C   FRICTIONAL RESISTANCE OF VERTICAL SHAFTS IS NEGLECTED
C
C   NET AIR FLOW SUPPLIED BY A/C SYSTEM FOR PRESSURIZATION IS ASSUMED
C   CONSTANT (INDEPENDANT OF THE LEVEL PRESSURES)
C
C   PRESSURES ARE ASSUMED UNIFORM THROUGHOUT THE LEVEL AREA (NO
C   PROVISION IS MADE FOR VESTIBULES OR COMPARTMENTIZATION OF LEVELS)
C
C   PROGRAM IS DIMENSIONED FOR A MAXIMUM OF 25 LEVELS AND 8 SHAFTS
C

```


C ACPF(I) -FLOW SUPPLIED BY A/C SYSTEM TO LEVEL I
 C FANSH -FLOW SUPPLIED TO SHAFT J BY A/C SYSTEM
 C

C LEAKAGE CONSTANTS:

C EA(I,1) -COEFFICIENT WALL #1 AT ITH LEVEL
 C EA(I,2) -COEFFICIENT WALL #2 AT ITH LEVEL
 C EA(I,3) -COEFFICIENT WALL 3 AT ITH LEVEL
 C EA(I,4) -COEFFICIENT WALL 4 AT ITH LEVEL
 C EA(I,5) -COEFFICIENT FROM LEVEL I TO LEVEL I+1
 C EA(I,J+5) -COEFFICIENT FROM LEVEL I TO SHAFT J
 C TV(J) -COEFFICIENT TOP VENT SHAFT J
 C BV(J) -COEFFICIENT BOTTOM VENT SHAFT J
 C X(J) -EXPONENT
 C

C INTEGERS:

C NN -NUMBER OF LEVELS
 C JJ -NUMBER OF SHAFTS
 C IBV -LOCATION OF BOTTOM VENT (LEVEL)
 C ITV -LOCATION OF TOP VENT (LEVEL)
 C JBV -SIDE AT WHICH BOTTOM VENT OCCURS (1,2,3 OR 4)
 C JTV -SIDE AT WHICH TOP VENT OCCURS (1,2,3 OR 4)
 C

C *****

C IMPLICIT REAL*8(A-H,O-Z), INTEGER*4(I-N)
 COMMON/INARG/TEMP,WP(25,4),ACPF(25),FANSH(8)
 COMMON/OKARG/NN,JJ,ITERM,KOUNT,F(25,13),FTV(8),FBV(8),C(33)
 COMMON/INPX/H(25),EA(25,13),X(13),TV(8),BV(8),PRESX(25,13),ITV(8)
 1 ,JTV(8),IBV(8),JBV(8)
 DIMENSION G(25,13),PL(25,13),GTV(8),PTVL(8),GBV(8),PBVL(8)
 DIMENSION A(33,33),AA(1089),PLL(325),P(33)
 EQUIVALENCE (PL(1,1), PLL(1))
 EQUIVALENCE (A(1,1),AA(1))
 EQUIVALENCE (P(1),C(1))
 C


```

DATA P0, IEND/.500,0/
C
ERROR=.0001
C
....ZERO MATRIX A
DO 1 K=1,1089
AA(K)=0.00
1
CONTINUE
C
3
CONTINUE
C
CALCULATE OUTSIDE PRESSURES
RH0=39.76578000/(TEMP+459.7200)
AVKR=-.1920*RH0
DO 5 J=1,4
DO 4 I=1,NN
PRESX(I,J)=AVKR*H(I)+WP(I,J)
4
CONTINUE
5
CONTINUE
C
....INITIAL LINEAR APPROXIMATION....
C
....STRAIGHT LINE THRU ZERO AND POINT CORRESPONDING TO PINIT....
NNJJ=NN+JJ
NNJJ2=NNJJ*NNJJ
JJ5=JJ+5
PPI=P0**(-0.500)
DO 20 J=1, JJ5
DO 10 I=1, NN
G(I,J)= (EA(I,J))*PPI
10
CONTINUE
20
CONTINUE
DO 30 J=1, JJ
GTV(J)=(TV(J))*PPI
GBV(J)=(BV(J))*PPI
30
CONTINUE
C
.....SET PL EQUAL TO ZERO.....
DO 40 K=1,325
PLL(K)=0.00
40
CONTINUE
DO 50 K=1,8

```

```

      PTVL(K)=0.00
      PBVL(K)=0.00
50    CONTINUE
      C
      60    CONTINUE
          KOUNT=0
      C
      C
      70    CONTINUE
      C
      C      ....CALCULATION OF ELEMENTS OF MATRIX A AND VECTOR C.....
      C
          JJ5=JJ+5
          NNJJ=NN+JJ
      C
      C      ....ELEMENTS OF MATRIX A.....
      C
      C      ....1ST ROW....
          A(1,1)=0.0
          DO 11 J=1, JJ5
      11    A(1,1) = A(1,1) - G(1,J)
          CONTINUE
          A(1,2) = G(1,5)
          DO 21 J=1, JJ
          NNJ=NN+J
          J5=J+5
          A(1,NNJ) =G(1,J5)
      21    CONTINUE
      C
      C      ....ROWS 2 TO NN-1.....
          NN1=NN-1
          DO 51 I=2, NN1
          A(I,I-1) = G(I-1,5)
          A(I,I+1) = G(I,5)
          A(I,I) = -G(I-1,5)
          DO 31 J=1, JJ5
          A(I,I) = A(I,I) - G(I,J)
      31    CONTINUE

```

```

      D0 41  J=1,JJ
      NNJ=NN+J
      J5=J+5
      A(I,NNJ)=G(I,J5)
41    CONTINUE
51    CONTINUE
C
C      ....ROW NN.....
      A(NN,NN-1) = G(NN-1,5)
      A(NN,NN) = -G(NN-1,5)
      D0 61  J=1,4
      A(NN,NN) = A(NN,NN) - G(NN,J)
61    CONTINUE
      D0 71  J=6,JJ5
      A(NN,NN) = A(NN,NN) - G(NN,J)
71    CONTINUE
      D0 81  J=1,JJ
      NNJ=NN+J
      J5=J+5
      A(NN,NNJ)=G(NN,J5)
81    CONTINUE
C
C      ....ROW NN+J.....
      D0 101 J=1,JJ
      NNJ=NN+J
      J5=J+5
      A(NNJ,NNJ)=0.0
      D0 91  I=1,NN
      A(NNJ,I)=G(I,J5)
      A(NNJ,NNJ)=A(NNJ,NNJ)-G(I,J5)
91    CONTINUE
      A(NNJ,NNJ)=A(NNJ,NNJ) -GBV(J) -GTV(J)
101   CONTINUE
C
C      ....ELEMENTS OF VECTOR C.....
C
      D0 111 K=1,NN
      C(K)=-.001*ACPF(K)

```

```

111 CONTINUE
C
C .....1ST ROW.....
D0 121 J=1,4
C(1) = C(1) - G(1,J)*(PRESX(1,J) + PL(1,J))
121 CONTINUE
D0 131 J=5,JJ5
C(1) = C(1) - G(1,J) * (PRESX(1,J) - PL(1,J))
131 CONTINUE
C
C .....ROWS 2 TO NN-1.....
D0 141 I=2,NN1
D0 141 J=1,4
C(I) = C(I) - G(I,J) *(PRESX(I,J) + PL(I,J))
141 CONTINUE
D0 151 J=5,JJ5
C(I) = C(I) -G(I,J)*(PRESX(I,J) - PL(I,J))
151 CONTINUE
C(I)=C(I)+G(I-1,5)*(PRESX(I-1,5)-PL(I-1,5))
161 CONTINUE
C
C .....ROW NN.....
D0 171 J=1,4
C(NN) =C(NN) - G(NN,J)*(PRESX(NN,J) +PL(NN,J))
171 CONTINUE
D0 181 J=6,JJ5
C(NN) = C(NN) - G(NN,J)*(PRESX(NN,J) - PL(NN,J))
181 CONTINUE
C(NN) = C(NN) +G(NN-1,5) * (PRESX(NN-1,5) - PL(NN-1,5))
C
C .....ROW NN+J.....
D0 201 J=1,JJ
NNJ=NN+J
IB=IBV(J)
JB=JBV(J)
J5=J+5
C(NNJ)=GBV(J)*(PRESX(IB,J5)-PRESX(IB,JB)-PBVL(J))- .001*FANSH(J)
IT=ITV(J)

```

```

JT=JTV(J)
C(NNJ)=C(NNJ)+GTV(J)*(PRESX(IT,J5)-PRESX(IT,JT)-PTVL(J))
DØ 191 I=1,NN
C(NNJ)=C(NNJ)+G(I,J5)*(PRESX(I,J5)-PL(I,J5))
191 CONTINUE
201 CONTINUE
C
C
C
C    ...COMPRESS MATRIX A INTO AA STORED BY COLUMNS...
DØ 211 J=1,NNJJ
JAA=J-1
IAA=JAA*NNJJ
DØ 211 I=1,NNJJ
IIAA=I+IAA
AA(IIAA)=A(I,J)
211 CONTINUE
C
C    CALL SIMQ (AA,C,NNJJ,KS)
C    ..PRESSURES P(I) ARE RETURNED IN C...
C    IF (KS) 1000,221,1100
221 CONTINUE
C
C
C
C    .....CALCULATE FLOW FUNCTIONS FOR LINEAR MODEL.....
C
C    ITERM = 0
C
C    DØ 22 J=1,4
C    DØ 12 I=1,NN
C    FX = G(I,J) * (PRESX(I,J)-P(I) + PL(I,J))
C    IF (DABS(FX-F(I,J))-ERROR) 12,12,2
2    F(I,J) =FX
C    CALL LINIZF (FX,EA(I,J),G(I,J),PL(I,J),X(J))
C    ITERM = ITERM +1
12 CONTINUE
22 CONTINUE
C
C    NN1=NN-1

```

C

```
D0 42 I=1,NN1
FX= G(I,5)*(P(I)-P(I+1) +PL(I,5) -PRESX(I,5))
IF (DABS(FX-F(I,5))-ERROR) 42,42,32
32 F(I,5) =FX
CALL LINIZE (FX,EA(I,5),G(I,5),PL(I,5),X(5))
ITERM =ITERM +1
42 CONTINUE
```

C

```
D0 72 J=1,JJ
NNJ=NN+J
J5=J+5
D0 62 I=1,NN
FX= G(I,J5)*(P(I)-PRESX(I,J5)-P(NNJ) +PL(I,J5))
IF (DABS(FX-F(I,J5))-ERROR) 62,62,52
52 F(I,J5) = FX
CALL LINIZE (FX,EA(I,J5),G(I,J5),PL(I,J5),X(J5))
ITERM =ITERM +1
62 CONTINUE
72 CONTINUE
```

C

XVENT=0.500

C

```
D0 122 J=1,JJ
NNJ=NN+J
IB=IBV(J)
JB=JBV(J)
IT=ITV(J)
JT=JTV(J)
J5=J+5
FX= GBV(J)*(PRESX(IB,JB) -P(NNJ)-PRESX(IB,J5)+PBVL(J))
IF (DABS(FX-FBV(J))-ERROR) 92,92,82
82 FBV(J) = FX
CALL LINIZE (FX,BV(J),GBV(J),PBVL(J),XVENT)
ITERM =ITERM +1
92 CONTINUE
FX = GTV(J)*(PRESX(IT,JT)-P(NNJ)-PRESX(IT,J5)+PTVL(J))
IF (DABS(FX-FTV(J))-ERROR) 112,112,102
```

```

102   FTV(J) = FX
      CALL LINIZE (FX,TV(J),GTV(J),PTVL(J),XVENT)
      ITERM = ITERM + 1
112   CONTINUE
122   CONTINUE
C
      KOUNT =KOUNT +1
      IF (KOUNT=50) 800,800,1000
800   IF(ITERM) 900,1000,900
900   DO 950 K=1,NNJJ2
      AA(K)=0.00
950   CONTINUE
      GO TO 70
C
1000  CONTINUE
C      ....FLEWS IN CFM....
      DO 1010 J=1,JJ5
      DO 1010 I=1,NN
      F(I,J)=F(I,J)*1000.
1010  CONTINUE
      DO 1020 J=1,JJ5
      FTV(J)=FTV(J)*1000.
      FBV(J)=FBV(J)*1000.
1020  CONTINUE
      RETURN
C
1100  WRITE (IDIAG,3000)
1999  STOP
3000  FORMAT(1X,'SINGULAR MATRIX-NO SOLUTION GIVEN BY SIMQ')
      END

```

```

SUBROUTINE SIMQ( A,B,N,KS)
C
C
C THIS SUBROUTINE IS FOR USE WITH THE AIR FLOW BUILDING MODEL PRGR
C THIS SUBROUTINE SOLVES THE LINEAR SIMULTANEOUS EQUATIONS
C
IMPLICIT REAL*8(A-H,O-Z),INTEGER*4(I-N)
DIMENSION A(1),B(1)
C FORWARD SOLUTION
KS=0
JJ=-N
DO 65 J=1,N
JY=J+1
JJ=JJ+N+1
BIGA=0.00
IT=JJ-J
DO 30 I=J,N
C SEARCH FOR MAXIMUM COEFFICIENT IN COLUMN
IJ=IT+I
IF(A(IJ)) 2,30,4
2 ABSA=-A(IJ)
GO TO 5
4 ABSA=A(IJ)
5 IF(BIGA) 6,20,8
6 BIGA=-BIGA
8 DIF=BIGA-ABSA
IF(DIF) 20,30,30
20 IMAX=I
25 BIGA=ABSA
30 CONTINUE
ITIM=IT+IMAX
BIGA=A(ITIM)
C TEST FOR SINGULAR MATRIX
IF(BIGA) 40,35,40
35 KS=1
RETURN
C INTERCHANGE ROWS IF NECESSARY

```



```

40  I1=J+N*(J-2)
    IT=IMAX-J
    DO 50 K=J,N
    I1=I1+N
    I2=I1+IT
    SAVE =A(I1)
    A(I1)=A(I2)
    A(I2)=SAVE
C   DIVIDE EQUATION BY LEADING COEFFICIENT
40  A(I1)=A(I1)/BIGA
    SAVE=B(IMAX)
    B(IMAX)=B(J)
    B(J)=SAVE/BIGA
C   ELIMINATE NEXT VARIABLE
55  IF(J=N) 55,70,55
    IQS=N*(J-1)
    DO 65 IX=JY,N
    IXJ=IQS+IX
    IT=J-IX
    DO 60 JX=JY,N
    IXJX=N*(JX-1)+IX
    JJX=IXJX+IT
60  A(IXJX)=A(IXJX)-(A(IXJ)*A(JJX))
65  B(IX)=B(IX)-(B(J)*A(IXJ))
C   BACK SOLUTION
70  NY=N-1
    IT=N*N
    DO 80 J=1,NY
    IA=IT-J
    IB=N-J
    IC=N
    DO 80 K=1,J
    B(IB)=B(IB)-A(IA)*B(IC)
    IA=IA-N
80  IC=IC-1
    RETURN
    END

```

C

```
SUBROUTINE LINIZE(FINIT,CONS,SLOPE,PX,XX)
  IMPLICIT REAL*8(A-H,O-Z),INTEGER*4(I-N)
  FMIN=.00005
  IF(XX=.050) 20,2,1
  1  IF(XX=1.00) 2,9,20
  2  IF (CONS) 20,8,3
  3  IF (FINIT-FMIN) 5,7,4
  4  PINIT=(FINIT/CONS)**(1.00/XX)
    SLOPE=XX*CONS*PINIT**(XX-1.00)
    PX=FINIT/SLOPE-PINIT
    GO TO 11
  5  IF (FINIT+FMIN) 6,7,7
  6  PINIT=(-FINIT/CONS)**(1.00/XX)
    SLOPE=XX*CONS*(-PINIT)**(XX-1.00)
    PX=FINIT/SLOPE-PINIT
    GO TO 11
  7  PMIN=(FMIN/CONS)**(1.00/XX)
    SLOPE=FMIN/PMIN
    GO TO 10
  8  SLOPE=0.00
    GO TO 10
  9  SLOPE=CONS
  10 PX=0.00
  11 RETURN
  20 STOP
  END
```

HEATING AND VENTILATING RESEARCH ASSOCIATION
BRACKNELL, BERKSHIRE
LIBRARY

```

C      SUBROUTINE OUT1(IOUT)
C
C      THIS SUBROUTINE CALCULATES AND OUTPUTS PRESSURE DIFFERENCES
C      ON FORTRAN DEVICE NUMBER IOUT
C
C
C      ***DIMENSIONS ARE FOR MAXIMUM OF 25 FLOORS AND 8 SHAFTS***
C
C      IMPLICIT REAL*8(A-H,O-Z),INTEGER*4(I-N)
C      COMMON/BKARG/NN,JJ,ITERM,KOUNT,F(25,13),FTV(8),FBV(8),C(33)
C      COMMON/INPX/H(25),EA(25,13),X(13),TV(8),BV(8),PRESX(25,13),ITV(8)
1      ,JTV(8),IBV(8),JBV(8)
C      DIMENSION PPX(8),DELP(25,13),DELP(8),DELPBV(8),P(33)
C      EQUIVALENCE (P(1),C(1))
C
C      JJ5=JJ+5
C      NN1=NN-1
C
C      ...CALCULATE PRESSURE DIFFERENCES...
C
C      DO 30 J=1,4
C      DO 31 I=1,NN
C      DELP(I,J)=PRESX(I,J)-P(I)
31      CONTINUE
30      CONTINUE
C
C      DO 40 I=1,NN1
C      DELP(I,5)=P(I+1)-P(I)+PRESX(I,5)
40      CONTINUE
C
C      ....NO FLOOR ABOVE, SO SET DELP EQUAL TO ZERO....
C      DELP(NN,5)=0.
C
C      DO 50 J=1,JJ
C      J5=J+5
C      NNJ=NN+J

```

```

DØ 51 I=1,NN
DEL P(I,J5)=P(NNJ)+PRESX(I,J5)-P(I)
51 CONTINUE
ITVJ=ITV(J)
JTVJ=JTV(J)
IBVJ=IBV(J)
JBVJ=JBV(J)
DELPTV(J)=P(NNJ)+PRESX(ITVJ,J5)-PRESX(ITVJ,JTVJ)
DELPBV(J)=P(NNJ)+PRESX(IBVJ,J5)-PRESX(IBVJ,JBVJ)
50 CONTINUE
C
C   ...WRITE PRESSURE DIFFERENCES...
C
WRITE (IØUT,2000)
WRITE (IØUT,2001)
WRITE (IØUT,2002)
DØ 60 I=1,NN
WRITE (IØUT,101) I,(DEL P(I,J),J=1,JJ5)
60 CONTINUE
WRITE (IØUT,2004) (DELPTV(J),J=1,JJ)
WRITE (IØUT,2005) (DELPBV(J),J=1,JJ)
WRITE (IØUT,2006)
RETURN
C
101 FORMAT (1X, I2 ,13(2X,F8.4))
2000 FORMAT ('1',25X,'*****PRESSURE DIFFERENCES (INCHES ØF WATER'
1      ', REFERENCED TØ FLØØR PRESSURE)*****')
2001 FORMAT ('0','LEVEL',2X,4('ØUTSIDE',3X),
1      'LEVEL',8(5X,'SHAFT'))
2002 FORMAT (8X,'SIDE 1',4X,'SIDE 2',4X,'SIDE 3',4X,'SIDE 4',4X,
1      'ABØVE',7X,'1',9X,'2',9X,'3',9X,'4',9X,'5',9X,'6',9X,'7',9X,'8')
2004 FORMAT ( / 13X,'.....TØP VENT.....',10F10.2)
2005 FORMAT (   11X,'.....BØTTØM VENT.....',10F10.2)
2006 FORMAT (///20X,'.....VENT PRESSURE DIFFERENCES ARE',
1      ' RELATIVE TØ ØUTSIDE AT THAT LEVEL.....')
END

```

```

SUBROUTINE OUT2(IOUT)
C
C THIS SUBROUTINE IS FOR USE WITH THE AIR INFILTRATION PROGRAM
C
C THIS SUBROUTINE OUTPUTS VOLUME FLOW RATES
C ON FORTRAN DEVICE NUMBER IOUT
C
C ***DIMENSIONS ARE FOR MAXIMUM OF 25 LEVELS AND 8 SHAFTS***
C
C IMPLICIT REAL*8(A-H,O-Z),INTEGER*4(I-N)
COMMON/BKARG/NN,JJ,ITERM,KOUNT,F(25,13),FTV(8),FBV(8),C(33)
COMMON/INPX/H(25),EA(25,13),X(13),TV(8),BV(8),PRESX(25,13),ITV(8)
1      ,JTV(8),IBV(8),JBV(8)
C DIMENSION SUMP0S(13),SUMNEG(13)
C
C JJ5=JJ+5
C
C DO 30 J=1,JJ5
C SUMP0S(J)=0.00
C SUMNEG(J)=0.00
C DO 20 I=1,NN
C IF (F(I,J)) 10,15,15
10 SUMNEG(J)=SUMNEG(J)+F(I,J)
C GO TO 20
15 SUMP0S(J)=SUMP0S(J)+F(I,J)
20 CONTINUE
30 CONTINUE
C DO 90 J=1,JJ
C J5=J+5
C IF (FTV(J)) 40,50,50
40 SUMNEG(J5)=SUMNEG(J5)+FTV(J)
C GO TO 60
50 SUMP0S(J5)=SUMP0S(J5)+FTV(J)
60 IF (FBV(J)) 70,80,80
70 SUMNEG(J5)=SUMNEG(J5)+FBV(J)
C GO TO 90
80 SUMP0S(J5)=SUMP0S(J5)+FBV(J)

```

```

90  CONTINUE
C
C  ...OUTPUT VOLUME FLOW...
WRITE (IOUT,1200)
WRITE (IOUT,1101)
WRITE (IOUT,1102)
WRITE (IOUT,1106)
DO 100 I=1,NN
WRITE (IOUT,1203) I,(F(I,J),J=1,JJ5)
100 CONTINUE
WRITE (IOUT,1204) (FTV(J),J=1,JJ)
WRITE (IOUT,1205) (FBV(J),J=1,JJ)
C
C  ...WRITE SUM OF +VE AND -VE FLOWS FOR EACH COLUMN...
WRITE (IOUT,1107)
WRITE (IOUT,1105) (SUMP0S(J),J=1,4),(SUMP0S(J),J=6,JJ5)
WRITE (IOUT,1108) (SUMNEG(J),J=1,4),(SUMNEG(J),J=6,JJ5)
C
WRITE (IOUT,1109)
WRITE (IOUT,1110)
WRITE (IOUT,1111)
WRITE (IOUT,1112)
WRITE (IOUT,1113)
C
RETURN
1101 FORMAT ('0','LEVEL',2X,4('OUTSIDE',3X),
1      'LEVEL',8(5X,'SHAFT'))
1102 FORMAT (8X,'SIDE 1',5X,'SIDE 2',3X,'SIDE 3',4X,'SIDE 4',4X,
1      'ABOVE',7X,'1',9X,'2',9X,'3',9X,'4',9X,'5',9X,'6',9X,'7',
1      9X,'8')
1105 FORMAT (1X,'+VE',F9.0,3F10.0,10X,8F10.0)
1106 FORMAT (10X,'(1)',3(7X,'(1)'),6X,'(2)',8(7X,'(3)'))
1107 FORMAT (/ 1X,'...SUM OF FLOWS...')
1108 FORMAT ('0','-VE',F9.0,3F10.0,10X,8F10.0)
1109 FORMAT (///10X,'*****SIGN CONVENTIONS*****')
1110 FORMAT (10X,'(1)  + INDICATES FLOW FROM OUTSIDE TO LEVEL AREA')
1111 FORMAT (10X,'(2)  + INDICATES FLOW FROM LEVEL SPACE TO LEVEL'
1      ', ' ABOVE')

```

```
1112  FORMAT (10X,'(3)  + INDICATES FLOW FROM LEVEL SPACE TO SHAFT')
1113  FORMAT (10X,'(4)  + INDICATES FLOW FROM OUTSIDE TO SHAFT',
1      '(THROUGH VENT OPENING)')
1200  FORMAT ('1',45X,'****VOLUME FLOW RATE (SCFM)****')
1203  FORMAT (1X,I2,I3(2X,F8.1))
1204  FORMAT ( / 13X,'.....TOP VENT..(4)..' ,20X,8F10.1)
1205  FORMAT ( 11X,'.....BOTTOM VENT..(4)..' ,20X,8F10.1)
      END
```