

TRNFLOW: Integration of COMIS into TRNSYS TYPE 56

Andreas Weber ¹, Markus Koschenz ¹,
Stefan Holst ², Marion Hiller ², Torsten Welfonder ²

¹ EMPA, Abteilung Energiesysteme/Haustechnik, CH-8600 Dübendorf
² TRANSSOLAR Energietechnik GmbH, D-70569 Stuttgart

ABSTRACT

TRNSYS' thermal building model, type 56, requires air flows between zones as input values. However, in natural ventilation systems these depend on the wind pressures and the inside and outside temperatures. To account for this situation, a coupling with an air flow model is absolutely necessary. TRNFLOW integrates the multi-zone air flow model COMIS into the type 56. An internal solver, optimised for this task, iterates in each time step between the two models until their solutions are consistent. The existing user surface PREBID was extended in such a way that data for the air flow model can be entered. Thus a user-friendly handling of the coupling is assured. With TRNFLOW, a immense step forward has been made for building simulation with TRNSYS.

KEYWORDS

natural ventilation, building simulation, TRNSYS, COMIS, TRNFLOW.

Introduction

In the thermal building model TRNSYS Type 56 the air flows between the zones and from the outside are defined by the user as input values. In natural ventilation systems these values depend on external wind pressures and the inside and outside temperatures. To meet these requirements there has to be a link to an airflow model. For these purposes in TRNFLOW the multi-zone air flow model COMIS has been integrated into Type 56. An internal solver algorithm optimized for this task iterates between the two models in every time step until the results are consistent. The capabilities of the existing user interface PREBID were enlarged to allow input of the necessary data for the air flow model. Therewith a user-friendly handling of the linked models will be guaranteed. With TRNFLOW the building simulation with TRNSYS has moved a major step forward.

Current Situation

In order to achieve sustainable buildings new energy systems have been generated using natural effects to renew the air and lead away the heat. Examples are passive night cooling, double facades, solar chimneys, inside courtyards and so on. In these systems the mutual impacts of thermal and air flow behavior are very distinctive. Thus for numerical building simulation programs an integral approach is inevitable.




Fig. 1: Present solution of the integration of COMIS as TYPE 157 into TRNSYS Type 56

Already in 1993 in the frame of the IEA project Annex 23 the EMPA has developed a coupling of the multizone air flow model COMIS with the thermal building and system simulation program TRNSYS and this was presented at the TRNSYS Userday 1994. The self-contained program COMIS was modified to TRNSYS Type 157 which can be linked to the thermal building model Type 56 within the TRNSYS-Deck via in- and outputs. The input information of the air flow model are read in by Type 157 from the standard COMIS Input File (CIF). The TRNSYS solver iterates the results of the two models until they match (Fig. 1).

Meanwhile the coupling has been successfully applied by several projects and simulation tasks. However thereby it was pointed out that the coupling is not very user-friendly and also requires a laborious handling. As the mutual classification of the data is made by hand the inputs tend to be incorrect. This susceptibility is also increased by the redundancies of the two input files. Furthermore it was proven that the TRNSYS solver is not always the perfect solution for such a system. The solver possibly has to be supported by additional convergence promoting Types what makes the handling again more difficult. Yet the need of an integral approach concerning thermal building dynamics and natural air exchange is clearly necessary. Therefore with TRNFLOW an improved version including a deepened integration of the two models has been developed.

Multizone Air Flow Model COMIS

Multizone air flow models idealize the building as a network of nodes and airflow links. A node represents a room volume which a set of state variables can be assigned to. Cracks, window joints and openings, shafts as well as ventilation components like inlets and outlets, ducts and fans represent the links. Boundary conditions and thereby also input factors are:

- State variables of the air in the zones
- Local wind pressures

The pressure p_Z is a free parameter in the node which is evaluated according to the continuity equation (mass flow balance in the node = 0). This results in n_Z equations where n_Z represents the number of zones.




Fig. 2: Modelling of a building with zones and current outlets

The relation between mass flow rate m and pressure difference Δp and thus the zone pressure p_Z is not linear. Therefore an iterative process is used to solve the system of equations. The mass flow rates per link and all dependent factors such as air exchange rates, air age etc. are calculated of the resulting zone pressures p_{Zi} . The calculation is static without an explicit consideration of the timestep. In principle calculating a condition based on a new time is independent of the previous timestep.

Coupling Concept

The indoor temperatures are important boundary conditions of a multi zone air flow model which mostly can only be defined on the basis of the user's guess. The indoor air temperatures calculated by the thermal model strongly depend on the exchange of air between the zones as well as the outside. To link the two models and mutually use the results is the obvious consequence. Thus the multi zone air flow model is completely integrated into Type 56. This means that the exchange of data between the thermal and the air flow model is made internally and no longer by inputs and outputs. The proper classification of air flows (infiltration, ventilation, couplings) and temperatures to the air flow node resp. the thermal zones and the appropriate other model is automatically carried out by the program.




Fig. 3: New concept of coupling of models: the air flow model is fully integrated in Type 56

The input files of both models are kept in the existing formats (BUI, CIF) but can be created by the common user interface PREBID 5. Air flow model data depending on time like wind velocity or window opening factors are defined as inputs or schedules. Outputs like air flows or zone

pressures are declared as outputs by means of new NTYPES and can be written into an output file using a printer type or processed otherwise. The standard COMIS Output File (COF) is optionally also available.

Internal Solver and User Interface

Due to the integration of the air flow model into Type 56 the TRNSYS Solver can no longer be used for the iteration process between the two models. I.e. the solutions have to reach convergence using a solver integrated into Type 56. Depending on the boundary conditions the coupling of the two models forms a recursive flow of information with negative feedback. E.g. at cold outdoor air an increasing indoor temperature imposes an increasing exchange of air. In turn this counters another increase of the indoor temperature so that a balance will appear (Fig. 4). If the negative feed back gets too strong there will be the risk of getting an unstable system. A solver algorithm with a successive substitution method (TRNSYS solver 0) then also becomes unstable. Therefor the new solver integrated into Type 56 automatically dampens individually every recursive flow of information according to the iteration process so that an optimum of stability and convergence is achieved.




Fig. 4: Recursive flow of information between air flow and thermal model

Unlike the current situation for TRNFLOW only the functionality of PREBID has to be enlarged. Beneath traditional data of the thermal model also the required input information of the air flow model will be entered into the new PREBID 5. This data is also stored in the BUI file and can be read in from it again. Analog to the Standard Type 56 files (TRN, BLD) the new PREBID 5 also creates a COMIS Input File (CIF) which is read by TRNFLOW (Fig. 5). The CIF created this way is - with few additions - completely equivalent to the format described in the COMIS 3.1 User`s Guide [2].




Fig. 5: Concept for user interface for TRNFLOW

Due to this approach it is intended that a future version of SIMCAD will also record air flow model data beneath the geometric data of the thermal model and write it into the BUI file.

Duct Network System

Beneath the room nodes (thermal zones) the air flow model needs additional auxiliary nodes for the ventilation duct network as junctions of the individual parts of the duct system. In order to keep the thermal model small these nodes are not modeled as thermal zones in Type 56.

The temperatures of the auxiliary nodes are directly calculated from the temperatures of the joining air flows. Thermal capacitance or other heat gains or losses of these nodes are not considered. In the thermal model air flows of the auxiliary nodes into the space zones are interpreted as ventilations.

To model an air heater or cooler, resp. a humidifier or dehumidifier, temperature as well as humidity can be defined for an auxiliary node by means of a constant, input or schedule variable. The power necessary to reach this set point for the air can be obtained by an output.

Figure 6 shows an example for the illustration of a duct network. The reference temperature of 20°C is defined for the auxiliary node AN6. For Room3 results a ventilation of 33kg/s with 17.9°C. Room1 and Room2 have zero ventilation.




Fig. 6: Example duct network system

Example: Double Facade

Although the development of TRNFLOW is not yet finished, experience could be obtained using the preliminary model of the expanded Type 56. The Figures 7 and 8 show a multi story building with double facade as an example.

TRNFLOW could demonstrate its suitability for large building models by an example with more than 60 thermal zones and lots of auxiliary nodes. No numerical or other difficulties have been obtained in those runs.




Fig. 7: Air flow network model of a multi story building with double facade




Fig. 8: ONLINE Plot of the zone temperatures: floor 2, double facade 2, staircase and outside temperature as well as the air flow referring to the room volume between floor2 and the staircase and the number of internal iterations

Conclusions

- TRNFLOW is a tool which allows an easy calculation of natural ventilation, passive night cooling, double facades and exhaust air shafts quite fast.
- No new input file structure or user interface has to be learned. Using PREBID 5 simply the known user-friendly user interface has been expanded.
- The newly-developed internal solver is featured with high stability. Due to integrated automatic optimization of convergence the user is no longer bothered with numerical questions.

References

- [1] H. Feustel, B. Smith, V. Dorer, A. Haas A. Weber et al.: *COMIS 3.1 – Program for Modelling of Multizone Airflow and Pollutant Transport in Buildings*, 2001 EMPA Dübendorf
- [2] H. Feustel, B. Smith, V. Dorer, A. Haas A. Weber et al.: *COMIS 3.1 – User's Guide*, 2001 EMPA Dübendorf