




#### Background pressure change correction






#### Pulse Progression over the past 20 years








# Low Pressure Pulse (LPP) Airtightness

• Low pressure rapid air leakage testing (4Pa)

- Measured air change rates that are representative of normal occupied conditions
- Simple user operation
- Low disruption
- Extensive validation
- Approved under UK Building Regulations (CIBSE TM23)








## Summary


- \* Air tightness testing needn't be a one size fits all single product market
- UK Regulations have set a precedent with CIBSE TM23, a globally accessible third party standard.
- Global market for Pulse across numerous fields new and existing homes, non-residential buildings and specialist environments. Very different to blower door fan and thus offers numerous new opportunities
- There is a large detailed and comprehensive evidence base for LPP and the Pulse product – commercial, academic and 3<sup>rd</sup> party inc. ETV




































Settings			Results				
TightnessTester		÷	AirTightnessTester				
CIN instrumenten by							
General information			General information				
Date Start time	2023-04-19		Date	2023-04-19			
Start time End time	12:23:42		Start time	12:23:42			
Location	Korenbloem 57		End time	12:28:52			
Type of ventilation	Balanced		Location	Korenbloem 57			
Measurement parameters	Durances	_	Type of ventilation	Balanced			
Standard	0.4 l/s/m <sup>2</sup>		Measurement parameters				
Flow rate (low)	77.0 m <sup>3</sup> /h	Edit	Standard	0.4 l/s/m <sup>2</sup>			
Flow rate (high)	445.0 m <sup>3</sup> /h	Edit	Flow rate (low)	77.0 m <sup>3</sup> /h	Ed		
Flow exponent	0.66	Edit	Flow rate (high)	445.0 m <sup>3</sup> /h	Ed		
Area	125.0 m <sup>2</sup>	Edit	Flow exponent	0.66	Ed		
Volume	Volume not filled in	Edit	Area	125.0 m <sup>2</sup>	Ed		
Results			Volume	Volume not filled in	Ed		
Average pressure	31.5±0.1 Pa				-		
Airtightness@10Pa	0.44±0.06 l/s/m <sup>2</sup>	Edit	Results				
			Average pressure	31.5±0.1 Pa			
			Airtightness@10Pa	0.44±0.06 l/s/m <sup>2</sup>	Ed		







1.200	Δf	ter		
1.4	7.1			_
C.C.	AirTightnessTester		:	
1.15		n bv		
	General information			
	Date	2023-06-16		
	Start time	12:17:37		
	End time	12:23:09		
	Location			
	Type of ventilation	Balanced		
	Measurement parameters			
	Standard	200.0 l/s/m <sup>2</sup>		
	Flow rate	440.0 m <sup>3</sup> /h	Edit	
	Flow exponent	0.66	Edit	
	Area	125.0 m <sup>2</sup>	Edit	
	Volume	350.0 m <sup>3</sup>	Edit	
	Results			
	Average pressure	4.2±0.5 Pa		
	Airtightness@10Pa	1.73±0.21 l/s/m <sup>2</sup>	Edit	









#### **Acoustic Approach**





- Possible approach to identify leak locations in building envelopes:
  microphone array + speaker
- Advantages:
  - Independent from pressure and temperature differences
  - Scanning of large areas possible


Kölsch/Schiricke, 19.06.2023























































## Thank you!

Dr.-Ing. Benedikt Kölsch Cerema benedikt.koelsch@cerema.fr

Dr.-Ing. Björn Schiricke DLR bjoern.schiricke@dlr.de

21

Kölsch/Schiricke, 19.06.2023