
INSTITUTTET FOR BYGNINGS
DEPT. OF BUILDING TECHNOLOGY AND STRUCTURAL
AALBORG UNIVERSITET • AAU • AALBORG

AIVC 11196

**INDOOR ENVIRONMENTAL TECHNOLOGY
PAPER NO. 64**

**Summary Report at ROOMVENT '96 Workshop: Outcome of IEA Annex 26
"Energy Efficient Ventilation of Large Enclosures", Yokohama, Japan, July
1996, pp. 4-11**

**P. HEISELBERG
ANALYSIS AND PREDICTION TECHNIQUES
DECEMBER 1996**

ISSN 1395-7953 R9656

Analysis and Prediction Techniques

Per Heiselberg
Aalborg University
Sohngaardsholmsvej 57
DK-9000 Aalborg
Denmark

ABSTRACT

In large enclosures, common ventilation strategies, ^{such} as complete mixing, require considerable amounts of energy to move and condition enormous amounts of air. The air flow pattern should therefore be well planned and controlled to ensure an acceptable indoor air quality in the occupied zone without the need for excessive air flow rates.

This part of the summary report concentrates on describing methods for designing and analysing ventilation in large enclosures. It includes application of different mathematical models in the design process for simulation of temperature distribution, air motion and contaminant spread in order to evaluate performance and locate problems.

At the first stages of the design process information is rather limited. Approximate HVAC solutions are developed based on engineering experience and use of appropriately simple analytical tools (macroscopic models) to save design work. At the latter stages of the design process more information is available and more detailed analytical tools (microscopic models) can be applied to evaluate the proposed air flow design.

The Annex 26 work has resulted in an easy and strategic procedure for designers and HVAC engineers to design ventilation and air conditioning by choosing adequate models at each design stage.

KEY WORDS

Large Enclosures, Air Flow Modelling, Energy Efficient Ventilation.

INTRODUCTION

Large enclosures, for example concert halls, sports centre and ice rinks, office buildings, factory halls, atria, shopping centres or passenger terminal buildings often present unsolved problems related to energy and air flows such as unwanted thermal stratification, local overheating, draughts or uncontrolled contaminant spreading. Therefore, within the International Energy Agency - Energy Conservation in Buildings and Community System (IEA-ECB&CS) a joint research programme, Annex 26 "Energy-Efficient Ventilation of Large Enclosures" was established to address these problems.

A large enclosure is defined as an enclosed ventilated air space at least partly occupied and containing various contaminant and heat sources. It is distinguished from other occupied rooms by the strong effect that buoyancy and temperature differences have on air motion, in particular on vertical streams of warm or cold air. Large enclosures may be complex and have partitions and openings.

In large enclosures common ventilation strategies, like complete mixing, require considerable amounts of energy to move and condition enormous amounts of air. The air flow pattern should therefore be well planned and controlled to ensure an acceptable indoor air quality in the occupied zone without the need for excessive air flow rates. This is obviously possible since, in large en-

PREDICTION TECH- ENCLOSURES

and analysis of venti-
two main groups ac-
elling detail. The first
s, which are simplified
d design development,
s, engineering models
d group is microscopic
l models for design
ng, such as computa-
and scale model ex-
ventilation efficiency
method to evaluate the
d on the results of the
s or measurements in

involved in the design
can be divided into ini-
sign phase, ventilation
design evaluation and
phase and commis-

the design process,
of the building and the
onment are roughly
ther limited. Conse-
AC solutions are de-
g experience (such as
gs) and use of appro-
s (macroscopic mod-
owever, for critical or
ble previous experi-
may not be available.
te tools (microscopic
n the design process,
to qualitatively evalu-

f the design process,
chitectural design are
more information is
analytical tools
e applied to evaluate
v design will work as
ms with local thermal
sation etc. The per-
stem can be evaluated
el. If the design crite-
c can be used for fur-
design improvement.
ized enclosures such
essary, as ventilation
s are well established

and application of more simple analytical methods will often be sufficient.

Table 1 summarises function, capability, obtained information and necessary resources for

each type of analysis and prediction technique. In the following sections each technique is described in more detail including date requirements, expectations to results and application advantages and disadvantages.

Table 1. Outline of analysis and prediction techniques for air flow in large enclosures.

	Macroscopic Model	Microscopic Model	Ventilation Efficiency Model
Design Stage	Initial and ventilation design phase	Ventilation design evaluation and troubleshooting	Ventilation design evaluation and troubleshooting
Purpose	Macroscopic analysis of air flow and temperature distribution at a few typical points	Microscopic analysis of air flow and temperature distribution in detail	Evaluation of efficiency of HVAC system
Available models	Flow Element model Engineering model Zonal model	CFD based on turbulence model Scale model experiment	Analysis by experiment Analysis based on results of CFD
Output	Mean temperature Vertical temperature distribution Heat load Air Flow Pattern Boundary conditions for CFD	Detailed distribution of air flow and temperature Study of problems to be solved in design phase	Distribution of ventilation efficiency index Mechanism of heat transfer and air flow in actual situation
Necessary equipment	Personal computer etc.	Super computer or EWS for CFD Scale model with devices for model experiment	Super computer or EWS for CFD Scale model with devices for model experiment
CPU time	Few minutes	10 - 100 hours a case for CFD	1 - 10 hours a case for CFD
Required time for application	About half a day pr. case to make input data	About 1 week pr. case to make input data for CFD 1 - 3 weeks pr. case for model experiment	About 1 day pr. case to make input data for CFD 1 - 3 weeks pr. case for model experiment

Flow Element Models

The flow process in ventilated rooms can be divided into different elements such as supply air jets, exhaust flows, thermal plumes, boundary layer flows, infiltration and gravity currents. These flow elements are isolated volumes where air movement is controlled by a restricted number of parameters, and is fairly independent of the general flow in the enclosure. Flow element models are very useful in

situations where the air flow pattern in a room is dominated by a single flow element or by flow elements which are not interacting with each other.

These semi-empirical models are often based on comprehensive measurement work and experience, but are also often developed under simplified geometrical and physical conditions. Therefore, they give very good results in cases where the conditions are close to the experimental

by models derived
the pressure distribu-
estimated from ge-
temperature differ-
outside combined
tics determines the
results are velocities
The large enclosure
zone with tempera-
ies in the model are
meters such as wind
leakage characteris-

al models is to split
ral macro-volumes,
y balances and to
eratures, pressures
macrovolume. The
s to evaluate the air
(heat fluxes) between
del with a large ap-
acy has been estab-
or flow elements in
by linking air mass
essure difference in
of the zonal model
field, that it, in prin-
analysis of time de-
e. However, detailed
ot be predicted, and
lower when the flow

es strongly depends
aces which limit the
and heat fluxes. To
pendent parameters
els are used. Com-
e developed with the
ind system perform-
t include sufficiently
ure geometry, solar
nvection and radia-
Its directly usable in
arious approaches
6 work to solve this

bed as field models
y predict velocity,
erties throughout a
of resolution. Micro
nservation laws of
collectively called
d flow, and it uses
als.

CFD simulation of the flow field in large en-
losures presents many difficulties due to the large
size of the enclosure and the complicated flow field.
For a large space it is only possible to conduct
simulations with large computational cells, which
makes it difficult to model the turbulent flow field
accurately and also causes various types of nu-
merical errors. As a result of the large size of the
space the air flow in the enclosure is predominantly
thermally driven, and the enclosure has typically a
high degree of thermal coupling with the external
environment. Therefore, it is especially important
to model accurately surface heat transfer processes
such as natural/mixed convection, solar radiation,
long wave thermal radiation, heat transfer through
external walls and structural heat storage. The
complicated flow field in a large enclosure can be
characterised as an elliptic flow composed of separa-
tion, reattachment, circulation etc., as anisotropic
and highly three-dimensional flow, as nonisothermal
sometimes with pronounced thermal stratification
and, typically, as a predominantly buoyancy driven
flow. Accurate prediction of such a flow field is very
difficult and, the popular κ - ϵ turbulence model
sometimes fails to give reasonable results.

CFD is a large software system composed
of a great many subsystems, and hence its use
demands an insight into topics such as HVAC tech-
nology, computational mathematics, fluid dynamics
and turbulence statistics. The successful application
of CFD to HVAC design requires a high degree of
specialised knowledge and sound engineering
judgement based on experience and expertise.

Annex 26 has studied all the processes, in-
volved in room air flow in large enclosures, and ad-
dressed the problems that arise in large enclosure
applications of CFD. It has resulted in a general
guidance and suggestions to overcome application
difficulties, and to get appropriate results at reason-
able costs.

Despite the many difficulties in the applica-
tion of CFD to large enclosure flow field analysis it
is the only method that makes a detailed analysis
possible. Although basic research into applying
CFD to room air flow problems started about 20-25
years ago, it is only within the last decade that CFD
has become practical for real design applications.
This advance had been impossible without the rapid
evolution of computer technology, and further ad-
vance in computer hardware and software technol-
ogy, combined with the decreasing cost of comput-
ing, will undoubtedly make CFD a more accessible
and attractive design tool in the future.

Scale Model Experiment

The principles and methods of scale model-
ling in ventilation applications have a long tradition
and are considered useful in ventilation design, es-
pecially, in air distribution in large enclosures. Scale
model experiments are performed mostly to deter-
mine air flow patterns in the enclosure under certain
boundary conditions determined by the indoor tech-
nology processes, the building construction and the
outdoor climate. Air flow patterns are often visual-
ised and temperatures and mean velocities are
measured.

It is assumed that similarity of the air mean
velocity fields can be fulfilled when the air flows in
real objects and in scale models are fully turbulent.
Similarity conditions include geometrical similarity,
similarity of the physical process and similarity of
boundary conditions. In modelling of air distribution
processes under steady state conditions the follow-
ing nondimensional numbers determine the similar-
ity of velocity and temperature fields: Reynolds
number ($Re = uL/\nu$), Archimedes number ($Ar =$
 $\beta g \Delta T u^2 / \nu^2$) and Prandtl's number ($Pr = \nu/a$).

In many cases it is impossible to maintain all
determining similarity numbers equal simultane-
ously for the whole ventilation process range.
Therefore according to the experimental target, it is
valuable to find out, which part of the general pro-
cess would be of special interest for modelling, and
in which part physical simulation would be more
suitable (e.g. substitute boundary conditions). In this
way, using the partial modelling method, model
construction and experiment can be much simpli-
fied. Equality of the nondimensional numbers Ar
and Re can not be fulfilled at the same time in both
a full-size ventilation system and a scale model,
when air is used as model fluid. However, if self
similarity of velocities and air flow patterns are as-
sumed in turbulent flows, a physically reasonable
simplification can be obtained, if the lowest level of
the Reynolds number, above which the flow in the
scale model becomes Reynolds number independ-
ent, is identified. In this way, using approximate
modelling, it is sufficient to maintain identical Ar -
and Pr numbers and Re numbers above a critical
value.

Scale model experiments require a proper
approach in model design and experimental organi-
sation. In constructing the model it is crucial to
choose model length scale so air flows within the
self-similarity range of the Reynolds number are
ensured, to choose proper simulation of boundary
conditions, to choose temperature difference scale
so relevant thermal boundary conditions and re-
quired accuracy of air velocity measurements can

done, depends on occupied space from ... In isolation of ... the properties of

of energy efficient ... has not only impli- ... also because the ... efficient ventilation can ... heat is particular im- ... a transport of heat ... en surfaces that can ... s that it is not possi- ... t between different

Common ventilation ... g, require consider- ... ove and condition ... the air flow pattern ... ed and controlled to ... quality in the occu- ... excessive air flow

ery report has sum- ... dels for predictions ... d indoor climate in ... provide various in- ... he information given ... degree of prediction ... each model. At the ... cess information is ... HVAC solutions are ... ing experience and ... e analytical tools ... design work. At the ... cess more informa- ... ailed analytical tools ... applied to evaluate

ls is reviewed from ... able 2 together with ... disadvantages. ... the HVAC engine- ... ure for designing ... y choosing adequa-

Table 2. Performance comparison of various analysis and prediction techniques.

	Flow element model	Zonal model (Eng. model)	CFD	Scale model experiment	Ventilation efficiency
Outline of model	Each element of flow, i.e. jet, plume, boundary layer flow etc., is analysed individually Entire flow field is examined by combination of these flow elements	Entire space is divided into several zones Balances of air flow rate, heat flux etc. are analysed, thus zone mean values of velocity, temperature and concentration are given	Space is divided into small cells, total number is about $10^4 - 10^5$ Discretized transport equations of velocity, temperature, concentration are solved with finite difference method	Indoor climate of large enclosures is measured using scale model of the space Similarity conditions between real space and model scale are important	Ventilation effectiveness for supplying fresh air and removing contaminants is analysed using results given from various models
Macro- or micromodel	Macromodel	Macromodel	Micromodel	Micromodel	-
Timedependent analysis	Difficult	Possible	Possible	Impossible	-
Limitation	Only the area of the flow element is analysed	Detailed distribution can not be predicted	A large number of cells are required for large enclosure analysis	Very difficult to satisfy similarity conditions accurately	Analysis dependent on results of other models
Input data requirements	Definition of type of flow element Empirical constants for supply jet, plumes etc. Temperatures of supply air, room air, surfaces Source heat flux	Zone division Boundary conditions at walls Location of heat sources etc. Properties of flow elements etc.	Mesh layout Boundary conditions for velocity heat flux etc.	Properties of supply jet etc. for calculation of similarity conditions Boundary conditions for interior heat sources and wall surface temperature etc.	Room air distribution Location of contaminant source Location of supply and volume flow rate of fresh air
Output information	Velocity and temperature distribution for each flow element	Mean temperature, pressure and concentration for each zone	Velocity and temperature distribution for each cell Wall surface temperature when radiation simulation is coupled	Space distribution of velocity and temperature Number of measuring points is limited due to experimental load	Ventilation efficiency evaluation Concentration distribution
Advantages	Practice is very simple and fast	Practice is rather simple Analysis of time-dependent phenomena possible	Very detailed analysis possible Presentation using CG technique is powerful	Measurement of physical phenomena is basically reliable	
Disadvantages	Can not be applied where flow elements interact with each other	Prediction accuracy becomes lower when flow field is complicated	Grid design and input data require large human work load Large CPU time is required	High experimental load (time, money, work)	

done, depends on occupied space from siding. In isolation of the properties of

of energy efficient is has not only impli- also because the efficient ventilation can heat is particular im- s a transport of heat en surfaces that can is that it is not possi- at between different

common ventilation ng, require consider- remove and condition he air flow pattern ed and controlled to r quality in the occur excessive air flow

ary report has sum- models for predictions d indoor climate in provide various in- the information given degree of prediction or each model. At the ocess information is HVAC solutions are ring experience and le analytical tools design work. At the ocess more informa- ailed analytical tools applied to evaluate

els is reviewed from able 2 together with d disadvantages. d the HVAC engine- dure for designing y choosing adequa-

Table 2. Performance comparison of various analysis and prediction techniques.

	Flow element model	Zonal model (Eng. model)	CFD	Scale model experiment	Ventilation efficiency
Outline of model	Each element of flow, i.e. jet, plume, boundary layer flow etc., is analysed individually Entire flow field is examined by combination of these flow elements	Entire space is divided into several zones Balances of air flow rate, heat flux etc. are analysed, thus zone mean values of velocity, temperature and concentration are given	Space is divided into small cells, total number is about $10^4 - 10^5$ Discretized transport equations of velocity, temperature, concentration are solved with finite difference method	Indoor climate of large enclosures is measured using scale model of the space Similarity conditions between real space and model scale are important	Ventilation effectiveness for supplying fresh air and removing contaminants is analysed using results given from various models
Macro- or micromodel	Macromodel	Macromodel	Micromodel	Micromodel	-
Time dependent analysis	Difficult	Possible	Possible	Impossible	-
Limitation	Only the area of the flow element is analysed	Detailed distribution can not be predicted	A large number of cells are required for large enclosure analysis	Very difficult to satisfy similarity conditions accurately	Analysis dependent on results of other models
Input data requirements	Definition of type of flow element Empirical constants for supply jet, plumes etc. Temperatures of supply air, room air, surfaces Source heat flux	Zone division Boundary conditions at walls Location of heat sources etc. Properties of flow elements etc.	Mesh layout Boundary conditions for velocity heat flux etc.	Properties of supply jet etc. for calculation of similarity conditions Boundary conditions for interior heat sources and wall surface temperature etc.	Room air distribution Location of contaminant source Location of supply and volume flow rate of fresh air
Output information	Velocity and temperature distribution for each flow element	Mean temperature, pressure and concentration for each zone	Velocity and temperature distribution for each cell Wall surface temperature when radiation simulation is coupled	Space distribution of velocity and temperature Number of measuring points is limited due to experimental load	Ventilation efficiency evaluation Concentration distribution
Advantages	Practice is very simple and fast	Practice is rather simple Analysis of time-dependent phenomena possible	Very detailed analysis possible Presentation using CG technique is powerful	Measurement of physical phenomena is basically reliable	
Disadvantages	Can not be applied where flow elements interact with each other	Prediction accuracy becomes lower when flow field is complicated	Grid design and input data require large human work load Large CPU time is required	High experimental load (time, money, work)	

ACKNOWLEDGEMENTS

This summary report is based on a part of the related Annex 26 report (Heiselberg et al. 1996), edited by Prof. Murakami and with contributions from the following authors:

Dr. Dario Aiulfi, Switzerland
Mr. Hassan Bouia, France
Dr. Gian Vincenzo Fracastoro, Italy
Dr. Per Heiselberg, Denmark
Dr. Kazuki Hibi, Japan
Dr. Christian Inard, France
Prof. Shinsuke Kato, Japan
Assoc. Prof. Yasushi Kondo, Japan
Dr. Hans Martin Mathisen, Norway
Prof. Stanislaw Mierzwinski, Poland
Prof. Shuzo Murakami, Japan
Dr. Shinichiro Nagano, Japan
Prof. Peter V. Nielsen, Denmark
Mr. Yoshiichi Ozeki, Japan
Ing. Marco Perino, Italy
Prof. Zbigniew Popiolek, Poland
Prof. Mats Sandberg, Sweden
Dr. Jacobus Van Der Maas, Switzerland
Mr. Shinji Yamamura, Japan
Mr. Mutsumi Yokoi, Japan

REFERENCES

Heiselberg, P.K.; Murakami, S.; Roulet, C.A. (editors). 1996. Ventilation of Large Spaces in Buildings, part 3 Analysis and Prediction Techniques. Final report of IEA-ECB&CS Annex 26.

Müller, D.; Vogel, N. (editors). 1996. Ventilation of Large Spaces in Buildings, part 2 Case Studies. Final report of IEA-ECB&CS Annex 26.

Waters, R.J. (editor). 1996. Ventilation of Large Spaces in Buildings, part 1 Design Guide. Final report of IEA-ECB&CS Annex 26.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 34: T. V. Jacobsen, P. V. Nielsen: *Numerical Modelling of Thermal Environment in a Displacement-Ventilated Room*. ISSN 0902-7513 R9337.

PAPER NO. 35: P. Heiselberg: *Draught Risk from Cold Vertical Surfaces*. ISSN 0902-7513 R9338.

PAPER NO. 36: P. V. Nielsen: *Model Experiments for the Determination of Airflow in Large Spaces*. ISSN 0902-7513 R9339.

PAPER NO. 37: K. Svidt: *Numerical Prediction of Buoyant Air Flow in Livestock Buildings*. ISSN 0902-7513 R9351.

PAPER NO. 38: K. Svidt: *Investigation of Inlet Boundary Conditions Numerical Prediction of Air Flow in Livestock Buildings*. ISSN 0902-7513 R9407.

PAPER NO. 39: C. E. Hyldgaard: *Humans as a Source of Heat and Air Pollution*. ISSN 0902-7513 R9414.

PAPER NO. 40: H. Brohus, P. V. Nielsen: *Contaminant Distribution around Persons in Rooms Ventilated by Displacement Ventilation*. ISSN 0902-7513 R9415.

PAPER NO. 41: P. V. Nielsen: *Air Distribution in Rooms - Research and Design Methods*. ISSN 0902-7513 R9416.

PAPER NO. 42: H. Overby: *Measurement and Calculation of Vertical Temperature Gradients in Rooms with Convective Flows*. ISSN 0902-7513 R9417.

PAPER NO. 43: H. Brohus, P. V. Nielsen: *Personal Exposure in a Ventilated Room with Concentration Gradients*. ISSN 0902-7513 R9424.

PAPER NO. 44: P. Heiselberg: *Interaction between Flow Elements in Large Enclosures*. ISSN 0902-7513 R9427.

PAPER NO. 45: P. V. Nielsen: *Prospects for Computational Fluid Dynamics in Room Air Contaminant Control*. ISSN 0902-7513 R9446.

PAPER NO. 46: P. Heiselberg, H. Overby, & E. Bjørn: *The Effect of Obstacles on the Boundary Layer Flow at a Vertical Surface*. ISSN 0902-7513 R9454.

PAPER NO. 47: U. Madsen, G. Aubertin, N. O. Breum, J. R. Fontaine & P. V. Nielsen: *Tracer Gas Technique versus a Control Box Method for Estimating Direct Capture Efficiency of Exhaust Systems*. ISSN 0902-7513 R9457.

PAPER NO. 48: Peter V. Nielsen: *Vertical Temperature Distribution in a Room with Displacement Ventilation*. ISSN 0902-7513 R9509.

PAPER NO. 49: Kjeld Svidt & Per Heiselberg: *CFD Calculations of the Air Flow along a Cold Vertical Wall with an Obstacle*. ISSN 0902-7513 R9510.

PAPER NO. 50: Gunnar P. Jensen & Peter V. Nielsen: *Transfer of Emission Test Data from Small Scale to Full Scale*. ISSN 1395-7953 R9537.

PAPER NO. 51: Peter V. Nielsen: *Healthy Buildings and Air Distribution in Rooms*. ISSN 1395-7953 R9538.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 52: Lars Davidson & Peter V. Nielsen: *Calculation of the Two-Dimensional Airflow in Facial Regions and Nasal Cavity using an Unstructured Finite Volume Solver*. ISSN 1395-7953 R9539.

PAPER NO. 53: Henrik Brohus & Peter V. Nielsen: *Personal Exposure to Contaminant Sources in a Uniform Velocity Field*. ISSN 1395-7953 R9540.

PAPER NO. 54: Erik Bjørn & Peter V. Nielsen: *Merging Thermal Plumes in the Indoor Environment*. ISSN 1395-7953 R9541.

PAPER NO. 55: K. Svidt, P. Heiselberg & O. J. Hendriksen: *Natural Ventilation in Atria - A Case Study*. ISSN 1395-7953 R9647.

PAPER NO. 56: K. Svidt & B. Bjerg: *Computer Prediction of Air Quality in Livestock Buildings*. ISSN 1395-7953 R9648.

PAPER NO. 57: J. R. Nielsen, P. V. Nielsen & K. Svidt: *Obstacles in the Occupied Zone of a Room with Mixing Ventilation*. ISSN 1395-7953 R9649.

PAPER NO. 58: C. Topp & P. Heiselberg: *Obstacles, an Energy-Efficient Method to Reduce Draught from Large Glazed Surfaces*. ISSN 1395-7953 R9650.

PAPER NO. 59: L. Davidson & P. V. Nielsen: *Large Eddy Simulations of the Flow in a Three-Dimensional Ventilated Room*. ISSN 1395-7953 R9651.

PAPER NO. 60: H. Brohus & P. V. Nielsen: *CFD Models of Persons Evaluated by Full-Scale Wind Channel Experiments*. ISSN 1395-7953 R9652.

PAPER NO. 61: H. Brohus, H. N. Knudsen, P. V. Nielsen, G. Clausen & P. O. Fanger: *Perceived Air Quality in a Displacement Ventilated Room*. ISSN 1395-7953 R9653.

PAPER NO. 62: P. Heiselberg, H. Overby & E. Bjørn: *Energy-Efficient Measures to Avoid Draught from Large Glazed Facades*. ISSN 1395-7953 R9654.

PAPER NO. 63: O. J. Hendriksen, C. E. Madsen, P. Heiselberg & K. Svidt: *Indoor Climate of Large Glazed Spaces*. ISSN 1395-7953 R9655.

PAPER NO. 64: P. Heiselberg: *Analysis and Prediction Techniques*. ISSN 1395-7953 R9656.

PAPER NO. 65: P. Heiselberg & P. V. Nielsen: *Flow Element Models*. ISSN 1395-7953 R9657.

PAPER NO. 66: Erik Bjørn & P. V. Nielsen: *Exposure due to Interacting Air Flows between Two Persons*. ISSN 1395-7953 R9658.

PAPER NO. 67: P. V. Nielsen: *Temperature Distribution in a Displacement Ventilated Room*. ISSN 1395-7953 R9659.

PAPER NO. 68: G. Zhang, J. C. Bennetsen, B. Bjerg & K. Svidt: *Analysis of Air Movement Measured in a Ventilated Enclosure*. ISSN 13995-7953 R9660.

**Department of Building Technology and Structural Engineering
Aalborg University, Sohngaardsholmsvej 57. DK 9000 Aalborg
Telephone: +45 9635 8080 Telefax: +45 9814 8243**

ued for early dis-
ogy Group at the
ic meetings, con-
Whenever possible
als, etc.) and not

INSTITUTTET FOR BYGNINGSTEKNIK
DEPT. OF BUILDING TECHNOLOGY AND STRUCTURAL ENGINEERING
AALBORG UNIVERSITET • AAU • AALBORG • DANMARK

INDOOR ENVIRONMENTAL TECHNOLOGY
PAPER NO. 64

Summary Report at ROOMVENT '96 Workshop: Outcome of IEA Annex 26
"Energy Efficient Ventilation of Large Enclosures", Yokohama, Japan, July
1996, pp. 4-11

P. HEISELBERG
ANALYSIS AND PREDICTION TECHNIQUES
DECEMBER 1996

ISSN 1395-7953 R9656

The papers on INDOOR ENVIRONMENTAL TECHNOLOGY are intended for dissemination of research results from the Indoor Environmental Technology Group at Aalborg University of Aalborg. These papers are generally submitted to scientific conferences or journals and should therefore not be widely distributed. Reference should be given to the final publications (proceedings, journals, etc.) to the paper in this series.

Printed at Aalborg University

be maintained and to adjust the model so air flow pattern visualisation and field measurements of parameters can be carried out in a convenient way. The errors of the approximate modelling method will be smaller and the test results more reliable the closer model size and flow parameter values are related to those in the full scale object. It is advisable to divide the problems investigated into those which require precise quantitative analysis with the use of partial modelling methods and those for which qualitative observations in small models, but of the whole object, may be sufficient.

Ventilation Efficiency

Ventilation efficiency is constituted of a number of concepts that reflect various aspects of the ventilation performance during both stationary and transient conditions, and comprises the performance both locally and globally. These concepts are based on actual concentrations, temperatures etc. Therefore, there is not any particular ventilation efficiency model because any model, physical model or computational model, that provides information about the actual variables can be used to assess the ventilation performance. The reliability of the assessment of the ventilation performance is therefore totally dependent on the reliability of the model providing information about the state in the ventilated space.

The connection between energy efficiency and ventilation efficiency is that an efficient system with respect to e.g. contaminant control, requires a smaller air flow rate to meet the design conditions in the occupied space of the enclosure and, thereby, a reduced need of energy for the transport of air. An efficient system may also require a smaller plant than usually. With respect to temperature control an efficient system requires a smaller temperature difference between the supply and the conditions in the occupied space than a less efficient system and, subsequently, less energy is required to meet the specified requirements.

To create an efficient ventilation in large enclosures the fact that the occupied zone is much smaller than the total volume of the enclosure is used. Therefore, to create uniform conditions within the whole space by using mechanical ventilation will not be energy efficient. Instead one should strive to create non-uniform conditions and to use the non-occupied part of the building as a storage for heat

and contaminant. If this can be done, depends on the possibility of "isolating" the occupied space from the remaining part of the building. In isolation of different parts from each other the properties of stratified flow can be used.

One general prerequisite of energy efficient ventilation is source control. This has not only implications for the plant size, but also because the smaller the load the easier efficient ventilation can be obtained. Source control of heat is particular important because there is always a transport of heat by exchange of radiation between surfaces that can "see" one another, which means that it is not possible to obstruct transfer of heat between different zones.

CONCLUSION

In large enclosures common ventilation strategies, like complete mixing, require considerable amounts of energy to move and condition enormous amounts of air. The air flow pattern should therefore be well planned and controlled to ensure an acceptable indoor air quality in the occupied zone without the need for excessive air flow rates.

This part of the summary report has summarised the use of various models for predictions and analysis of ventilation and indoor climate in large enclosures. The models provide various information, and the contents of the information given from the models as well as the degree of prediction accuracy of the models differ for each model. At the first stages of the design process information is rather limited and approximate HVAC solutions are developed based on engineering experience and use of appropriately simple analytical tools (macroscopic models) to save design work. At the latter stages of the design process more information is available and more detailed analytical tools (microscopic models) can be applied to evaluate the proposed air flow design.

The performance of these models is reviewed from this point of view and given in Table 2 together with comparisons of advantages and disadvantages. Table 2 gives the designers and the HVAC engineers an easy and strategic procedure for designing ventilation and air conditioning by choosing adequate models at each design stage.

conditions, while it can be difficult to apply them and get good results in cases that differ.

The greatest assets of the models are the fact that they are relatively easy to use, they require only a few input parameters, they are not very time-consuming and they do not demand any investments of importance. To use the models in a particular case it is necessary to define the geometrical and physical conditions, to find the appropriate model, to estimate the input parameters and to calculate the results using a pocket calculator or a spreadsheet program. At the same time this is the greatest disadvantage of the models. Many of the models are only applicable under certain conditions, and together with the limited requirements to the input parameters, the results will not give very detailed information about the air flow conditions but only the level of a few key parameters of the flow.

Conventionally sized enclosures have often simple geometrical and physical conditions and the air flow pattern is often dominated by a single flow element or by flow elements which are not interacting with each other. Consequently an analysis of the air flow conditions by the flow element models will be sufficient in the design of the air distribution system.

Large enclosures have often very complicated geometrical shapes and physical conditions, and the air flow will often consist of several flow elements occurring at the same time. The flow elements will only dominate the air flow conditions in relatively small parts of the enclosure, and the flow path will often be influenced by other flow elements. In such cases the flow element models will only be useful at the first stages of the design process to keep design costs down and, eventually, to estimate the air flow conditions in specific areas of the enclosure. More detailed analytical tools (field models) will be necessary to estimate the air flow and temperature conditions in the enclosure as a whole. However, the results from the flow element models will still be very useful as input and comparison.

Engineering Models

Engineering models are macroscopic models ranging from very simple calculation methods to elaborate models describing very complex problems. They include in the Annex 26 work models for natural ventilation in buildings, zonal models and building thermal dynamic models.

Natural ventilation occurs due to pressure differences between the inside and the outside caused by thermal buoyancy and wind, and the

general aspects are described by models derived from the Bernoulli equation. The pressure distribution over the building envelope estimated from geometry, wind characteristics and temperature differences between the inside and the outside combined with the air leakage characteristics determines the induced ventilation rates. The results are velocities and flow rates in the openings. The large enclosure is essentially treated as a single zone with temperature stratification. The uncertainties in the model are closely related to the input parameters such as wind pressure coefficients and air leakage characteristics.

The main principle of zonal models is to split the indoor air volume into several macro-volumes, to write the mass- and energy balances and to compute mean values for temperatures, pressures and concentrations for each macrovolume. The main problem in zonal models is to evaluate the air flows (and to a less extent the heat fluxes) between the macrovolumes. A zonal model with a large application field and a good accuracy has been established by using specific laws for flow elements in volumes where they occur, and by linking air mass flows between zones with a pressure difference in other zones. The advantages of the zonal model are that it covers the whole flow field, that it, in principle, is rather simple and that analysis of time dependent phenomena is possible. However, detailed distribution of parameters can not be predicted, and prediction accuracy becomes lower when the flow field is complicated.

Air flow in large enclosures strongly depends on boundary conditions at surfaces which limit the space such as temperatures and heat fluxes. To calculate these often time dependent parameters building thermal dynamic models are used. Commercially available programs are developed with the purpose of simulating building and system performance. Often the models do not include sufficiently detailed descriptions of enclosure geometry, solar radiation and coupled internal convection and radiation exchange to make the results directly usable in detailed flow field analysis. Various approaches have been used in the Annex 26 work to solve this problem.

Field Models

CFD programs are described as field models or microscopic models, as they predict velocity, temperature and other flow properties throughout a whole space with a high degree of resolution. Micro simulation is based on the conservation laws of mass, energy and momentum, collectively called the governing equations for fluid flow, and it uses far smaller cells than macromodels.

closures, the occupied zone is relatively small. In large enclosures some designs suffer both from over-sizing of equipment and from excessive energy requirements, which are usually caused by the lack of knowledge and guidance at the design stage.

The objectives of Annex 26 were to increase the understanding of the physics of air motion, thermal stratification, and contaminant spread in large enclosures, and to develop methods to minimise within large enclosures energy consumption in the provision of: 1) good indoor air quality and comfort, 2) the save removal of airborne contaminants and 3) the satisfactory distribution of fresh air.

Annex 26 concentrated on analysing the response of the air mass in large spaces to thermal and other inputs from the building and the environment, and it aimed at reducing energy consumption by ventilation. The air flow is particularly important. Firstly, it provides a mechanism for relatively large scale energy transfer processes and, secondly, it has a strong relevance to thermal comfort, removal of airborne contaminants and provision of fresh air at the breathing level, which are of prime importance to comfort and productivity of the occupants.

The Annex addressed problems that are related to the elements of the design procedure for a real building: 1) design, 2) construction, 3) commissioning and 4) troubleshooting. Methods to solve these problems were developed including both development of measuring techniques for field measurements in large enclosures, development of design and analysis methods for air flow and ventilation, and increment of the understanding of the air motion by measurements in a number of case studies.

This part of the summary report concentrates on describing methods for designing and analysing ventilation in large enclosures. It includes application of different mathematical models in the design process for simulation of thermal dynamics of building components, temperature distribution, air motion and contaminant spread in order to evaluate performance and locate problems. The developed measurement techniques and the application of both measurement and modelling techniques on specific case studies are reported in other parts.

ANALYSIS AND PREDICTION TECHNIQUES FOR LARGE ENCLOSURES

Techniques for design and analysis of ventilation can be categorised in two main groups according to the level of modelling detail. The first group is macroscopic models, which are simplified models for a first estimate and design development, such as flow element models, engineering models and zonal models. The second group is microscopic models, which are detailed models for design evaluation and troubleshooting, such as computational fluid dynamics (CFD) and scale model experiments. Add to this the ventilation efficiency model, which is strictly a method to evaluate the ventilation performance based on the results of the macro- or microscopic models or measurements in the actual building.

The different stages involved in the design process of a large enclosure can be divided into initial design phase, building design phase, ventilation design phase, ventilation design evaluation and troubleshooting, construction phase and commissioning (Waters, 1996).

At the first stages of the design process, when the architectural form of the building and the quality of the indoor environment are roughly sketched, information is rather limited. Consequently only approximate HVAC solutions are developed based on engineering experience (such as data on existing similar buildings) and use of appropriately simple analytical tools (macroscopic models) to save design work. However, for critical or unconventional spaces suitable previous experience or engineering methods may not be available. In such cases more elaborate tools (microscopic models) may be used earlier in the design process, but only for a coarse analysis to qualitatively evaluate different design options.

At the latter stages of the design process, where the HVAC and the architectural design are more highly developed and more information is available, more detailed analytical tools (microscopic models) can be applied to evaluate whether the proposed air flow design will work as intended, or there are problems with local thermal discomfort, low IAQ, condensation etc. The performance of the ventilation system can be evaluated by a ventilation efficiency model. If the design criteria are not fulfilled the models can be used for further troubleshooting and design improvement. However, for conventionally sized enclosures such detailed analysis is rarely necessary, as ventilation techniques for such enclosures are well established