

Air Infiltration and Ventilation Centre
University of Warwick Science Park
Barclays Venture Centre
Sir William Lyons Road
Coventry CV4 7EZ
Great Britain
Telephone: (0203) 692050
Telex: 312401
Fax: (0203) 410156


861

PB80-213986

Simplified Heating and Cooling Energy Analysis
Calculations for Residential Applications

(U.S.) National Bureau of Standards
Washington, DC National Engineering Lab.

Jul 80



U.S. Department of Commerce
National Technical Information Service

NTIS

NBSIR 80-1961

Simplified Heating and Cooling Energy Analysis Calculations for Residential Applications

Tamami Kusuda
T. Saitoh

National Bureau of Standards
National Engineering Laboratory
Center for Building Technology
U.S. Department of Commerce
Washington, DC 20234

July 1980



U.S. DEPARTMENT OF COMMERCE

NATIONAL BUREAU OF STANDARDS

REPRODUCED BY
**NATIONAL TECHNICAL
INFORMATION SERVICE**
U. S. DEPARTMENT OF COMMERCE
SPRINGFIELD, VA. 22161

U.S. DEPT. OF COMM. BIBLIOGRAPHIC DATA SHEET	1. PUBLICATION OR REPORT NO. NBSIR 80-1961	2. Gov't Accession No.	3. Recipient's Accession No. PB 80 213986
4. TITLE AND SUBTITLE SIMPLIFIED HEATING AND COOLING ENERGY ANALYSIS CALCULATIONS FOR RESIDENTIAL APPLICATIONS		5. Publication Date July 1980	
7. AUTHOR(S) Tamami Kusuda and T. Saitoh		6. Performing Organization Code 742.01	
9. PERFORMING ORGANIZATION NAME AND ADDRESS NATIONAL BUREAU OF STANDARDS DEPARTMENT OF COMMERCE WASHINGTON, DC 20234		8. Performing Organ. Report No. NBSIR 80-1961	
12. SPONSORING ORGANIZATION NAME AND COMPLETE ADDRESS (Street, City, State, ZIP)		10. Project/Task/Work Unit No. 742 9504	
15. SUPPLEMENTARY NOTES ☐ Document describes a computer program; SF-185, FIPS Software Summary, is attached.		11. Contract/Grant No.	
16. ABSTRACT (A 200-word or less factual summary of most significant information. If document includes a significant bibliography or literature survey, mention it here.) In order to shorten the lengthy computational labor and cost common to most existing hourly simulation computer programs, a simplified energy calculation procedure was developed for the evaluation of energy conservation effectiveness of home retrofitting. The procedure utilizes monthly normal weather parameters such as temperature, humidity, wind data, and solar radiation, in lieu of the traditional degree-day procedure. The thermal time constant was used to account for the effect of building thermal mass on seasonal heat transfer performance. In addition to standard retrofit procedures such as addition of thermal insulation, use of storm windows, and sealing of cracks, included in the procedure are the energy conservation effects due to the use of solar collectors, hot water tank insulation, and insulation around the heat distribution systems such as ducts and pipes.		13. Type of Report & Period Covered	
		14. Sponsoring Agency Code	
17. KEY WORDS (six to twelve entries; alphabetical order; capitalize only the first letter of the first key word unless a proper name; separated by semicolons) Energy analysis calculation; energy retrofit; home audit; thermal time constant.			
18. AVAILABILITY ☒ Unlimited ☐ For Official Distribution. Do Not Release to NTIS ☐ Order From Sup. of Doc., U.S. Government Printing Office, Washington, DC 20462, SD Stock No. SN003-003- ☒ Order From National Technical Information Service (NTIS), Springfield, VA, 22161		19. SECURITY CLASS (THIS REPORT) UNCLASSIFIED	21. NO. OF PRINTED PAGES
		20. SECURITY CLASS (THIS PAGE) UNCLASSIFIED	22. Price

NBSIR 80-1961

**SIMPLIFIED HEATING AND COOLING
ENERGY ANALYSIS CALCULATIONS FOR
RESIDENTIAL APPLICATIONS**

Tamami Kusuda
T. Saitoh

National Bureau of Standards
National Engineering Laboratory
Center for Building Technology
U.S. Department of Commerce
Washington, DC 20234

July 1980



U.S. DEPARTMENT OF COMMERCE, Philip M. Klutznick, *Secretary*
Luther H. Hodges, Jr., *Deputy Secretary*
Jordan J. Baruch, *Assistant Secretary for Productivity, Technology, and Innovation*
NATIONAL BUREAU OF STANDARDS, Ernest Ambler, *Director*

Simplified Heating and Cooling Energy Analysis
Calculation for Residential Applications

T. Kusuda and T. Saitoh*
Center for Building Technology
National Engineering Laboratory
National Bureau of Standards
Washington, D.C. 20234

ABSTRACT

In order to reduce the lengthy computational labor and costs common to most existing hourly simulation computer programs, a simplified energy calculation procedure suitable for a handheld calculator was developed for the evaluation of home retrofitting with respect to energy conservation. The procedure utilizes monthly normal weather parameters such as temperature, humidity, wind data, and solar radiation, in lieu of the traditional degree-day procedure.

The thermal time constant was used to account for the effect of building thermal mass on seasonal heat transfer performance. In addition to standard retrofit procedures such as addition of thermal insulation, use of storm windows, and sealing of cracks, this calculation includes energy conservation effect due to the use of solar collectors, hot water tank insulation, and insulation around the heat distribution systems such as ducts and pipes.

Also included are comparative annual heating and cooling requirements determined by the simplified procedure and that calculated by the DOE-2 computer program for a typical residence.

Keywords: Energy analysis calculation; energy retrofit; home audit; thermal time constant.

* Guest worker from Ohbayashi-Gumi, Tokyo, Japan.

TABLE OF CONTENTS

	<u>Page</u>
ABSTRACT	111
1. INTRODUCTION	1
2. OVERALL ALGORITHMIC STRUCTURE	1
3. THERMAL TIME CONSTANT, THTC	4
4. ENVELOPE DATA	4
4.1 Type Designation	4
4.2 Area, A	4
4.3 Overall Heat Transfer Coefficient U	4
4.4 Solar Absorptivity, ABS	6
4.5 Shadow Factors, SHDW	6
4.6 Shading Coefficient, SC	6
4.7 Wall Orientation, WAZ	6
4.8 Wall Tilt Angle, WTLT	6
5. SUBROUTINE ALGORITHMS	6
5.1 SOLDAT	6
5.2 SAT	7
5.3 INFIL	8
5.4 ATTIC	9
5.5 CRAWL	9
5.6 GF	10
5.7 QG	13
5.8 HLHG	14
5.9 HRCT	17
5.10 EREQ	17
5.11 SEU	18
5.12 QI	19
5.13 QECHG	20
5.14 QR	20
5.15 DBRH	21
5.16 BSMT	21
5.17 HWHREQ	23
5.18 CSDUPI	24
5.19 ASDUPI	24
5.20 BMDUPI	25
5.21 OSDUPI	26
6. COMPARISON WITH DOE-2 RUNS	27
APPENDIX A: LIU-JORDAN SOLAR CALCULATION DATA	A-1
APPENDIX B: AVERAGE EARTH TEMPERATURE FOR UNDERGROUND HEAT DISTRIBUTION SYSTEM	B-1
APPENDIX C: FORTRAN LISTING OF THE COMPUTER PROGRAM	C-1
APPENDIX D: ELEMENTS OF DATA STATEMENT IN MAIN PROGRAM	D-1
APPENDIX E: THERMAL TIME CONSTANT AND ITS APPLICATION	E-1

REFERENCES

1. INTRODUCTION

The purpose of this report is to describe detailed algorithm, data base and Fortran listing of a simplified home energy analysis procedure suitable for small computer or pocket calculator. This simplified procedure was originally developed for DOE to assist the state and local government energy officials who are making economic benefit analyses of various home improvement options, such as insulation, storm windows, hot water tank insulation, insulation around pipes and ducts, etc.

The procedure calculates the annual energy requirement calculations for heating and cooling of single-family residences in conjunction with the Department of Energy Project Home Energy Audit questionnaire and economic analysis. Since the Project Home Energy Audit Program mandated that the computation time, equivalent to the UNIVAC 1100 CPU (Central Processing Unit) time, is to be within 3 seconds, it precluded the comprehensive hourly simulation procedures such as used in BLAST, DOE-2, and NBSLD.

A scheme adopted in the DoE Home Energy Audit calculation procedure is to develop a simplified yet relatively comprehensive heating and cooling load calculation routine where most of the major building heat transfer elements are addressed in an approximate manner. The results of the calculation obtained by this simplified routine are then compared against those obtained from a DOE-2, ² the comprehensive hourly simulation computer program designated as the Standard Evaluation Technique for Building Energy Performance Standards, for a ranch house.

2. OVERALL ALGORITHMIC STRUCTURE

The flow chart for the simplified procedure is shown in Figure 1, and detailed algorithms, including Fortran listing, for each of the subroutines are given in the following sections.

The basic scheme of the calculation is to determine monthly normal values of daytime and nighttime heat gains (heat loss will be considered a negative heat gain) separately for all of the major heat exchange components, and to integrate them into monthly normal daytime and nighttime heating and cooling requirements.

In Figure 1, all of the major heat gain (loss) through various elements of building envelope is denoted with symbols ending with D and N, indicating daytime heat gain and nighttime heat gain, respectively.

Although not described in detail in this report, a special subroutine, SOLDAT, was developed to generate daily total solar radiation data for the normal day for each of 12 months for any given orientation and tilt angle of the wall in a given locality, while a separate routine called SAT determines the normal daily average sol-air temperature to be applicable for the calculation of heat gain through walls, roofs, and doors. Detailed documentation for SOLDAT can be found in reference 2.

NBS HOME ENERGY AUDIT CALCULATION




Figure 1. Flow chart of the Heating and Cooling Load Program

Where the roof has ventilated attic space, the program determines the attic space temperature based upon heat balance, which is in turn used to determine the heat gain through the ceiling.

The SOLDAT routine will also provide the solar radiation data for the solar collectors, which may be available in some of the energy conservation designs. The solar collector performance will be simulated by a simplified linear relationship between the collector efficiency and $\Delta T/I$, where ΔT represents the average temperature difference between the outdoor air and collector inlet fluid temperatures, while I represents the daily average of hourly solar insolation.

Heat gain from the floors is determined by the use of special algorithms to simulate the heat transfer process of basement, slab-on-grade, and crawl space under the floor, respectively.

In addition, there are several other subroutines in the calculation, such as INFIL to determine the air leakage rate, DBRH to determine the moist air properties, and subroutines to determine the energy loss from hot water tanks, ducts and pipes.

The major distinction of the present method from the existing degree-day or bin procedures is that the new method is based upon the monthly normal day data for each of the 12 months of the year. The monthly normal data needed are:

- daytime average temperature
- nighttime average temperature
- total solar radiation upon horizontal surface
- average relative humidity (morning and afternoon)
- average wind speed
- ground temperature

for the normal days of the month.

Fortunately, these data are available in the existing literature for most of the major Weather Bureau stations throughout the United States. The Liu and Jordan paper, entitled, "Availability of Solar Energy for Flat-Plate Solar Collectors," ASHRAE Symposium on Low Temperature Engineering Applications of Solar Energy, 1967, provides the average daytime temperature and the solar radiation data for more than 80 stations in the United States (see Appendix A). A U.S. Weather Bureau publication called "Comparative Climatic Data Through 1976"* provides the long-period (30 years or more) normals and extremes of monthly average temperature, precipitation, relative humidity, and wind data.

Ground temperature data, previously developed by Kusuda and Achenbach, shown in Appendix B, are also employed for the heat transfer calculation for slab-on-grade floor, basement walls and basement floor.

* For sale by the National Climatic Center, Federal Bldg., Asheville, N.C., 28801 (Tel. 704-258-2850, X 683). \$1.50 copy.

4.4. SOLAR ABSORPTIVITY, ABS

These data are used to determine the outside surface temperature of exterior walls as influenced by the solar radiation data. Typical values are:

for very dark surface	0.95
medium dark surface	0.7
light surface	0.4

4.5. SHADOW FACTORS, SHDW

This factor indicates how much of the exterior surface is shaded from direct sun by adjacent buildings, exterior shading devices, or by trees. Typical figures are:

if completely shaded	1.0
if partially shaded	0.5
if not shaded at all	0.

4.6. SHADING COEFFICIENT, SC

This factor relates to the internal shading devices used for the windows. Typical values for a single glaze window are:

for venetian blinds	0.5
roller shades	0.4
tinted films	0.3.

4.7. WALL ORIENTATION, WAZ

These data indicate the orientation of walls and windows, measured clockwise from the south. Thus, for example,

WAZ =	0 for south-facing wall/window/door
WAZ =	90 for west
WAZ =	180 for north
WAZ =	270 for east.

4.8. WALL TILT ANGLE, WTLT

These data are for the slant angle of the walls or windows. For most construction, the value is 90° for walls and windows and 0° for roofs. For solar collectors, the actual tilt angle will be used and will usually be an angle other than 0° or 90°.

5. SUBROUTINE ALGORITHMS

5.1. SOLDAT

Using the Liu/Jordan method ^{2/}, this program generates 12 monthly values of total solar radiation over the roofs, floors, walls, windows, and solar

collectors. The details of the calculation procedure are given in NBS Building Sciences Series 96 entitled "Hourly Solar Radiation Data for Vertical and Horizontal Surfaces on Average Days in the United States and Canada." This routine also includes the shadow effect of the roof overhang upon the direct radiation incident on a given vertical surface.

Input: XLAT = latitude, degree
 WAZ = wall azimuth angle, degrees from south
 WTLT = wall tilt angle, degree from horizontal surface
 ZKT = Liu/Jordan constants
 H = daily normal solar radiation over a horizontal surface Btu/ft²
 RHO = ground reflectance
 TOWN = zip code
 OVHANG = roof overhang, ft
 WALLHT = wall height, ft

Output: XIDT = daily total solar radiation, Btu/hr ft²
 XIDD = daily total diffuse sky radiation, Btu/hr ft²
 HRDAY = daytime hours, hr
 HRNIT = nighttime hours, hr

5.2. SAT

Sol-air temperature routine

Input: WTLT = tilt angle, degrees from horizontal surface
 It = incident total solar insolation, Btu/day ft²
 Id = incident sky radiation, Btu/day ft²
 SHDW = shadow factor
 0 = no shadow
 0.5 = partial shadow
 1.0 = complete shadow
 AB = surface absorptivity
 FO = surface heat transfer coefficient, Btu/h ft² °F
 = 4 for J,J,A
 = 5 for M,A,M,S,O,N
 = 6 for D,J,F
 TOD = daytime temperature, °F
 TON = nighttime temperature, °F
 HRDAY = daytime hours, hr

Total radiation incident upon a surface

$$I = (It - Id) * (1 - SHDW) + Id$$

Output: Sol-air temperature

$$\text{Daytime SATD} = TOD + \frac{AB * I}{HRDAY * FO} \frac{10^{-1}}{FO * \cos(WTLT)}$$

$$\text{Nighttime SATN} = \text{TON} - \frac{10^{\ast/}}{\text{FO}} \ast \cos(\text{WTLT})$$

5.3. INFIL

Infiltration calculation, cfm

Input: V = volume of the room, ft³
 ACHS = standard air change data, air change/hr
 TO = outdoor temperature, °F = (TOD + TON)/2
 TI = indoor temperature, °F = (TID + TIN)/2
 WS = wind speed, mph

$$\text{AC (air leakage rate)} = (\text{ACHS}/0.695) \ast [0.15 + 0.013 \ast \text{WS} + 0.005 \ast \text{ABS}(\text{TO}-\text{TI})]^{\pm/}$$

Standard Air Leakage Data (ACHS)

In lieu of the crack method, hourly air-change values are to be provided because there are more experimentally measured data reported by the use of He and SF₆ tracer gas dilution technique. Recommended values are as follows:

Living space: 1.5 for leaky building
 1.0 for standard building
 0.5 for modern-type building

Attic space: mechanical ventilation 20 Ac/hr
 natural ventilation 6 Ac/hr

Crawl space: 3 Ac/hr

Output: Air leakage rate

$$\text{RINFIL} = (\text{V}) \ast \frac{\text{AC}}{60}, \text{ ft}^3/\text{m} (\text{cfm})$$

^{\ast/} Assumed average sky heat loss: 10 Btu/hr, ft².

^{\pm/} Modified Achenbach/Coblentz equation.
 "Field Measurements of Air Infiltration in Ten Electrically Heated Houses" ASHRAE Trans. 69, 1963, pp. 358-365.
 DoE - 2 program uses, however, different equations such as
 AC = 0.252 + 0.0218 * WS + 0.0084 * ABS (TO-TS)

5.4. ATTIC

Attic temperature calculation

Input:

AR = roof area, ft²
TRD = daytime roof sol-air temperature, °F
TRN = nighttime roof sol-air temperature, °F
AC = ceiling area, ft²
TAD = daytime room temperature, °F
TAN = nighttime room temperature, °F
AW = end wall area, ft²
TWD = daytime end wall sol-air temperature, °F (average of two end walls)
TWN = nighttime end wall sol-air temperature, °F
CFM = air flow, ft³/min
UR, UC, UW = U-value for roof, ceiling and end walls, Btu/h ft² °F
TOD = daytime outdoor air temperature, °F
TON = nighttime outdoor air temperature, °F

Output: Attic temperature (daytime and nighttime)

$$ATTICD = \frac{UR*AR*TRD + UW*AW*TWD + UC*AC*TAD + 1.08*CFM*TOD}{UR*AR + UW*AW + UC*AC + 1.08*CFM}$$

$$ATTICN = \frac{UR*AR*TRN + UW*AW*TWN + UC*AC*TAN + 1.08*CFM*TON}{UR*AR + UW*AW + UC*AC + 1.08*CFM}$$

ATTICD = TID if attic temperature is controlled
ATTICN = TIN

5.5. CRAWL

Crawl space temperature routine

Input: Daytime and nighttime crawl space temperatures

TOD = daytime outdoor temperature, °F
TON = nighttime outdoor temperature, °F
TG = ground temperature, °F
TAD = daytime room temperature, °F
TAN = nighttime room temperature, °F
TWD = daytime wall sol-air temperature, °F
TWN = nighttime wall sol-air temperature, °F
CFM = air flow rate, ft³/min
UF = floor heat transfer coefficient, Btu/h ft² °F
UW = wall heat transfer coefficient, Btu/hr ft² °F
UG = ground surface heat transfer coefficient = 0.1, Btu/h ft² °F

AW = crawl space wall area, ft²
 AF = floor area, ft²

Output:

$$\text{CRAWLN} = \frac{\text{UF} \cdot \text{TAD} \cdot \text{AF} + \text{UW} \cdot \text{TWD} \cdot \text{AW} + \text{UG} \cdot (\text{TG} + \text{TOD}) \cdot \text{AF} / 2 + 1.08 \cdot \text{CFM} \cdot \text{TOD}}{\text{UF} \cdot \text{AF} + \text{UW} \cdot \text{AW} + \text{UG} \cdot \text{AF} + 1.08 \cdot \text{CFM}}$$

$$\text{CRAWLN} = \frac{\text{UF} \cdot \text{TAN} \cdot \text{AF} + \text{UW} \cdot \text{TWN} \cdot \text{AW} + \text{UG} \cdot (\text{TG} + \text{TON}) \cdot \text{AF} / 2 + 1.08 \cdot \text{CFM} \cdot \text{TON}}{\text{UF} \cdot \text{AF} + \text{UW} \cdot \text{AW} + \text{UG} \cdot \text{AF} + 1.08 \cdot \text{CFM}}$$

5.6. GF

Ground floor heat transfer routine (slab-on-grade floor)

Input:

AF = floor area, ft²
 P = exposed perimeter length, ft
 WT = wall thickness, ft
 TAD = daytime room temperature, °F
 TAN = nighttime room temperature, °F
 TOD = daytime outdoor temperature, °F
 TON = nighttime outdoor temperature, °F
 R = Thermal resistance of hour layers, which is between the room air and the floor slab-ground interface,
 ZK = Ground thermal conductivity Btu-in/h ft² °F

Calculation Procedure

The slab-on-grade heat transfer calculation presented herein is based upon an exact solution of Muncey and Spencer^{3/}.

The Base Ground Thermal Resistance RS shown in Fig. 3 was precalculated for a square slab of 40 ft x 40 ft over a ground of thermal conductivity 12 Btu-in/h ft² °F.

In order to correct the value of RS for the specific slab under consideration, which would be different from the basic structure, the three correction factors α, β and FS are needed.

The Perimeter length correction factor

$$\alpha = P/160$$


The Conductivity correction factor

$$\beta = ZK/12$$

The slab shape correction factor FS can be determined from Fig. 4 by knowing $\text{AF} / \frac{P^2}{4}$

Figure 3. Thermal resistance of slab-on-grade floor.

11






Figure 4. Shape correction factor for the slab-on-grade floor.

Calculation

$$R_F = \frac{\beta}{(\alpha * UF)}: \text{adjusted floor resistance}$$

$$E = \frac{WT}{\alpha} \quad \text{adjusted wall thickness}$$

Read from Figure 2 the value of RS corresponding to these RF and E data.

Ground Thermal Resistance:

$$R_G = \frac{\alpha}{\beta} * RS * PS$$

Overall heat transfer coefficient of the slab-on-grade floor:

$$UF = \frac{1}{(R_G + R)}$$

Heat loss through the slab-on-grade floor:

$$\text{daytime: } QFD = UF * AF * (TAD - TO)$$

$$\text{nighttimes: } QFN = UF * AF * (TAN - TO)$$

$$\text{where } TO = \frac{TOD + TON}{2}$$

5.7. QG

Window heat gain routine

Input:

AG = glass area, ft²
SC = shading coefficient
UG = heat transfer coefficient, Btu/h ft² °F
TOD = daytime outdoor temperature, °F
TON = nighttime outdoor temperature, °F
TID = daytime indoor temperature, °F
TIN = nighttime indoor temperature, °F
SHDW = external shadow factor

0. = no shadow
0.5 = partial shadow
1.0 = complete shadow

It = total incident solar radiation, Btu/day ft²
Id = diffuse sky radiation, Btu/day, ft²
HRDAY = daytime hours, hr
HRNIT = nighttime hours, hr

Output: Daytime and nighttime window heat gain

$$I = (I_t - I_d) * (1 - SHDW) + I_d$$

$$\text{Daytime} \quad QGD = AG * [I * (SC) * 0.87 + UG * (TOD - TID) * HRDY]$$

$$\text{Nighttime} \quad QGN = AG * [UG * (TON - TIN) * HRNIT]$$

5.8. HLHG

Heat loss and heat gain calculations

Input:

QID = daytime infiltration heat gain, Btu/day
QIN = nighttime infiltration heat gain, Btu/day
QWD = daytime wall heat gain, Btu/day
QWN = nighttime wall heat gain, Btu/day
QDD = daytime door heat gain, Btu/day
QDN = nighttime door heat gain, Btu/day
QCD = daytime ceiling heat gain, Btu/day
QCN = nighttime ceiling heat gain, Btu/day
QGD = daytime window heat gain, Btu/day
QGN = nighttime window heat gain, Btu/day
QFD = daytime floor heat gain, Btu/day
QFN = nighttime floor heat gain, Btu/day
QRD = daytime internal heat gain, Btu/day
QRN = nighttime internal heat gain, Btu/day

The above values will be negative if they are heat loss.

THTC = thermal time constant, hr
SGD = daytime solar heat gain through windows, Btu/day
CFM = air leakage, cu ft/min
 U_i ($i = 1, 2, \dots, N$) = overall heat transfer coefficient of each of the building envelope elements, Btu/h ft² °F
 A_i ($i = 1, 2, \dots, N$) = area of each of the building envelope elements, ft²
N = total number of building envelope elements
IACNV = natural ventilation index: = 1 if open windows in summer when outdoor temp. < thermostat setting.
= 0 if never open windows.
PUH = pick-up time or pull-down time (see Appendix E)
HRDAY = daytime hours, hr
HRNIT = nighttime hours, hr

Output:

HLD = daytime sensible heating load, Btu/day
HLN = nighttime sensible heating load, Btu/day
CLD = daytime sensible cooling load, Btu/day
CLN = nighttime sensible cooling load, Btu/day

Calculation Procedure

This routine uses the building thermal time constant (THTC) concept, detail of which is given in the Appendix E.

Total envelope heat gain

daytime

$$QTD = QID + QWD + QDD + QGD + QFD + QRD + QCD$$

nighttime

$$QTN = QIN + QWN + QDN + QGN + QFN + QRN + QCN$$

If TID = TIN

$$HLD = QTD \text{ if } QTD < 0$$

$$HLN = QTN \text{ if } QTN < 0$$

$$CLD = QTD \text{ if } QTD > 0$$

$$CLN = QTN \text{ if } QTN > 0$$

otherwise the following calculations are necessary

Envelope heat transfer factor

$$ZK = \frac{N}{1 + 1.08 \cdot CFM} \sum_{i=1}^N U_i A_i$$

also let

$$ZX = \exp\left(\frac{-PUH}{THTC}\right)$$

$$ZY = \exp\left(\frac{-12+PUH}{THTC}\right)$$

Cooling season calculations: (QTD > 0 and QTN > 0)

PULDWN: Evening pull-down cooling requirement necessary to lower the building temperature from TID of daytime to TIN of nighttime within a specified pickup period of PUH hours.

$$PULDWN = ZK \cdot \left(TON - TID + \frac{(TID - TIN)}{1 - ZX} \right) \cdot PUH$$

DH = duration of morning warm-up hour during which the cooling is off

$$DH = THTC * \ln \left(\frac{ZQ - TIN + TOD + TD}{ZQ - TID + TOD} \right)$$

$$\text{where } ZQ = \frac{SGD + QRD}{HRDAY * ZK}$$

CON: total daytime cooling hour

$$CON = HRDAY - DH$$

daytime cooling load

$$QTD = QTD * CON / 12$$

QTN: actual nighttime cooling requirement

$$CLN = \frac{QTN * (HRNIT - PUH)}{HRNIT} + PULDOWN * PUH$$

If the natural cooling is used as

if IACNV=1, CLD=0 for TOD ≤ TID

CLN=0 for TON ≤ TIN

Heating season calculations: (QTD<0 and QTN<0)

PICKUP: early morning pick-up heating requirement necessary to raise the building temperatures from TIN to TID within PUH hours

$$PICKUP = ZK * \left((TIN - TOD) + \frac{(TID - TIN)}{1 - ZK} \right) * PUH$$

DH: duration of evening cool-down hours during which the heating system is off

$$DH = THTC * \ln \left(\frac{TID + TD - TON - ZQ}{TIN - TON - ZQ} \right)$$

$$\text{when } ZQ = \frac{QRN}{ZK * HRNIT}$$

CON: total heating hours

$$CON = HRNIT - DH$$

daytime heating load

$$HCD = \frac{QTD * (HRNIT - PUH)}{HRNIT} - PICKUP * PUH$$

nighttime heating requirement

$$HLN = QTN * CON / HRNIT$$

5.9. HCRT: Heating and cooling requirement calculations

Input:

HLD = daytime sensible heating load, Btu/day
HCN = nighttime sensible heating load, Btu/day
CLD = daytime sensible cooling load, Btu/day
CLN = nighttime sensible cooling load, Btu/day
HL = daily sensible heat load = HLD + HLN
HG = daily sensible cooling load = CLD + CLN
LHG = latent heat gain
AIRLOS = air leakage through ducts = $\frac{\text{AIR LOSS} \times 100\%}{\text{supply air}}$

Heating requirement: $HREQ = HL * (1.0 + AIRLOS/100)$

if cooling season, $HREQ = 0$

Cooling requirements: $CREQ = (HG + LHG) * (1.0 + AIRLOS/100)$

if open windows in summer when outdoor
temp. < thermostat setting, $LHG = 0$

if heating season, $CREQ = 0$

5.10. EREQ: Energy requirement

Input:

HREQ = heating requirement
CREQ = cooling requirement
EH = heating efficiency
EC = cooling efficiency
WHREQ = hot water heating requirement
QS = energy from solar collector
QQC = heat gain through ducts and pipes
QQH = heat loss through ducts and pipes
ISYS = system index

1 = heating + no cooling

2 = no heating + cooling

3 = heating + cooling

Output:


EREQ (Energy Requirement)

System Index	Heating Energy Requirement	Cooling Energy Requirement
ISYS = 1	$(HREQ + WHREQ + QS + QQH)/EH$	0
2	$(WHREQ + QS + QQH)/EH$	$(CREQ + QQC)$
3	$(HREQ + WHREQ + QS + QQH)/EH$	$(CREQ + QQC)$

5.11. SEU: Solar collector heat gain

Input:

SA, SB = Collector efficiency curve data



Typical solar collector performance.

	SA	SB
High Performance	0.8	1.2
(double glaze, selective surface)		
Medium Performance	0.75	1.0
(double glaze, common black)		
(single glaze, selective surface)		
Low Performance	0.7	0.8
(single glaze, common black)		

TE = inlet fluid temperature to the collector, °F
 TOD = daytime outdoor temperature, °F
 I = daily total solar radiation, Btu/day
 SUF = solar heat utilization factor

0.8 for large storage tank system
 0.5 for small storage tank system

AS = collector area, ft²
 HRDAY = daytime hours, hr

Solar heat utilized

$$QS = AS * SA * \left(1 - \frac{HRDAY * (TE - TOD)}{SB * I}\right) * SUF * I$$

5.12. QI: Infiltration heat gain

Input:

INFIL = infiltration rate, cfm
 TOD = daytime outdoor temperature, °F
 TON = nighttime outdoor temperature, °F
 TID = daytime indoor temperature, °F
 TIN = nighttime indoor temperature, °F
 RH = room relative humidity, %
 RHA = afternoon outdoor relative humidity, %
 RHM = morning outdoor relative humidity, %
 HRDAY = daytime hours
 HRNIT = nighttime hours

Output:

Daytime sensible heat gain
 $QID = 1.08 * INFIL * (TOD - TID) * HRDAY$
 Nighttime sensible heat gain
 $QIN = 1.08 * INFIL * (TON - TIN) * HRNIT$

Latent heat

Determine the humidity ratio of indoor and outdoor air from psychrometric chart or by calling the psychrometric routine described in (5.15).

Calculate indoor humidity ratio WIN and WID by

nighttime Call DBRH (TIN, RH, WIN)

and daytime Call DBRH (TID, RH, WID).

Determine the daytime and nighttime humidity ratios of outdoor air, WOD and WON by

Call DBRH (TOD, RHA, WOD)

Call DBRH (TON, RHM, WON)

Daytime latent heat gain:

$$QILD = 4.5 * INFIL * (WOD - WID) * 1061 * HRDAY$$

Nighttime latent heat gain:

$$QILN = 4.5 * INFIL * (WON - WIN) * 1061 * HRNIT$$

It is important to note that QID, QIN, QILD and QILN are all zero when the natural cooling is used to minimize or eliminate the need for mechanical cooling.

5.13. QECHG: Opaque envelope conduction heat gain (walls, doors, roofs and floors)

Input: For all the opaque envelope such as atticless roofs, walls and doors, the following input data should be provided:

SATD = daytime sol-air temperature, °F

SATN = nighttime sol-air temperature, °F

U = overall heat transfer coefficient,
Btu/h ft² °F

A = area, ft²

TID = daytime indoor temperature, °F

TIN = nighttime indoor temperature, °F

HRDAY = daytime hours, hr

HRNIT = nighttime hours, hr

For daytime heat gain, $QD = U * A * (SATD - TID) * HRDAY$ Btu/day

For nighttime heat gain, $QN = U * A * (SATN - TIN) * HRNIT$ Btu/day

For the attic ceiling and crawl space floor, the sol-air temperature should be replaced by the attic temperature and crawl-space temperature.

5.14. QR: Internal heat gain

Input:

NPD = number daytime occupants

NPN = number nighttime occupants

WTD = average daytime lighting power, w

WTN = average nighttime lighting power, w
 WED = average daytime equipment power, w
 WEN = average nighttime equipment power, w
 HRDAY = daytime hours, hr
 HRNIT = nighttime hours,

Sensible heat gain

It is assumed that 1/3 of the equipment heat is used for the evaporation of water vapor such as from cooking.

Daytime: $QRSD = [NPD*240 + [WTD+(WED*0.66)]*3.413]*HRDAY$
 Nighttime: $QBSN = [NPN*240 + [WTN+(WEN*0.66)]*3.413]*HRNIT$

Latent heat gain

Daytime: $QRLD = [NPD*160 + (WED*0.34)*3.413]*HRDAY$
 Nighttime: $QRLN = [NPN*160 + (WEN*0.34)*3.413]*HRNIT$

5.15. DBRH: Relative humidity routine (see Appendix C-27)

Input:

DB = dry-bulb temperature, °F
 RH = relative humidity, %

Calculation algorithms for psychrometric routines are provided in reference [4].

Output:

W = humidity ratio, lb/lb

5.16. BSMT: Basement temperature and heat loss calculation

Input:

ZK = ground thermal conductivity Btu-in/hr ft² °F
 UBW = basement wall heat conductance, Btu/hr ft² °F⁻¹/
 UBF = basement floor heat conductance, Btu/hr ft² °F⁻¹/
 UFLR1 = heat conductance of floor above the basement,
 Btu/hr ft² °F
 BWAEX = Area of the exposed section of the basement wall, ft²
 BWA = basement wall area, ft²
 BFA = basement floor area, ft²
 L = height of the basement wall which is ground covered, ft

^a/ UBW and UBF are to be determined from the room air to the external surface of the wall/slab (soil interface).

TID = daytime temperature of the room above, °F
 TIN = nighttime temperature of the room above, °F
 TOD = daytime outdoor temperature, °F
 TON = nighttime outdoor temperature, °F
 TG = ground temperature, °F
 HRDAY = daytime hours, hr
 HRNIT = nighttime hours, hr
 QBHG = basement heat gain from furnace, boiler, or other equipment, Btu/hr

Output:

BSMTD = daytime basement temperature, °F
 BSMTN = nighttime basement temperature, °F
 BQFD = daytime basement heat loss, Btu/day
 BQFN = nighttime basement heat loss, Btu/day
 TO = (TOD + TON)/2.0

There are no exact solutions, similar to those described in the slab-on-grade calculation, for the basement wall heat condition. An approximate value of UW may be obtained by the following equation.

$$\begin{aligned}
 UW &= \frac{1}{\frac{1}{UFW} + \frac{1}{HO}} && \text{for the exposed section.} \\
 UW &= \frac{2 * ZK}{(\pi * L)} * \ln \left(1 + \frac{\pi * UFW * L}{2 * ZK} \right) && \text{for the ground-covered section.}
 \end{aligned}$$

The latter equation was derived from the assumption that the heat flow path between the basement wall and the ground surface is a quarter circle.

Basement flow heat transfer coefficient.

UF = The value should be determined by the same procedure used in the calculation of slab-on-grade floor heat transfer coefficient described in section 5.6.

$$BSMTD = \frac{QBHG + UW * BWA * TO + UF * BFA * TG + UFLR1 * BFA * TID}{UW * BWA + UF * BFA + UFLR1 * BFA}$$

$$BSMTN = \frac{QBHG + UW * BWA * TO + UF * BFA * TG + UFLR1 * BFA * TIN}{UW * BWA + UF * BFA + UFLR1 * BFA}$$

If basement is heated

$BQFD = (-UW \cdot (TID - T_O) \cdot BWA - UF \cdot (TID - T_G) \cdot BFA) \cdot HRDAY$
 $BQFN = (-UW \cdot (TIN - T_O) \cdot BWA - UF \cdot (TIN - T_G) \cdot BFA) \cdot HRNIT$
 $BSMTD = TID, BSMTN = TIN$

If basement is not heated BQFD & BQFN are calculated by using Subroutine

QECHG (=7.13. Opaque envelope conduction heat gain calculations) and the basement temperatures, BSMTD and BSMTN above.

5.17. HWHREQ: hot water heating requirement

Input: $TOUT$ = hot water outlet temperature °F
 TIN = hot water inlet temperature = ground temperature °F
 HWT = hot water usage, gallons/day
 A = total jacket area, ft²
 $BSMTD$ = daytime basement or indoor temperature, °F
 $BSMTN$ = nighttime basement or indoor temperature, °F
 $D1$ = thickness of existing tank insulation, ft
 $RAM1$ = thermal conductivity of existing insulation, Btu/hr, ft, °F
 $D2$ = thickness of additional insulation, ft
 $RAM2$ = thermal conductivity of additional insulation, Btu/h, ft, °F
 $HRDAY$ = daytime hour, hr
 $HRNIT$ = nighttime hours, hr

Output: Heat loss through existing jacket insulation around the hot water tank

$$HLHWH1 = U1 \cdot A \cdot ((BSMTD - TOUT) \cdot HRDAY) + (BSMTN - TOUT) \cdot HRNIT$$

where $U1 = 1.0 / (0.685 + D1/RAM1)$

Heat loss through additional jacket insulation of hot water tank

$$HLHWH2 = U2 \cdot A \cdot ((BSMTD - TOUT) \cdot HRDAY) + (BSMTN - TOUT) \cdot HRNIT$$

where $U2 = 1.0 / (0.685 + D1/RAM1 + D2/RAM2)$

Energy saving by additional insulation over the hot water tank

$$SAVE = HLHWH2 - HLHWH1$$

Hot water heating requirement, including jacket heat loss

$$WHREQ = 500.0/60.0*(TIN-TOUT)*HWT + HLHWH2$$

If $WHREQ > 0$, $WHREQ = 0$

Hot water heating requirement, excluding jacket heat loss

$$WHREQ2 = WHREQ - HLHWH2$$

5.18. CSDUPI: heat loss and gain through ducts and pipes in crawl space

Input:
 ADUCT = total surface area of duct in crawl space, ft^2
 UDUCT = U value of duct, $Btu/h\ ft^2\ ^\circ F$
 APIPE = total surface area of pipe in crawl space, ft^2
 UPIPE = U value of pipe, $Btu/h\ ft^2\ ^\circ F$
 TCSUPA = supply chilled air temperature, $^\circ F$
 TCSUPW = supply chilled water temperature, $^\circ F$
 THSUPA = supply hot air temperature, $^\circ F$
 THSUPW = supply hot water temperature, $^\circ F$
 CRAWLD = daytime crawl temperature, $^\circ F$
 CRAWLN = nighttime crawl temperature, $^\circ F$
 CFAC = factor for estimating operation time of cooling equipment
 HFAC = factor for estimating operation time of heating equipment
 HRDAY = daytime hours, hr
 HRNIT = nighttime hours, hr

Output: Heat gain through ducts and pipes

$$QC = ADUCT*UDUCT*((CRAWLD - TCSUPA)*HRDAY + (CRAWLN - TCSUPA)*HRNIT) *CFAC + APIPE*UPIPE*((CRAWLD - TCSUPW)*HRDAY + (CRAWLN - TCSUPW)*HRNIT)*CFAC$$

Heat loss through ducts and pipes

$$QH = ADUCT*UDUCT*((CRAWLD - THSUPA)*HRDAY + (CRAWLN - THSUPA)*HRNIT) *HFAC + APIPE*UPIPE*((CRAWLD - THSUPW)*HRDAY + (CRAWLN - THSUPW)*HRNIT)*HFAC$$

If cooling season, $QH = 0$

If heating season, $QC = 0$

5.19. ASDUPI: heat loss and gain through ducts and pipes in attic space

Input:
 ADUCT = total surface area of duct in attic space, ft^2
 UDUCT = U value of duct, $Btu/h\ ft^2\ ^\circ F$
 APIPE = total surface area of pipe in attic space, ft^2
 UPIPE = U value of pipe, $Btu/h\ ft^2\ ^\circ F$
 TCSUPA = supply chilled air temperature, $^\circ F$
 TCSUPW = supply chilled water temperature, $^\circ F$
 THSUPA = supply hot air temperature, $^\circ F$

THSUPW = supply hot water temperature, °F
 ATD = attic daytime temperature, °F
 ATN = attic nighttime temperature, °F
 CFAC = factor for estimating operation time of cooling equipment
 HFAC = factor for estimating operation time of heating equipment
 HRDAY = daytime hours
 HRNIT = nighttime hours

Output:

Heat gain through ducts and pipes

QC = $ADUCT * UDUCT * ((ATD - TCSUPA) * HRDAY + (ATN - TCSUPA) * HRNIT) * CFAC + APIPE * UPIPE * ((ATD - TCSUPW) * HRDAY + (ATN - TCSUPW) * HRNIT) * CFAC$

Heat loss through ducts and pipes

QH = $ADUCT * UDUCT * ((ATD - THSUPA) * HRDAY + (ATN - THSUPA) * HRNIT) * HFAC + APIPE * UPIPE * ((ATD - THSUPW) * HRDAY + (ATN - THSUPW) * HRNIT) * HFAC$

If cooling season, QH = 0

If heating season, QC = 0

5.20. BMDUFI: heat loss and gain through ducts and pipes in basement

Input: ADUCT = total surface area of duct in basement, ft²
 UDUCT = U value of duct, Btu/h ft² °F
 APIPE = total surface area of pipe in basement, ft²
 UPIPE = U value of pipe, Btu/h ft² °F
 TCSUPA = supply chilled air temperature, °F
 TCSUPW = supply chilled water temperature, °F
 THSUPA = supply hot air temperature, °F
 THSUPW = supply hot water temperature, °F
 BSMTD = basement daytime temperature, °F
 BSMTN = basement nighttime temperature, °F

CFAC = factor for estimating operation time of cooling equipment

HFAC = factor for estimating operation time of heating equipment

HRDAY = daytime hours, hr

HRNIT = nighttime hours, hr

Output:

Heat gain through ducts and pipes

QC = $ADUCT * UDUCT * ((BSMTD - TCSUPA) * HRDAY + (BSMTN - TCSUPA) * HRNIT) * CFAC + APIPE * UPIPE * ((BSMTD - TCSUPW) * HRDAY + (BSMTN - TCSUPW) * HRNIT) * CFAC$

Heat loss through ducts and pipes

$$QH = ADUCT*UDUCT*((BSMTD - THSUPA)*HRDAY + (BSMTN - THSUPA)*HRNIT)*HFAC + APIPE*UPIPE*((BSMTD - THSUPW)*HRDAY + (BSMTN - THSUPW)*HRNIT)*HFAC$$

If cooling season, $QH = 0$

If basement heated, $QH = 0$

If heating season, $QC = 0$

5.21. OSDUPI: heat loss and gain through outdoor ducts and pipes

Input: ADUCT = total surface area of outdoor duct, ft^2
ULUCT = U value of duct, $Btu/h\ ft^2\ ^\circ F$
APIPE = total surface area of outdoor pipe, ft^2
UPIPE = U value of pipe, $Btu/h\ ft^2\ ^\circ F$
TCSUPA = supply chilled air temperature, $^\circ F$
TCSUPW = supply chilled water temperature, $^\circ F$
THSUPA = supply hot air temperature, $^\circ F$
THSUPW = supply hot water temperature, $^\circ F$
TOD = daytime outdoor temperature, $^\circ F$
TON = nighttime outdoor temperature, $^\circ F$
CFAC = factor for estimating operation time of cooling equipment
HFAC = factor for estimating operation time of heating equipment
HRDAY = daytime hours, hr
HRNIT = nighttime hours, hr

Output:

Heat gain through ducts and pipes

$$QC = ADUCT*UDUCT*((TOD - TCSUPA)*HRDAY + (TON - TCSUPA)*HRNIT)*CFAC + APIPE*UPIPE*((TOD - TCSUPW)*HRDAY + (TON - TCSUPW)*HRNIT)*CFAC$$

Heat loss through ducts and pipes

$$QH = ADUCT*UDUCT*((TOD - THSUPA)*HRDAY + (TON - THSUPA)*HRNIT)*HFAC + APIPE*UPIPE*((TOD - THSUPW)*HRDAY + (TON - THSUPW)*HRNIT)*HFAC$$

If cooling season, $QH = 0$

If heating season, $QC = 0$

The routines described above are incorporated into a Fortran program, listing of which is given in Appendix C.

Appendix D presents a description of the data file and suggested default values to be used for the heating and cooling requirement calculations.

5. COMPARISON WITH DOE-2 RUNS

Figures 5 and 6 are comparisons of annual heating and cooling requirements obtained by the simplified procedure described herein with those obtained by DOE-2, a comprehensive hourly simulation program for building energy analysis, for ten cities and for a combination of several energy conservation options as shown in Table 1. The basic building data used for these comparative calculations are described in a recent report of the Lawrence Berkeley Laboratory⁵⁷.

As can be seen, the total annual heating and cooling requirements obtained by the simplified procedure do not agree well with those determined by the DOE-2.

Since the DOE-2 uses TRY (Typical Reference Year) weather data, a set of monthly normal day data were generated from the DOE-2 program from the TRY weather data tape and used in the simplified calculation procedure. The infiltration routine was also modified to be consistent with the DOE-2 algorithm. Figures 7 and 8 show the improved relationships between the two calculations as the result of these two adjustments.

Table 1. Building Data for the Comparative Calculations with DOE-2

City	Base Case				Additions to Base Levels of Insulation, Glazing							
	Wall	Attic	Windows	Floor	1	2	3	Options				
					4	5	6	7	8			
Minneapolis	Alum Siding R-11	R-22	Double	Basement U=.000001	R-38 Attic	R-19 Wall	Triple Glaze	R-25 Wall				
Chicago	Alum Siding R-11	R-19	Double	Basement U=.000001	R-38 Attic	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze	R-25 Wall		
Portland	Alum Siding R-11	R-19	Double	Crawl Space R-7 U=.04339	R-19 Wall	R-19 Floor	R-38 Attic	Triple Glaze	R-25 Wall			
Washington DC	Alum Siding R-11	R-19	Double	Basement U=.000001	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze	R-25 Wall			
Atlanta	Alum Siding R-11	R-19	Single	Crawl Space R-7 U=.04359	Double Glaze	R-11 Floor	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze	R-19 Floor	R-25 Wall
28 Fresno	Stucco R-11	R-19	Single	Slab-on- Grade U=.1202	Double Glaze	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze			
Burbank	Stucco R-11	R-19	Single	Slab-on- Grade U=.1202	Double Glaze	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze			
Phoenix	Alum Siding R-11	R-19	Single	Slab-on- Grade U=.1202	Double Glaze	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze			
Houston	Alum Siding R-11	R-19	Single	Slab-on- Grade U=.1202	Double Glaze	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze			
Ft. Worth	Alum Siding R-11	R-19	Single	Slab-on- Grade U=.1202	Double Glaze	R-30 Attic	R-19 Wall	R-38 Attic	Triple Glaze			




Figure 5. Comparison between the annual heating requirements of a typical residence determined by the simplified procedure and by the DOE-2 program




Figure 6. Comparison between the annual cooling requirements of a typical residence determined by the simplified procedure and by the DOE-2 program




Figure 7. Improved comparison between the annual heating requirements of a typical residence determined by the simplified procedure and by the DOE-2 program




Figure 8. Improved comparison between the annual cooling requirements of a typical residence determined by the simplified procedure and by the DOE-2 program

APPENDIX A. LIU-JORDAN SOLAR CALCULATION DATA
Radiation and Other Data for 80 Locations in the United States and Canada

(H = Monthly average daily total radiation on a horizontal surface, Btu/day-ft²; K_t = the fraction of the extra terrestrial radiation transmitted through the atmosphere; t_o = ambient temperature, deg F.)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Albuquerque, N. M.	H	1150.9	1453.9	1925.4	2343.5	2560.9	2757.5	2561.2	2387.8	2120.3	1639.8	1274.2	1051.1
Lat. 35°03'N.	K _t	0.704	0.691	0.719	0.722	0.713	0.737	0.695	0.708	0.728	0.711	0.684	0.704
El. 5314 ft.	t _o	37.3	43.3	50.1	59.6	69.4	79.1	82.8	80.6	73.6	62.1	47.8	39.4
Annette Is., Alaska.	H	236.2	428.4	883.4	1357.2	1634.7	1638.7	1632.1	1269.4	962	454.6	220.3	152
Lat. 55°02'N.	K _t	0.427	0.415	0.492	0.507	0.484	0.441	0.454	0.427	0.449	0.347	0.304	0.361
El. 110 ft.	t _o	35.8	37.5	39.7	44.4	51.0	56.2	58.6	59.8	54.8	48.2	41.9	37.4
Apalachicola, Florida.	H	1107	1378.2	1654.2	2040.9	2268.6	2195.9	1978.6	1912.9	1703.3	1544.6	1243.2	982.3
Lat. 29°45'N.	K _t	0.577	0.584	0.576	0.612	0.630	0.594	0.542	0.558	0.559	0.608	0.574	0.543
El. 35 ft.	t _o	57.3	59.0	62.9	69.5	76.4	81.8	83.1	83.1	80.6	73.2	53.7	58.55
Astoria, Oregon.	H	338.4	607	1008.5	1401.5	1838.7	1753.5	2007.7	1721	1322.5	780.4	413.6	295.2
Lat. 46°12'N.	K _t	0.330	0.397	0.454	0.471	0.524	0.466	0.551	0.538	0.526	0.435	0.336	0.332
El. 8 ft.	t _o	41.3	44.7	46.9	51.3	55.0	59.3	62.6	63.6	62.2	55.7	48.5	43.9
Atlanta, Georgia.	H	848	1080.1	1426.9	1807	2618.12	2002.6	2092.9	1898.1	1519.2	1290.8	997.8	751.6
Lat. 33°39'N.	K _t	0.493	0.496	0.522	0.551	0.561	0.564	0.545	0.559	0.515	0.543	0.510	0.474
El. 976 ft.	t _o	47.2	49.6	55.9	65.0	73.2	80.9	82.4	81.6	77.4	66.5	54.8	47.7
Barrow, Alaska.	H	13.3	143.2	713.3	1491.5	1883	2055.3	1602.2	953.5	428.4	152.4	22.9	-
Lat. 71°20'N.	K _t	-	0.776	0.773	0.726	0.553	0.533	0.448	0.377	0.315	0.35	-	-
El. 22 ft.	t _o	-13.2	-15.9	-12.7	2.1	20.5	35.4	41.6	40.0	31.7	18.6	2.6	-8.6
Bethel, Alaska.	H	142.4	404.8	1052.4	1662.3	1711.8	1698.1	1401.8	938.7	755	430.6	164.9	83
Lat. 60°47'N.	K _t	0.536	0.557	0.704	0.675	0.519	0.458	0.398	0.336	0.406	0.432	0.399	0.459
El. 125 ft.	t _o	9.2	11.6	14.2	29.4	42.7	55.5	56.9	54.8	47.4	33.7	19.0	9.4
Bismarck, North Dakota.	H	587.4	934.3	1328.4	1668.2	2056.1	2173.8	2305.5	1929.1	1441.3	1018.1	600.4	464.2
Lat. 46°47'N.	K _t	0.594	0.628	0.605	0.565	0.588	0.579	0.634	0.606	0.581	0.584	0.510	0.547
El. 1660 ft.	t _o	12.4	15.9	29.7	46.6	58.6	67.9	76.1	73.5	61.6	49.6	31.4	18.4
Blue Hill, Mass.	H	555.3	797	1143.9	1438	1776.4	1943.9	1881.5	1622.1	1314	941	592.2	482.3
Lat. 42°13'N.	K _t	0.445	0.458	0.477	0.464	0.501	0.516	0.513	0.495	0.492	0.472	0.406	0.436
El. 629 ft.	t _o	28.3	28.3	36.9	46.9	58.5	67.2	72.3	70.6	64.2	54.1	43.3	31.5
Boise, Idaho.	H	518.8	884.9	1280.4	1814.4	2189.3	2376.7	2500.3	2149.4	1717.7	1128.4	678.6	456.8
Lat. 43°34'N.	K _t	0.446	0.533	0.548	0.594	0.619	0.631	0.684	0.660	0.656	0.588	0.494	0.442
El. 2844 ft.	t _o	29.5	36.5	45.0	53.5	62.1	69.3	79.6	77.2	66.7	56.3	42.3	33.1

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Boston, Mass.	$\bar{P}$	505.5	738	1067.1	1355	1769	1864	1860.5	1570.1	1287.5	896.7	535.8	442.8
Lat. 42°22'N.	$\bar{K}_t$	0.410	0.426	0.445	0.438	0.499	0.495	0.507	0.480	0.477	0.453	0.372	0.400
El. 29 ft.	t_o	31.4	31.4	39.9	49.5	60.4	69.8	74.5	73.8	66.8	57.4	46.6	34.9
Brownsville, Texas	$\bar{H}$	1105.9	1262.7	1505.9	1714	2092.2	2288.5	2345	2124	1774.9	1536.5	1104.8	982.3
Lat. 25°55'N.	$\bar{K}_t$	0.517	0.500	0.505	0.509	0.584	0.627	0.650	0.617	0.566	0.570	0.468	0.488
El. 20 ft.	t_o	63.3	66.7	70.7	76.2	81.4	85.1	86.5	86.9	84.1	78.9	70.7	65.2
Caribou, Maine	$\bar{H}$	497	861.6	1360.1	1495.9	1779.7	1779.7	1898.1	1675.6	1254.6	793	415.5	398.9
Lat. 46°52'N.	$\bar{K}_t$	0.504	0.579	0.619	0.507	0.509	0.473	0.522	0.527	0.506	0.455	0.352	0.470
El. 628 ft.	t_o	11.5	12.8	24.4	37.3	51.8	61.6	67.2	65.0	56.2	44.7	31.3	16.8
Charleston, S.C.	$\bar{H}$	946.1	1152.8	1352.4	1918.8	2063.4	2113.3	1649.4	1933.6	1557.2	1332.1	1075.6	882
Lat. 32°54'N.	$\bar{K}_t$	0.541	0.521	0.491	0.584	0.574	0.567	0.454	0.569	0.525	0.554	0.539	0.506
El. 46 ft.	t_o	53.6	55.2	60.6	67.8	74.8	80.9	82.9	82.3	79.1	69.8	59.8	54.0
Cleveland, Ohio.	$\bar{H}$	466.8	681.9	1207	1443.9	1928.4	2102.6	2094.4	1840.6	1410.3	997	526.6	427.3
Lat. 41°24'N.	$\bar{K}_t$	0.361	0.383	0.497	0.464	0.543	0.559	0.571	0.559	0.524	0.491	0.351	0.371
El. 805 ft.	t_o	30.8	30.9	39.4	50.2	62.4	72.7	77.0	75.1	68.5	57.4	44.0	32.8
Columbia, Mo.	$\bar{H}$	651.3	941.3	1315.8	1631.3	1999.6	2129.1	2148.7	1953.1	1689.6	1202.6	839.5	590.4
Lat. 38°58'N.	$\bar{K}_t$	0.458	0.492	0.520	0.514	0.559	0.566	0.585	0.588	0.606	0.562	0.510	0.457
El. 785 ft.	t_o	32.5	36.5	45.9	57.7	66.7	75.9	81.1	79.4	71.9	61.4	46.1	35.8
Columbus, Ohio.	$\bar{H}$	486.3	746.5	1112.5	1480.8	1839.1	(2111)	2041.3	1572.7	1189.3	919.5	479	430.2
Lat. 40°00'N.	$\bar{K}_t$	0.356	0.401	0.447	0.470	0.515	(0.561)	0.555	0.475	0.433	0.441	0.302	0.351
El. 833 ft.	t_o	32.1	33.7	42.7	53.5	64.4	74.2	78	75.9	70.1	58	44.5	34.0
Davis, Calif.	$\bar{H}$	599.2	945	1504	1959	2368.6	2619.2	2565.6	2287.8	1856.8	1288.5	795.6	550.5
Lat. 38°33'N.	$\bar{K}_t$	0.416	0.490	0.591	0.617	0.662	0.697	0.697	0.687	0.664	0.598	0.477	0.421
El. 51 ft.	t_o	47.6	52.1	56.8	63.1	69.6	75.7	81	79.4	76.7	67.8	57	48.7
Dodge City, Kan.	$\bar{H}$	953.1	1186.3	1565.7	1975.6	2126.5	2459.8	2400.7	2210.7	1841.7	1421	1065.3	873.8
Lat. 37°46'N.	$\bar{K}_t$	0.639	0.598	0.606	0.618	0.594	0.655	0.652	0.663	0.654	0.650	0.625	0.652
El. 2592 ft.	t_o	33.8	38.7	46.5	57.7	66.7	77.2	83.8	82.4	73.7	61.7	46.5	36.8
East Lansing, Michigan ...	$\bar{H}$	425.8	739.1	1086	1249.8	1732.8	1914	1884.5	1627.7	1303.3	891.5	473.1	379.7
Lat. 42°44'N.	$\bar{K}_t$	0.35	0.431	0.456	0.406	0.489	0.508	0.514	0.498	0.493	0.456	0.333	0.349
El. 856 ft.	t_o	26.0	26.4	35.7	48.4	59.8	70.3	74.5	72.4	65.0	53.5	40.0	29.0
East Wareham, Mass.	$\bar{H}$	504.4	762.4	1132.1	1392.6	1704.8	1958.3	1873.8	1607.4	1363.8	996.7	636.2	521
Lat. 41°46'N.	$\bar{K}_t$	0.398	0.431	0.462	0.449	0.480	0.520	0.511	0.489	0.508	0.496	0.431	0.461
El. 18 ft.	t_o	32.2	31.6	39.0	48.3	58.9	67.5	74.1	72.8	65.9	56	46	34.8

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Edmonton, Alberta.....	H	331.7	652.4	1165.3	1541.7	1900.4	1914.4	1964.9	1528	1113.3	704.4	413.6	245
Lat. 53°35'N.....	K _t	0.529	0.585	0.624	0.564	0.558	0.514	0.549	0.506	0.506	0.504	0.510	0.492
El. 2219 ft.....	t _o	10.4	14	26.3	42.9	55.4	61.3	66.6	63.2	54.2	44.1	26.7	14.0
El Paso, Texas.....	H	1247.6	1612.9	2048.7	2447.2	2673	2731	2391.1	2350.5	2077.5	1704.8	1324.7	1051.6
Lat. 31°48'N.....	K _t	0.686	0.714	0.730	0.741	0.743	0.733	0.652	0.669	0.693	0.395	0.647	0.626
El. 3916 ft.....	t _o	47.1	53.1	58.7	67.3	75.7	84.2	84.9	83.4	78.5	69.0	56.0	48.5
Ely, Nevada.....	H	871.6	1255	1749.8	2103.3	2322.1	2649	2417	2307.7	1935	1473	1078.6	814.8
Lat. 38°17'N.....	K _t	0.618	0.660	0.692	0.664	0.649	0.704	0.656	0.695	0.696	0.691	0.658	0.64
El. 6262 ft.....	t _o	27.3	32.1	39.5	48.3	57.0	65.4	74.5	72.3	63.7	52.1	39.9	31.1
Fairbanks, Alaska.....	H	66	283.4	860.5	1481.2	1806.2	1970.8	1702.9	1247.6	699.6	323.6	104.1	20.3
Lat. 64°49'N.....	K _t	0.639	0.556	0.674	0.647	0.546	0.529	0.485	0.463	0.419	0.416	0.47	0.458
El. 436 ft.....	t _o	-7.0	0.3	13.0	32.2	50.5	62.4	63.8	58.3	47.1	29.6	5.5	-6.6
Fort Worth, Texas.....	H	936.2	1198.5	1597.8	1629.1	2105.1	2437.6	2293.3	2216.6	1880.6	1476	1147.6	913.6
Lat. 32°50'N.....	K _t	0.530	0.541	0.577	0.556	0.585	0.654	0.624	0.653	0.634	0.612	0.576	0.563
El. 544 ft.....	t _o	48.1	52.3	59.8	68.8	75.9	84.0	87.7	88.6	81.3	71.5	58.8	50.8
Fresno, Calif.....	H	712.9	1116.6	1652.8	2049.4	2409.2	2641.7	2512.2	2300.7	1897.8	1415.5	906.6	616.6
Lat. 36°46'N.....	K _t	0.462	0.551	0.632	0.638	0.672	0.703	0.682	0.686	0.665	0.635	0.512	0.44
El. 331 ft.....	t _o	47.3	53.9	59.1	65.6	73.5	80.7	87.5	84.9	78.6	68.7	57.3	48.9
Gainesville, Fla.....	H	1036.8	1324.7	1635	1956.4	1934.7	1960.9	1895.6	1873.8	1615.1	1312.2	1169.7	919.5
Lat. 29°39'N.....	K _t	0.535	0.56	0.568	0.587	0.538	0.531	0.519	0.547	0.529	0.515	0.537	0.508
El. 165 ft.....	t _o	62.1	63.1	67.5	72.8	79.4	83.4	83.8	84.1	82	75.7	67.2	62.4
Glasgow, Mont.....	H	572.7	965.7	1437.6	1741.3	2127.3	2261.6	2414.7	1984.5	1531	997	574.9	428.4
Lat. 48°13'N.....	K _t	0.621	0.678	0.672	0.597	0.611	0.602	0.666	0.630	0.629	0.593	0.516	0.548
El. 2277 ft.....	t _o	13.3	17.3	31.1	47.8	59.3	67.3	76	73.2	61.2	49.2	31.0	18.6
Grand Junction, Colo.....	H	848	1210.7	1622.9	2002.2	2300.3	2645.4	2517.7	2157.2	1957.5	1394.8	969.7	793.4
Lat. 39°07'N.....	K _t	0.597	0.633	0.643	0.632	0.643	0.704	0.690	0.65	0.705	0.654	0.59	0.621
El. 4849 ft.....	t _o	26.9	35.0	44.6	55.8	66.3	75.7	82.5	79.6	71.4	58.3	42.0	31.4
Grand Lake, Colo.....	H	735	1135.4	1579.3	1876.7	1974.9	2369.7	2103.3	1708.5	1715.8	1212.2	715.6	660.5
Lat. 40°15'N.....	K _t	0.541	0.615	0.637	0.597	0.553	0.63	0.572	0.516	0.626	0.583	0.494	0.542
El. 8389 ft.....	t _o	18.5	23.1	28.5	39.1	48.7	56.6	62.8	61.5	55.5	45.2	30.3	22.6
Great Falls, Mont.....	H	524	869.4	1369.7	1621.4	1970.8	2179.3	2383	1986.3	1536.5	984.9	575.3	420.7
Lat. 47°29'N.....	K _t	0.552	0.596	0.631	0.551	0.565	0.580	0.656	0.627	0.626	0.574	0.503	0.518
El. 3664 ft.....	t _o	25.4	27.6	35.6	47.7	57.5	64.3	73.8	71.3	60.6	51.4	38.0	29.1

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Greensboro, N.C.	H	743.9	1031.7	1323.2	1755.3	1988.5	2111.4	2033.9	1810.3	1517.3	1202.6	908.1	690.8
Lat. 36°05'N.	K _t	0.469	0.499	0.499	0.543	0.554	0.563	0.552	0.538	0.527	0.531	0.501	0.479
El. 891 ft.	t ₀	42.0	44.2	51.7	60.8	69.9	78.0	80.2	78.9	73.9	62.7	51.5	43.2
Griffin, Georgia.	H	889.6	1135.8	1450.9	1923.6	2163.1	2176	2064.9	1961.2	1605.9	1352.4	1073.8	781.5
Lat. 33°15'N.	K _t	0.513	0.517	0.523	0.586	0.601	0.583	0.562	0.578	0.543	0.565	0.545	0.487
El. 980 ft.	t ₀	48.9	51.0	59.1	66.7	74.6	81.2	83.0	82.2	78.4	68	57.3	49.4
Hatteras, N.C.	H	891.9	1184.1	1590.4	2128	2376.4	2438	2334.3	2085.6	1758.3	1337.6	1053.5	798.1
Lat. 35°13'N.	K _t	0.546	0.563	0.593	0.655	0.661	0.652	0.634	0.619	0.605	0.58	0.566	0.535
El. 7 ft.	t ₀	49.9	49.5	54.7	61.5	69.9	77.2	80.0	79.8	76.7	67.9	59.1	51.3
Indianapolis, Ind.	H	526.2	797.4	1184.1	1481.2	1828	2042	2039.5	1832.1	1513.3	1094.4	662.4	491.1
Lat. 39°44'N.	K _t	0.380	0.424	0.472	0.47	0.511	0.543	0.554	0.552	0.549	0.520	0.413	0.391
El. 793 ft.	t ₀	31.3	33.9	43.0	54.1	64.9	74.8	79.6	77.4	70.6	59.3	44.2	33.4
Inyokern, Calif.	H	1148.7	1554.2	2136.9	2594.8	2925.4	3108.8	2908.8	2759.4	2409.2	1819.2	3170.1	1094.4
Lat. 35°39'N.	K _t	0.716	0.745	0.803	0.8	0.815	0.830	0.790	0.820	0.834	0.795	0.743	0.742
El. 2440 ft.	t ₀	47.3	53.9	59.1	65.6	73.5	80.7	87.5	84.9	78.6	68.7	57.3	48.9
Ithaca, N.Y.	H	434.3	755	1074.9	1322.9	1779.3	2025.8	2031.3	1736.9	1320.3	918.4	466.4	370.8
Lat. 42°27'N.	K _t	0.351	0.435	0.45	0.428	0.502	0.538	0.554	0.530	0.497	0.465	0.324	0.337
El. 950 ft.	t ₀	27.2	26.5	36	48.4	59.6	68.9	73.9	71.9	64.2	53.6	41.5	29.6
Lake Charles, La.	H	899.2	1145.7	1487.4	1801.8	2080.4	2213.3	1968.6	1910.3	1678.2	1505.5	1122.1	875.3
Lat. 30°13'N.	K _t	0.473	0.492	0.521	0.542	0.578	0.597	0.538	0.558	0.553	0.597	0.524	0.494
El. 12 ft.	t ₀	55.3	58.7	63.5	70.9	77.4	83.4	84.8	85.0	81.5	73.8	62.6	56.9
Lander, Wyo.	H	786.3	1146.1	1638	1988.5	2114	2492.2	2438.4	2120.6	1712.9	1301.8	837.3	694.8
Lat. 42°48'N.	K _t	0.65	0.672	0.691	0.647	0.597	0.662	0.665	0.649	0.647	0.666	0.589	0.643
El. 5370 ft.	t ₀	20.2	26.3	34.7	45.5	56.0	65.4	74.6	72.5	61.4	48.3	3.4	23.8
Las Vegas, Nev.	H	1035.8	1438	1926.5	2322.8	2629.5	2799.2	2524	2342	2062	1602.6	1190	964.2
Lat. 36°05'N.	K _t	0.654	0.697	0.728	0.719	0.732	0.746	0.685	0.697	0.718	0.704	0.657	0.668
El. 2162 ft.	t ₀	47.5	53.9	60.3	69.5	78.3	88.2	95.0	92.9	35.4	71.7	57.8	50.2
Lemont, Illinois.	H	(590)	879	1255.7	1481.5	1866	2041.7	1990.8	1836.9	1469.4	1015.5	(639)	(531)
Lat. 41°40'N.	K _t	(0.464)	0.496	0.520	0.477	0.525	0.542	0.542	0.559	0.547	0.508	(0.433)	(0.467)
El. 595 ft.	t ₀	28.9	30.3	39.5	49.7	59.2	70.8	75.8	74.3	67.2	57.6	43.0	30.6
Lexington, Ky.	H	-	-	-	1834.7	2171.2	-	2246.5	2064.9	1775.6	1315.8	-	681.5
Lat. 38°02'N.	K _t	-	-	-	0.575	0.606	-	0.610	0.619	0.631	0.604	-	0.513
El. 979 ft.	t ₀	36.5	38.8	47.4	57.8	67.5	76.2	79.8	78.2	72.8	61.2	47.6	38.5

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Lincoln, Neb.	H	712.5	955.7	1299.6	1587.8	1856.1	2040.6	2011.4	1902.6	1543.5	1215.8	773.4	643.2
Lat. 40°51'N.	K _t	0.542	0.522	0.532	0.507	0.522	0.542	0.547	0.577	0.568	0.598	0.508	0.545
El. 1189 ft.	t _o	27.8	32.1	42.4	55.8	65.8	76.0	82.6	80.2	71.5	59.9	43.2	31.8
Little Rock, Ark.	H	704.4	974.2	1335.8	1669.4	1960.1	2091.5	2081.2	1938.7	1640.6	1282.6	913.6	701.1
Lat. 34°44'N.	K _t	0.424	0.458	0.496	0.513	0.545	0.559	0.566	0.574	0.561	0.552	0.484	0.463
El. 265 ft.	t _o	44.6	48.5	56.0	65.8	73.1	76.7	85.1	84.6	78.3	67.9	54.7	46.7
Los Angeles, Calif. (WBAS).	H	930.6	1284.1	1729.5	1948	2196.7	2272.3	2413.6	2155.3	1898.1	1372.7	1082.3	901.1
Lat. 33°56'N.	K _t	0.547	0.596	0.635	0.595	0.610	0.608	0.657	0.635	0.641	0.574	0.551	0.566
El. 99 ft.	t _o	56.2	56.9	59.2	61.4	64.2	66.7	69.6	70.2	69.1	66.1	62.6	58.7
Los Angeles, Calif. (WBO).	H	911.8	1223.6	1640.9	1866.8	2061.2	2259	2428.4	2198.9	1891.5	1362.3	1053.1	877.8
Lat. 34°03'N.	K _t	0.538	0.568	0.602	0.571	0.573	0.605	0.66	0.648	0.643	0.578	0.548	0.566
El. 99 ft.	t _o	57.9	59.2	61.8	64.3	67.6	70.7	75.8	76.1	74.2	69.6	65.4	60.2
Madison, Wis.	H	564.6	812.2	1232.1	1455.3	1745.4	2031.7	2046.5	1740.2	1443.9	993	555.7	495.9
Lat. 43°08'N.	K _t	0.49	0.478	0.522	0.474	0.493	0.540	0.559	0.534	0.549	0.510	0.396	0.467
El. 866 ft.	t _o	21.8	24.6	35.3	49.0	61.0	70.9	76.8	74.4	65.6	53.7	37.8	25.4
Matanuska, Alaska.	H	119.2	345	-	1327.6	1628.4	1727.6	1526.9	1169	737.3	373.8	142.8	54.4
Lat. 61°30'N.	K _t	0.513	0.503	-	0.545	0.494	0.466	0.434	0.419	0.401	0.390	0.372	0.364
El. 180 ft.	t _o	13.9	21.0	27.4	38.6	50.3	57.6	60.1	58.1	50.2	37.7	22.9	13.9
Medford, Oregon H.	H	435.4	804.4	1259.8	1807.4	2216.2	2440.5	2607.4	2261.6	1672.3	1043.5	558.7	346.5
Lat. 42°23'N.	K _t	0.353	0.464	0.527	0.584	0.625	0.648	0.710	0.689	0.628	0.526	0.384	0.313
El. 1329 ft.	t _o	39.4	45.4	50.8	56.3	63.1	69.4	76.9	76.4	69.6	58.7	47.1	40.5
Miami, Florida.	H	1292.2	1554.6	1828.8	2020.6	2068.6	1991.5	1992.6	1890.8	1646.8	1436.5	1321	1183.4
Lat. 25°47'N.	K _t	0.604	0.616	0.612	0.600	0.578	0.545	0.552	0.549	0.525	0.534	0.559	0.588
El. 9 ft.	t _o	71.6	72.0	73.8	77.0	79.9	82.9	84.1	84.5	83.3	80.2	75.6	72.6
Midland, Texas.	H	1066.4	1345.7	1784.8	2036.1	2301.1	2317.7	2301.8	2193	1921.8	1470.8	1244.3	1023.2
Lat. 31°56'N.	K _t	0.587	0.596	0.638	0.617	0.639	0.622	0.628	0.643	0.642	0.600	0.609	0.611
El. 2854 ft.	t _o	47.9	52.8	60.0	68.8	77.2	83.9	85.7	85.0	78.9	70.3	56.6	49.1
Nashville, Tenn.	H	589.7	907	1246.8	1662.3	1997	2149.4	2079.7	1862.7	1600.7	1223.6	823.2	614.4
Lat. 36°07'N.	K _t	0.373	0.440	0.472	0.514	0.556	0.573	0.565	0.554	0.556	0.540	0.454	0.426
El. 605 ft.	t _o	42.6	45.1	52.9	63.0	71.4	80.1	83.2	81.9	76.6	65.4	52.3	44.3
New Port, R.I.	H	565.7	856.4	1231.7	1484.8	1849	2019.2	1942.8	1687.1	1411.4	1035.4	656.1	527.7
Lat. 41°29'N.	K _t	0.438	0.482	0.507	0.477	0.520	0.536	0.529	0.513	0.524	0.512	0.44	0.460
El. 60 ft.	t _o	29.5	32.0	39.6	48.2	58.6	67.0	73.2	72.3	65.7	56.2	46.5	34.4

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
New York, N. Y.	H	539.5	790.8	1180.4	1426.2	1738.4	1994.1	1930.7	1605.9	1349.4	977.8	598.1	476
Lat. 40°46'N.	K _t	0.406	0.435	0.480	0.455	0.488	0.53	0.528	0.486	0.500	0.475	0.397	0.403
El. 52 ft.	t _o	35.0	34.9	43.1	52.3	63.3	72.2	76.9	75.3	69.5	59.3	48.3	37.7
Oak Ridge, Tenn.	H	604	895.9	1241.7	1689.6	1942.8	2066.4	1972.3	1795.6	1559.8	1194.8	796.3	610
Lat. 36°01'N.	K _t	0.382	0.435	0.471	0.524	0.541	0.551	0.536	0.534	0.542	0.527	0.438	0.422
El. 905 ft.	t _o	41.9	44.2	51.7	61.4	69.8	77.8	80.2	78.8	74.5	62.7	50.4	42.5
Oklahoma City, Oklahoma ..	H	938	1192.6	1534.3	1849.4	2005.1	2355	2273.8	2211	1819.2	1409.6	1085.6	897.4
Lat. 35°24'N.	K _t	0.580	0.571	0.576	0.570	0.558	0.629	0.618	0.565	0.628	0.614	0.588	0.608
El. 1304 ft.	t _o	40.1	45.0	53.2	63.6	71.2	80.6	85.5	85.4	77.4	66.5	52.2	43.1
Ottawa, Ontario.	H	539.1	852.4	1250.5	1506.6	1857.2	2084.5	2045.4	1752.4	1326.6	826.9	458.7	408.5
Lat. 45°20'N.	K _t	0.499	0.540	0.554	0.502	0.529	0.554	0.560	0.546	0.521	0.450	0.359	0.436
El. 339 ft.	t _o	14.6	15.6	27.7	43.3	57.5	67.5	71.9	69.8	61.5	48.9	35	19.6
Phoenix, Ariz.	H	1126.6	1514.7	1967.1	2388.2	2709.6	2781.5	2450.5	2299.6	2131.3	1688.9	1290	1040.9
Lat. 33°26'N.	K _t	0.65	0.691	0.716	0.728	0.753	0.745	0.667	0.677	0.722	0.708	0.657	0.652
El. 1112 ft.	t _o	54.2	58.8	64.7	72.2	80.8	89.2	94.6	92.5	87.4	75.8	63.6	56.7
Portland, Maine.	H	565.7	874.5	1329.5	1528.4	1923.2	2017.3	2095.6	1799.2	1428.8	1035	591.5	507.7
Lat. 43°39'N.	K _t	0.482	0.524	0.569	0.500	0.544	0.536	0.572	0.554	0.546	0.539	0.431	0.491
El. 63 ft.	t _o	23.7	24.5	34.4	44.8	55.4	65.1	71.1	69.7	61.9	51.8	40.3	28.0
Rapid City, S. D.	H	687.8	1032.5	1503.7	1807	2028	2193.7	2235.8	2019.9	1628	1179.3	733.1	590.4
Lat. 44°09'N.	K _t	0.601	0.627	0.649	0.594	0.574	0.583	0.612	0.622	0.628	0.624	0.566	0.588
El. 3218 ft.	t _o	24.7	27.4	34.7	48.2	58.3	67.3	76.3	75.0	64.7	52.9	38.7	29.2
Riverside, Calif.	H	999.6	1335	1750.5	1943.2	2282.3	2492.6	2443.5	2263.8	1955.3	1509.6	1169	979.7
Lat. 33°57'N.	K _t	0.589	0.617	0.643	0.594	0.635	0.667	0.665	0.668	0.665	0.639	0.606	0.626
El. 1020 ft.	t _o	55.3	57.0	60.6	65.0	69.4	74.0	81.0	81.0	78.5	71.0	63.1	57.2
St. Cloud, Minn.	H	632.8	976.7	1383	1598.1	1859.4	2003.3	2007.8	1828.4	1369.4	890.4	545.4	463.1
Lat. 45°35'N.	K _t	0.595	0.629	0.614	0.534	0.530	0.533	0.573	0.570	0.539	0.490	0.435	0.504
El. 1034 ft.	t _o	13.6	16.9	29.8	46.2	58.8	68.5	74.4	71.9	62.5	50.2	32.1	18.3
Salt Lake City, Utah.	H	622.1	986	1301.1	1813.3	-	-	-	-	1689.3	1250.3	-	552.8
Lat. 40°46'N.	K _t	0.468	0.909	0.529	0.579	-	-	-	-	0.621	0.610	-	0.467
El. 4227 ft.	t _o	29.4	36.2	44.4	53.9	63.1	71.7	81.3	79.0	68.7	57.0	42.5	34.0
San Antonio, Tex.	H	1045	1293.2	1560.1	1664.6	2024.7	814.8	2264.2	2185.2	1844.6	1487.4	1104.4	954.6
Lat. 29°32'N.	K _t	0.541	0.550	0.542	0.500	0.563	0.220	0.647	0.637	0.603	0.584	0.507	0.528
El. 794 ft.	t _o	53.7	58.4	65.0	72.2	79.2	85.0	87.4	87.8	82.6	74.7	63.3	56.5

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Santa Maria, Calif	H	983.8	1296.3	1805.9	2067.9	2375.6	2599.6	2540.6	2293.3	1965.7	1566.4	1169	943.9
	K _t	0.595	0.613	0.671	0.638	0.661	0.695	0.690	0.678	0.674	0.676	0.624	0.627
	t ₀	54.1	55.3	57.6	59.5	61.2	63.5	65.3	65.7	65.9	64.1	60.6	56.1
Sault Ste. Marie, Michigan	H	488.6	843.9	1336.5	1559.4	1862.3	2064.2	2149.4	1767.9	1207	809.2	392.2	359.8
	K _t	0.490	0.560	0.606	0.526	0.560	0.549	0.590	0.554	0.481	0.457	0.323	0.408
	t ₀	16.3	16.2	25.6	39.5	52.1	61.6	67.3	66.0	57.9	46.8	33.4	21.9
Sayville, N. Y	H	602.9	936.2	1259.4	1560.5	1857.2	2123.2	2040.9	1734.7	1446.8	1087.4	697.8	533.9
	K _t	0.453	0.511	0.510	0.498	0.522	0.564	0.555	0.525	0.530	0.527	0.450	0.447
	t ₀	35	34.9	43.1	52.3	63.3	72.2	76.9	75.3	69.5	59.3	48.3	37.7
Schenectady, N. Y.	H	488.2	753.5	1026.6	1272.3	1553.1	1687.8	1662.3	1494.8	1124.7	820.6	436.2	356.8
	K _t	0.406	0.441	0.433	0.413	0.438	0.448	0.454	0.458	0.426	0.420	0.309	0.331
	t ₀	24.7	24.6	34.9	48.3	61.7	70.8	76.9	73.7	64.6	53.1	40.1	28.0
Seattle, Wash	H	282.6	520.6	992.2	1507	1881.5	1909.9	2110.7	1688.5	1211.8	702.2	386.3	239.5
	K _t	0.296	0.355	0.456	0.510	0.538	0.508	0.581	0.533	0.492	0.407	0.336	0.292
	t ₀	42.1	45.0	48.9	54.1	59.8	64.4	68.4	67.9	63.3	58.3	48.4	44.4
Seattle, Wash	H	252	471.6	917.3	1375.6	1664.9	1724	1805.1	1617	1129.1	638	325.5	218.1
	K _t	0.266	0.324	0.423	0.468	0.477	0.459	0.498	0.511	0.459	0.372	0.284	0.269
	t ₀	38.9	42.9	46.9	51.9	58.1	62.8	67.2	66.7	61.6	54.0	45.7	41.5
Seabrook, N. J.	H	591.9	854.2	1195.6	1518.8	1800.7	1964.6	1949.8	1715	1445.7	1071.9	721.8	522.5
	K _t	0.426	0.453	0.476	0.481	0.504	0.522	0.530	0.517	0.524	0.508	0.449	0.416
	t ₀	39.5	37.6	43.9	54.7	64.9	74.1	79.8	77.7	69.7	61.2	48.5	39.3
Spokane, Wash.	H	446.1	837.6	1200	1864.6	2104.4	2226.5	2479.7	2076	1511	844.6	486.3	279
	K _t	0.478	0.579	0.556	0.602	0.603	0.593	0.684	0.656	0.616	0.494	0.428	0.345
	t ₀	26.5	31.7	40.5	49.2	57.9	64.6	73.4	71.7	62.7	51.5	37.4	30.5
State College, Pa.	H	501.8	749.1	1106.6	1399.2	1754.6	2027.6	1968.2	1590	1338.1	1017	580.1	443.9
	K _t	0.381	0.413	0.451	0.448	0.493	0.539	0.536	0.512	0.492	0.496	0.379	0.376
	t ₀	31.3	31.4	39.8	51.3	63.4	71.8	75.8	73.4	66.1	55.6	43.2	32.6
Stillwater, Okla.	H	763.8	1081.5	1463.8	1702.6	1879.3	2235.8	2244.3	2039.1	1724.3	1314	991.5	783
	K _t	0.484	0.527	0.555	0.528	0.523	0.596	0.604	0.607	0.599	0.581	0.548	0.544
	t ₀	41.2	45.6	53.8	64.2	71.6	81.1	85.9	85.9	77.5	67.6	52.6	43.9
Tampa, Fla.	H	1223.6	1461.2	1771.9	2016.2	2228	2146.5	1991.9	1845.4	1687.8	1493.3	1328.4	1119.5
	K _t	0.605	0.600	0.606	0.602	0.620	0.583	0.548	0.537	0.546	0.572	0.590	0.589
	t ₀	64.2	65.7	68.8	74.3	79.4	83.0	84.0	84.4	82.9	77.2	69.6	65.6

Appendix A (Continued)

		Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
Toronto, Ontario	H	451.3	674.5	1088.9	1388.2	1785.2	1941.7	1968.6	1622.5	1284.1	835	458.3	352.8
Lat. 43°41'N.....	K _t	0.388	0.406	0.467	0.455	0.506	0.516	0.539	0.500	0.493	0.438	0.336	0.348
El. 379 ft	t _o	26.5	26.0	34.2	46.3	58	68.4	73.8	71.8	64.3	52.6	40.9	30.2
Tucson, Arizona	H	1171.9	1453.8	-	2434.7	-	2601.4	2292.2	2179.7	2122.5	1640.9	1322.1	1132.1
Lat. 32°07'N.....	K _t	0.648	0.646	-	0.738	-	0.698	0.625	0.640	0.710	0.672	0.650	0.679
El. 2556 ft	t _o	53.7	57.3	82.3	69.7	78.0	87.0	90.1	87.4	84.0	73.9	62.5	56.1
Upton, N. Y.	H	583	872.7	1280.4	1609.9	1891.5	2159	2044.6	1789.6	1472.7	1102.6	686.7	551.3
Lat. 40°52'N.....	K _t	0.444	0.483	0.522	0.514	0.532	0.574	0.557	0.542	0.542	0.538	0.448	0.467
El. 75 ft	t _o	35.0	34.9	43.1	52.3	63.3	72.2	78.9	75.3	69.5	59.3	48.3	37.7
Washington, D. C. (WBCO)..	H	632.4	901.5	1255	1600.4	1846.8	2080.8	1929.9	1712.2	1446.1	1083.4	763.5	594.1
Lat. 38°51'N.....	K _t	0.445	0.470	0.496	0.504	0.516	0.553	0.524	0.516	0.520	0.506	0.464	0.460
El. 64 ft	t _o	38.4	39.6	48.1	57.5	67.7	76.2	79.9	77.9	72.2	60.9	50.2	40.2
Winnipeg, Man.	H	488.2	835.4	1354.2	1641.3	1904.4	1962	2123.8	1761.2	1190.4	767.5	444.6	345
Lat. 49°54'N.....	K _t	0.601	0.636	0.661	0.574	0.550	0.524	0.587	0.567	0.504	0.482	0.436	0.503
El. 786 ft	t _o	3.2	7.1	21.3	40.9	55.9	65.3	71.9	69.4	58.6	45.6	25.2	10.1

Appendix B

AVERAGE EARTH TEMPERATURE FOR
UNDERGROUND HEAT DISTRIBUTION SYSTEM DESIGN

The following list presents the average earth temperature from 0 to 10 feet below the surface for the four seasons of the year and for the whole year for the indicated locals. The temperatures were computed on the basis of the method described in the 1965 ASHRAE technical paper entitled "Earth Temperature and Thermal Diffusivity at Selected Stations in the United States" by T. Kusuda and P. R. Achenbach (in ASHRAE Transactions, Volume 71, Part I, p. 61, 1965) using the monthly average air temperatures published by the U.S. Weather Bureau for the listed localities in the United States. Earth temperatures are expressed in fahrenheit degrees.

Location	Month	Winter 12,1,2	Spring 3,4,5	Summer 6,7,8	Autumn 9,10,11	Annual
Alabama						
Anniston AP ^a		55.	58.	70.	67.	63.
Birmingham AP		54.	58.	71.	68.	63.
Mobile AP		61.	63.	74.	71.	67.
Mobile CO ^b		61.	64.	75.	72.	68.
Montgomery AP		58.	61.	73.	70.	65.
Montgomery CO		59.	62.	74.	71.	66.
Arizona						
Bisbee COOP ^c		55.	58.	70.	67.	62.
Flagstaff AP		35.	39.	54.	50.	45.
Ft Huachuca (proving ground)		55.	58.	71.	68.	63.
Phoenix AP		60.	64.	79.	75.	69.
Phoenix CO		61.	65.	80.	76.	70.
Prescott AP		46.	49.	65.	61.	55.
Tucson AP		59.	62.	76.	73.	68.
Winslow AP		45.	49.	65.	61.	55.
Yuma AP		65.	69.	84.	80.	75.
Arkansas						
Fort Smith AP		52.	56.	72.	68.	62.
Little Rock AP		53.	57.	72.	68.	62.
Texarkana AP		56.	60.	74.	71.	65.
California						
Bakersfield AP		56.	60.	74.	70.	65.
Beaumont CO		53.	56.	67.	64.	60.
Bishop AP		47.	51.	65.	61.	56.
Blue Canyon AP		43.	46.	58.	55.	50.
Burbank AP		58.	60.	68.	66.	63.
Eureka CO		50.	51.	54.	54.	52.
Fresno AP		54.	58.	72.	68.	63.
Los Angeles AP		58.	59.	64.	63.	61.
Los Angeles CO		60.	61.	68.	66.	64.

Location	Winter	Spring	Summer	Autumn	Annual
California					
Mount Shasta CO	41.	44.	57.	54.	49.
Oakland AP	53.	54.	60.	59.	56.
Red Bluff AP	54.	58.	72.	69.	63.
Sacramento AP	53.	56.	67.	64.	60.
Sacramento CO	54.	57.	68.	65.	61.
Sandberg CO	47.	50.	63.	60.	55.
San Diego AP	59.	60.	66.	65.	62.
San Francisco AP	53.	54.	59.	57.	56.
San Francisco CO	55.	55.	59.	58.	57.
San Jose COOP	55.	57.	64.	62.	59.
Santa Catalina AP	57.	58.	64.	62.	60.
Santa Maria AP	54.	55.	60.	59.	57.
Colorado					
Alamosa AP	30.	35.	52.	48.	41.
Colorado Springs AP	39.	43.	59.	55.	49.
Denver AP	39.	43.	60.	56.	50.
Denver CO	41.	45.	61.	58.	51.
Grand Junction AP	39.	44.	65.	60.	52.
Pueblo AP	41.	45.	62.	58.	51.
Connecticut					
Bridgeport AP	40.	44.	61.	57.	50.
Hartford AP	39.	43.	61.	57.	50.
Hartford AP (Brainer)	39.	43.	60.	56.	50.
New Haven AP	40.	44.	60.	56.	50.
Delaware					
Wilmington AP	44.	48.	64.	60.	54.
Washington, D.C.					
Washington AP	47.	51.	66.	63.	56.
Washington CO	47.	51.	66.	63.	57.
Silver Hill OBS ^d	46.	50.	65.	61.	55.
Florida					
Apalachicola CO	63.	65.	75.	73.	69.
Daytona Beach AP	65.	67.	75.	74.	70.
Fort Myers AP	70.	71.	78.	76.	74.
Jacksonville AP	63.	66.	75.	73.	69.
Jacksonville CO	64.	66.	76.	73.	70.
Key West AP	74.	75.	80.	79.	77.
Key West CO	75.	76.	81.	79.	78.
Lakeland CO	68.	69.	77.	75.	72.
Melbourne AP	68.	70.	77.	75.	72.
Miami AP	72.	74.	79.	78.	76.
Miami CO	72.	73.	78.	77.	75.
Miami Beach COOP	74.	75.	80.	78.	77.
Orlando AP	68.	70.	77.	75.	72.

Location	Winter	Spring	Summer	Autumn	Annual
Florida					
Pensacola CO	62.	64.	74.	72.	68.
Tallahassee AP	61.	64.	74.	72.	68.
Tampa AP	68.	69.	77.	75.	72.
West Palm Beach	71.	73.	79.	77.	75.
Georgia					
Albany AP	60.	63.	75.	72.	67.
Athens AP	54.	58.	71.	68.	63.
Atlanta AP	54.	57.	70.	67.	62.
Atlanta CO	54.	57.	70.	67.	62.
Augusta AP	56.	59.	72.	69.	64.
Columbus AP	56.	59.	72.	69.	64.
Macon AP	58.	61.	74.	71.	66.
Rome AP	53.	56.	70.	67.	61.
Savannah AP	60.	63.	74.	71.	67.
Thomasville CO	62.	64.	74.	72.	68.
Valdosta AP	61.	64.	74.	72.	68.
Idaho					
Boise AP	40.	44.	62.	58.	51.
Idaho Falls 46 W	30.	35.	55.	50.	42.
Idaho Falls 42 N W	28.	33.	54.	49.	41.
Lewiston AP	42.	46.	63.	59.	52.
Pocatello AP	35.	40.	59.	55.	47.
Salmon CO	32.	37.	56.	52.	44.
Illinois					
Cairo CO	49.	53.	70.	65.	60.
Chicago AP	38.	43.	62.	57.	50.
Joliet AP	37.	42.	61.	56.	49.
Moline AP	38.	43.	62.	58.	50.
Peoria AP	39.	44.	63.	58.	51.
Springfield AP	41.	45.	64.	60.	52.
Springfield CO	43.	47.	66.	62.	54.
Indiana					
Evansville AP	47.	51.	67.	63.	57.
Fort Wayne AP	39.	43.	61.	57.	50.
Indianapolis AP	41.	46.	64.	59.	52.
Indianapolis CO	43.	48.	65.	61.	54.
South Bend AP	38.	42.	61.	56.	49.
Terre Haute AP	42.	47.	65.	60.	53.
Iowa					
Burlington AP	39.	44.	64.	59.	51.
Charles City CO	33.	38.	60.	55.	46.
Davenport CO	39.	44.	64.	59.	51.
Des Moines AP	37.	42.	63.	58.	50.
Des Moines CO	38.	43.	64.	59.	51.

Location	Winter	Spring	Summer	Autumn	Annual
Iowa					
Dubuque AP	34.	39.	60.	55.	47.
Sioux City AP	35.	40.	62.	57.	49.
Waterloo AP	35.	40.	61.	56.	48.
Kansas					
Concordia CO	42.	47.	67.	62.	54.
Dodge City AP	43.	48.	67.	62.	55.
Goodland AP	38.	43.	62.	57.	50.
Topeka AP	43.	47.	66.	62.	55.
Topeka CO	44.	49.	68.	63.	56.
Wichita AP	45.	50.	68.	64.	57.
Kentucky					
Bowling Green AP	47.	51.	67.	63.	57.
Lexington AP	44.	48.	65.	61.	54.
Louisville AP	46.	50.	67.	63.	56.
Louisville CO	47.	51.	67.	64.	57.
Louisiana					
Baton Rouge AP	61.	63.	74.	72.	67.
Burrwood CO	65.	67.	77.	74.	71.
Lake Charles AP	61.	64.	75.	73.	68.
New Orleans AP	63.	65.	75.	73.	69.
New Orleans CO	64.	66.	77.	74.	70.
Shreveport AP	58.	61.	75.	72.	66.
Maine					
Caribou AP	24.	29.	50.	45.	37.
Eastport CO	33.	37.	51.	48.	42.
Portland AP	33.	38.	56.	51.	44.
Maryland					
Baltimore AP	45.	49.	65.	61.	55.
Baltimore CO	47.	51.	67.	63.	57.
Frederick AP	44.	48.	65.	61.	55.
Massachusetts					
Boston AP	41.	44.	61.	57.	51.
Nantucket AP	41.	44.	57.	54.	49.
Plymouth field AP	34.	38.	55.	51.	44.
Worcester AP	36.	40.	58.	54.	47.
Michigan					
Alpena CO	33.	37.	54.	50.	43.
Detroit Willow Run AP	38.	42.	60.	56.	49.
Detroit City AP	38.	43.	60.	56.	49.
Escanaba CO	30.	35.	53.	49.	42.
Flint AP	36.	40.	58.	54.	47.
Grand Rapids AP	36.	40.	58.	54.	47.

Location	Winter	Spring	Summer	Autumn	Annual
Michigan					
Grand Rapids CO	38.	42.	60.	56.	49.
East Lansing CO	36.	40.	58.	54.	47.
Marquette CO	31.	35.	53.	49.	42.
Muskegon AP	36.	40.	57.	53.	47.
Sault Ste Marie AP	28.	32.	51.	47.	39.
Minnesota					
Crookston COOP	25.	31.	55.	49.	40.
Duluth AP	25.	30.	52.	47.	38.
Duluth CO	26.	31.	52.	47.	39.
International Falls	22.	27.	51.	45.	36.
Minneapolis AP	32.	37.	60.	54.	46.
Rochester AP	31.	36.	58.	53.	44.
Saint Cloud AP	28.	33.	56.	51.	42.
Saint Paul AP	32.	37.	60.	54.	46.
Mississippi					
Jackson AP	57.	61.	73.	70.	65.
Meridian AP	57.	60.	72.	69.	64.
Vicksburg CO	58.	61.	74.	71.	66.
Missouri					
Columbia AP	43.	48.	66.	62.	55.
Kansas City AP	44.	49.	68.	64.	56.
Saint Joseph AP	42.	47.	67.	62.	54.
Saint Louis AP	45.	49.	67.	63.	56.
Saint Louis CO	46.	50.	68.	64.	57.
Springfield AP	45.	49.	66.	62.	56.
Montana					
Billings AP	35.	40.	59.	55.	47.
Butte AP	27.	31.	50.	45.	38.
Glasgow AP	27.	33.	56.	51.	42.
Glasgow CO	28.	34.	57.	52.	43.
Great Falls AP	34.	38.	56.	52.	45.
Harve CO	31.	36.	57.	52.	44.
Helena AP	31.	36.	55.	50.	43.
Helena CO	32.	36.	55.	50.	43.
Kalispell AP	32.	37.	54.	50.	43.
Miles City AP	32.	37.	59.	54.	45.
Missoula AP	33.	37.	56.	51.	44.
Nebraska					
Grand Island AP	38.	43.	64.	59.	51.
Lincoln AP	39.	44.	64.	60.	52.
Lincoln CO University	40.	45.	65.	61.	53.
Norfolk AP	35.	40.	62.	57.	48.
North Platte AP	37.	42.	62.	57.	49.
Omaha AP	39.	44.	65.	60.	52.

Location	Winter	Spring	Summer	Autumn	Annual
Nebraska					
Scottbluff AP	36.	41.	60.	56.	48.
Valentine CO	35.	40.	61.	56.	48.
Nevada					
Elko AP	34.	39.	57.	53.	46.
Ely AP	35.	39.	56.	52.	45.
Las Vegas AP	56.	60.	78.	74.	67.
Reno AP	40.	44.	58.	55.	49.
Tonopah	41.	45.	61.	57.	51.
Winnemucca AP	38.	42.	60.	56.	49.
New Hampshire					
Concord AP	33.	38.	56.	52.	45.
Mt Washington COOP	17.	21.	37.	33.	27.
New Jersey					
Atlantic City CO	45.	49.	63.	60.	54.
Newark AP	43.	47.	63.	59.	53.
Trenton CO	43.	47.	64.	60.	53.
New Mexico					
Albuquerque AP	46.	50.	67.	63.	57.
Clayton AP	43.	47.	63.	59.	53.
Raton AP	38.	42.	58.	54.	48.
Roswell AP	51.	54.	69.	66.	60.
New York					
Albany AP	36.	40.	59.	54.	47.
Albany CO	38.	43.	61.	56.	49.
Bear Mountain CO	38.	42.	59.	55.	48.
Binghamton AP	34.	38.	56.	52.	45.
Binghamton CO	38.	42.	59.	55.	48.
Buffalo AP	37.	41.	58.	54.	47.
New York AP (La Guardia)	44.	48.	64.	60.	54.
New York CO	44.	47.	63.	59.	53.
New York Central Park	44.	48.	64.	60.	54.
Oswego CO	36.	40.	58.	54.	47.
Rochester AP	37.	41.	58.	54.	47.
Schenectady COOP	35.	40.	59.	55.	47.
Syracuse AP	38.	42.	60.	56.	49.
North Carolina					
Asheville CO	48.	51.	64.	61.	56.
Charlotte AP	52.	55.	69.	66.	60.
Greensboro AP	49.	53.	67.	64.	58.
Hatteras CO	56.	59.	70.	68.	63.
Raleigh AP	51.	55.	69.	65.	60.
Raleigh CO	52.	56.	70.	66.	61.
Wilmington AP	56.	59.	71.	69.	64.
Winston Salem AP	50.	53.	67.	64.	58.

Location	Winter	Spring	Summer	Autumn	Annual
North Dakota					
Bismarck AP	27.	33.	56.	51.	42.
Devils Lake CO	24.	29.	54.	48.	39.
Fargo AP	26.	32.	56.	50.	41.
Minot AP	25.	31.	54.	49.	39.
Williston CO	27.	33.	56.	50.	41.
Ohio					
Akron-Canton AP	39.	43.	60.	56.	50.
Cincinnati AP	43.	47.	64.	60.	54.
Cincinnati CO	46.	50.	66.	63.	56.
Cincinnati ABBE OBS	45.	49.	65.	61.	55.
Cleveland AP	40.	44.	61.	57.	51.
Cleveland CO	41.	45.	62.	58.	51.
Columbus AP	41.	46.	62.	59.	52.
Columbus CO	43.	47.	64.	60.	53.
Dayton AP	42.	46.	63.	59.	52.
Sandusky CO	41.	45.	62.	58.	51.
Toledo AP	38.	43.	60.	56.	49.
Youngstown AP	39.	43.	60.	56.	50.
Oklahoma					
Oklahoma City AP	50.	54.	71.	67.	60.
Oklahoma City CO	50.	55.	71.	68.	61.
Tulsa AP	50.	54.	71.	67.	61.
Oregon					
Astoria AP	47.	48.	56.	54.	51.
Baker CO	36.	40.	56.	52.	46.
Burns CO	36.	40.	58.	54.	47.
Eugene AP	46.	48.	59.	57.	52.
Meacham AP	34.	38.	52.	49.	43.
Medford AP	46.	49.	62.	59.	54.
Pendleton AP	42.	46.	63.	59.	53.
Portland AP	46.	49.	60.	57.	53.
Portland CO	48.	50.	61.	59.	55.
Roseburg AP	47.	49.	60.	57.	53.
Roseburg CO	48.	51.	61.	59.	55.
Salem AP	46.	49.	60.	57.	53.
Sexton Summit	42.	44.	55.	52.	48.
Troutdale AP	45.	48.	59.	57.	52.
Pennsylvania					
Allentown AP	40.	44.	62.	58.	51.
Erie AP	38.	42.	58.	55.	48.
Erie CO	40.	44.	60.	56.	50.
Harrisburg AP	43.	47.	63.	59.	53.
Park Place CO	36.	40.	57.	53.	46.
Philadelphia AP	44.	48.	64.	61.	54.
Philadelphia CO	46.	50.	66.	62.	56.
Pittsburgh Allegheny	42.	46.	62.	58.	52.

Location	Winter	Spring	Summer	Autumn	Annual
Pennsylvania					
Pittsburgh GRTR PITT	40.	44.	61.	57.	51.
Pittsburgh CO	44.	48.	64.	60.	54.
Reading CO	43.	47.	64.	60.	54.
Scranton CO	40.	44.	61.	57.	50.
Wilkes Barre-Scranton	39.	43.	60.	56.	49.
Williamsport AP	40.	44.	61.	57.	51.
Rhode Island					
Block Island AP	41.	45.	59.	55.	50.
Providence AP	39.	43.	59.	56.	49.
Providence CO	41.	45.	62.	58.	51.
South Carolina					
Charleston AP	58.	61.	72.	70.	65.
Charleston CO	60.	62.	74.	71.	67.
Columbia AP	56.	59.	72.	69.	64.
Columbia CO	57.	60.	72.	69.	64.
Florence AP	55.	59.	72.	69.	64.
Greenville AP	53.	56.	69.	66.	61.
Spartanburg AP	53.	56.	70.	66.	61.
South Dakota					
Huron AP	31.	37.	60.	55.	46.
Rapid City AP	34.	39.	58.	54.	46.
Sioux Falls AP	32.	37.	60.	55.	46.
Tennessee					
Bristol AP	48.	51.	65.	62.	56.
Chattanooga AP	51.	55.	69.	65.	60.
Knoxville AP	50.	54.	68.	65.	59.
Memphis AP	52.	56.	71.	68.	62.
Memphis CO	53.	57.	72.	68.	62.
Nashville AP	51.	54.	69.	66.	60.
Oak Ridge CO	49.	52.	67.	64.	58.
Oak Ridge 8 S	49.	52.	67.	64.	58.
Texas					
Abilene AP	55.	58.	73.	70.	64.
Amarillo AP	47.	50.	67.	63.	57.
Austin AP	60.	63.	76.	73.	68.
Big Springs AP	56.	59.	74.	70.	65.
Brownsville AP	68.	70.	79.	77.	74.
Corpus Christi AP	65.	68.	78.	76.	72.
Dallas AP	57.	61.	76.	72.	66.
Del Rio AP	62.	65.	77.	75.	70.
El Paso AP	54.	58.	72.	69.	63.
Fort Worth AP (Amon Carter)	57.	60.	75.	72.	66.
Galveston AP	63.	66.	77.	74.	70.

Location	Winter	Spring	Summer	Autumn	Annual
Texas					
Galveston CO	63.	66.	77.	74.	70.
Houston AP	62.	65.	76.	73.	69.
Houston CO	63.	66.	77.	74.	70.
Laredo AP	67.	70.	81.	79.	74.
Lubbock AP	50.	54.	69.	65.	59.
Midland AP	55.	59.	73.	70.	64.
Palestine CO	58.	62.	74.	71.	66.
Port Arthur AP	61.	64.	75.	72.	68.
Port Arthur CO	63.	65.	76.	74.	69.
San Angelo AP	58.	61.	74.	71.	66.
San Antonio AP	61.	64.	77.	74.	69.
Victoria AP	64.	67.	78.	76.	71.
Waco AP	58.	62.	76.	73.	67.
Wichita Falls AP	53.	57.	73.	69.	63.
Utah					
Blanding CO	39.	43.	60.	56.	50.
Milford AP	37.	42.	61.	56.	49.
Salt Lake City AP	40.	44.	63.	59.	51.
Salt Lake City CO	41.	46.	65.	60.	53.
Vermont					
Burlington AP	32.	37.	57.	52.	44.
Virginia					
Cape Henry CO	51.	55.	68.	65.	60.
Lynchburg AP	48.	51.	66.	62.	57.
Norfolk AP	51.	54.	68.	64.	59.
Norfolk CO	52.	56.	69.	66.	61.
Richmond AP	48.	52.	67.	63.	58.
Richmond CO	50.	53.	68.	64.	59.
Roanoke AP	48.	51.	66.	62.	57.
Washington					
Ellensburg AP	37.	41.	59.	55.	48.
Kelso 'P	45.	47.	57.	54.	51.
North Head L H RESVN	47.	49.	54.	53.	51.
Olympia AP	44.	46.	56.	54.	50.
Omak 2 mi N W	36.	40.	59.	55.	47.
Port Angeles AP	45.	46.	53.	52.	49.
Seattle AP (Boeing Field)	46.	48.	58.	56.	52.
Seattle CO	47.	50.	59.	57.	53.
Seattle-Tacoma AP	44.	47.	57.	55.	51.
Spokane AP	37.	41.	58.	54.	47.
Stampede Pass	32.	35.	48.	45.	40.
Tacoma CO	46.	48.	58.	55.	52.
Tattosh Island CO	46.	47.	52.	51.	49.
Walla Walla CO	44.	48.	65.	61.	54.
Yakima AP	40.	44.	61.	57.	50.

Location	Winter	Spring	Summer	Autumn	Annual
West Virginia					
Charleston AP	47.	50.	65.	61.	56.
Elkins AP	41.	45.	59.	56.	50.
Huntington CO	48.	52.	67.	63.	57.
Parkersburg CO	45.	49.	65.	61.	55.
Petersburg CO	44.	48.	63.	60.	54.
Wisconsin					
Green Bay AP	31.	36.	56.	51.	44.
La Crosse AP	32.	38.	60.	55.	46.
Madison AP	34.	39.	59.	54.	47.
Madison CO	34.	39.	60.	55.	47.
Milwaukee AP	35.	40.	58.	54.	47.
Milwaukee CO	36.	41.	59.	55.	48.
Wyoming					
Casper AP	34.	38.	57.	52.	45.
Cheyenne AP	35.	39.	55.	51.	45.
Lander AP	31.	35.	56.	51.	43.
Rock Springs AP	31.	35.	54.	50.	42.
Sheridan AP	33.	37.	56.	52.	44.
Hawaii					
Hilo AP	72.	72.	74.	74.	73.
Honolulu AP	74.	75.	77.	77.	76.
Honolulu CO	74.	74.	77.	76.	75.
Lihue AP	72.	73.	76.	75.	74.
Alaska					
Anchorage AP	25.	29.	46.	42.	35.
Annette AP	40.	42.	51.	49.	46.
Barrow AP	4.	7.	16.	14.	10.
Bethel AP	18.	23.	41.	37.	30.
Cold Bay AP	33.	35.	43.	41.	38.
Cordova AP	32.	35.	45.	43.	39.
Fairbanks AP	14.	19.	38.	34.	26.
Galena AP	13.	18.	37.	33.	25.
Gambell AP	15.	19.	34.	30.	24.
Juneau AP	34.	36.	47.	45.	41.
Juneau CO	36.	39.	49.	46.	42.
King Salmon AP	25.	28.	44.	40.	34.
Kotzebue AP	10.	14.	31.	27.	21.
McGrath AP	14.	18.	37.	33.	25.
Nome AP	16.	20.	37.	33.	26.
Northway AP	12.	16.	32.	29.	22.
Saint Paul Island AP	31.	32.	40.	38.	35.
Yakutat AP	33.	36.	45.	43.	39.
West Indies					
Ponce Santa Isabel AP	75.	76.	78.	78.	77.
San Juan AP	77.	77.	79.	79.	78.

Location	Winter	Spring	Summer	Autumn	Annual
West Indies					
San Juan CO	77.	77.	79.	79.	78.
Swan Island	80.	80.	82.	81.	81.
Virgin Islands					
St Croix, V.I. AP	78.	78.	81.	80.	79.
Pacific Islands					
Canton Island AP	83.	84.	84.	84.	84.
Koror	81.	81.	81.	81.	81.
Ponape Island AP	81.	81.	81.	81.	81.
Truk Moen Island	81.	81.	81.	81.	81.
Wake Island AP	79.	79.	81.	81.	80.
Yap	81.	81.	82.	82.	82.

^aAP = Airport data.

^bCO = City office data.

^cCOOP = Cooperative weather station.

^dOBS = Observation station.

Appendix C

Fortran Listing of the Computer Program

<u>Subroutine Name</u>	<u>Subroutine Description</u>	<u>Page</u>
MAIN	Main program	C-1
HCLD	Heating and cooling load determination	C-3
SOLDAT	Solar radiation data (Liu-Jordan)	C-15
ZD	A subroutine of SOLDAT	C-18
F	Slab-on-grade perimeter heat loss (unused)	C-19
SAT	Sol-air temperature	C-20
ATTIC	Attic air temperature	C-21
CRAWL	Crawl space air temperature	C-22
GF	Ground floor heat loss	C-23
SLABR	Slab-on-grade thermal resistance	C-24
GAMMAR	A subroutine of SLABR	C-26
BSMT	Basement temperature	C-27
QECHG	Opaque envelope (wall, roof) heat transfer	C-28
QG	Window heat gain	C-29
INFIL	Infiltration rate	C-30
QI	Infiltration heat gain	C-31
DBRH	A psychrometric routine	C-32
PVSF	A psychrometric routine	C-33
QR	Internal heat gain	C-34
HLHG	Building heat loss and heat gain	C-35
THTCX	Thermal time constant	C-38
HCRT	Heating and cooling requirement	C-39
SEU	Solar energy utilization	C-40
EREQ	Energy requirement	C-41
HWHREQ	Hot water heating requirement	C-43

(continued)

2

<u>Subroutine Name</u>	<u>Subroutine Description</u>	<u>Page</u>
CSDUPI	Duct and pipe heat loss in a crawl space	C-44
ASDUPI	Duct and pipe heat loss in an attic	C-45
BMDUPI	Duct and pipe heat loss in a basement	C-46
OSDUPI	Heat loss from outside duct and pipe	C-47
ZKDN	Building heat transfer factor	C-48
PSY2	A psychrometric routine	C-49
WBF	A psychrometric routine	C-40
DEGDAY	Energy analysis by the degree day method	C-51
LINT	Linear interpolation subroutine	C-52
MAX	Maximum value	C-53
MIN	Minimum value	C-54
	Sample run	C-55

020202*CONSP6(1).MAIN(23)

```

1 C THIS IS THE HOME ENERGY AUDIT PROGRAM OF NBS
2 C CALCULATION PROCEDURES ARE BASED ON THE MONTHLY NORMAL WEATHER DATA AND ON THE
3 C VARIABLE DEGREE DAY METHODS. DETAILS OF THE ALGORITHM ARE GIVEN IN
4 C NBSIR 80-1961 ENTITLED "SIMPLIFIED HEATING AND COOLING ENERGY CALCULATIONS
5 C FOR RESIDENTIAL APPLICATIONS" BY T. KUSUDA AND TOMONORI SAITOH.
6 C
7 DIMENSION B(350),R(50),HLHWH1(12),HLHWH2(12),SAVE(12)
8 1,QQC(12),QQH(12),WHREQ(12),CDEC(16),HDEC(16),TOD(12),TON(12)
9 DIMENSION TOWN(4)/' WASHI','NGTON','DC','/'
10 DIMENSION HOUSE(4)/' HASTI','NCS HO','USE','/'
11 C HRDAY DAYTIME HOURS
12 C HRNIT NIGHTTIME HOURS
13 C CDEC COOLING DEGREE DAYS FOR BASE 45 THROUGH 60 DEC F
14 C HDEC HEATING DEGREE DAYS FOR BASE 45 THROUGH 60 DEC F
15 COMMON/HR/HRDAY(12),HRNIT(12)
16 C DATA DEFINITIONS ARE IN THE SUBROUTINE HCLD
17 C B(1),I=1,337 : INPUT
18 C R(1),I=1,50 : OUTPUT
19 DATA (B(1),I=1,153)/
20 * 9600.0,0.5,38.4,39.6,48.1,57.5,67.7,76.2,79.9, 1-9
21 *77.9,72.2,60.9,50.2,40.2,35.6,37.3,45.1,56.4, 10-18
22 *66.2,74.6,78.7,77.1,70.6,59.8,48.3,37.4,70.7,70.7,78.7,78.7, 19-33
23 *78.7,78.7,70.7,70.7,65.6,65.6,65.6,65.6,78.7,78.7,78.7,78.7,65.6,65.6, 34-49
24 *65.6,1.-9999.-9999.9.9. 50-54
25 *10.4,10.9,10.5,9.2,8.7,8.1,6.0,8.2,8.5, 55-63
26 *9.2,9.4,-9999.-9999.180.0,38.5,0.2,20234.55.10, 64-72
27 *0.80,1.13,0.0,270.0,0.0,0.0,0.10,0.0,0.0, 73-81
28 *72.00,0.80,1.13,0.0,90.0,0.0,0.0,0.1,0.0, 82-90
29 *90.0,75.1,0.70,0.70,0.70,0.70,0.70,0.70,0.70, 91-99
30 *70.0,70.0,70.0,70.0,70.0,70.0,70.0,0.0,0.0,1.0, 100-108
31 *10.0,0.0,0.9,-9999.-9999.-9999.-9999.-9999.-9999., 109-117
32 *-9999.-9999.-9999.-9999.-9999.-9999.-9999.-9999.0.100,244.9,1.0, 118-126
33 *10.0,9.1,240.1,10.0,9.1,248.1,10.0,9.1,240.1, 127-144
34 *0.0,0.0,80.60,0.0,0.0,0.9,0.2,0.625/ 145-153
35 DATA (B(1),I=154,314)/
36 *1.0,1.0,-9999.37.5,3.0,0.05,0.4,-9999.0.1, 154-162
37 *75.0,6.0,9.0,1.0,1.0,140.0,60.0,62.0,64.0, 163-171
38 *66.0,67.0,68.0,67.0,66.0,65.0,64.0,62.0,61.0, 172-180
39 *0.0,0.0,0.0,0.0,0.0,1.79,3.0,116.4,260.4, 181-189
40 *846.0,508.8,1200.0,1200.0,1.0,3.0,0.164,0.0,1.0, 190-198
41 *0.1,0.0,20.0,1.0,500.500.1,0.0,516.0,553, 199-207
42 *0.524,0.516,0.520,0.506,0.464,0.460,632.4,901.5,1255.0, 208-216
43 *1600.4,1846.8,2080.8,1929.9,1712.2,1446.1,1083.4,763.5,594.1, 217-225
44 *0.67,-9999.-9999.-9999.-9999.-9999.2.1,-9999.-9999., 226-234
45 *-9999.-9999.-9999.-9999.-9999.-9999.2.0,20.0,20.0,20.0, 235-243
46 *20.0,20.0,60.0,60.0,60.0,60.0,20.0,20.0,20.0, 244-252
47 *20.0,20.0,20.0,20.0,20.0,60.0,60.0,60.0,60.0, 253-261
48 *20.0,20.0,20.0,69.0,67.0,68.0,68.0,72.0,73.0, 262-270
49 *75.0,79.0,80.0,79.0,73.0,71.0,54.0,52.0,49.0, 271-279
50 *47.0,51.0,52.0,52.0,54.0,55.0,51.0,52.0,57.0, 280-288
51 *-9999.0.0,0.9,0.49,20.0,-9999.0.0,0.0,0.0, 289-297
52 *0.0,-9999.0.0,0.0,0.0,0.0,0.0,-9999.0.0,0.0, 298-306
53 Z0.46,0.0,1.0,40.0,0.08,0.025,0.0,0.0,0.0/ 307-314
54 DATA (B(1),I=315,337)/
55 162.0,41.0,140.0,176.0, 315-316
56 2100.0,0.57,0.0,1.46, 319-322
57 30.0,0.57,0.0,1.46, 323-326

```

```

58 4100.0,0.57,0.0,1.46,
59 50.0,1.46,0.0,4.10,10.0,0.0,64000.0/
60 DATA CDEG/2251.,2084.,1927.,1773.,1626.,1483.,1346.,1210.,1078.,
61 *953.,830.,718.,615.,520.,427.,344./,HDEC/B27.,936.,1052.,1174.,
62 *1298.,1430.,1568.,1714.,1861.,2018.,2185.,2359.,2537.,2722.,2911.,
63 *3107./
64 DO 100 I=1,4
65 B(I+337)=TOWN(I)
66 100 B(I+341)=HOUSE(I)
67 CALL RCLD(B,R,HLHWH1,HLHWH2,SAVE,QQC,QQH,WHREQ,THT,TCT)
68 TBTU=R(2)-R(1)
69 WRITE(6,1000) (R(I),I=1,2)
70 WRITE(6,1010) TBTU
71
72 C
73 C VARIABLE DEGREE DAY METHOD CALCULATION
74 CALL DEGDAY(R,CDEG,HDEC,THT,TCT)
75 SUM1=0.0
76 SUM2=0.0
77 SUM3=0.0
78 SUM4=0.0
79 SUM5=0.0
80 SUM6=0.0
81 SUM7=0.0
82 DO 200 I=1,12
83 SUM1=SUM1+HLHWH1(I)
84 SUM2=SUM2+HLHWH2(I)
85 SUM3=SUM3+SAVE(I)
86 SUM4=SUM4+WHREQ(I)
87 SUM5=SUM5+QQC(I)
88 SUM6=SUM6+QQH(I)
89 SUM7=SUM7-SUM2
90 200 CONTINUE
91 WRITE(6,1001) SUM1
92 1001 FORMAT(1H,'ANNUAL HEAT LOSS THROUGH NON-ADDITIONAL JACKET INSULA
93 TION OF HOT WATER TANK : ',G10.4)
94 WRITE(6,1002) SUM2
95 1002 FORMAT(1H,'ANNUAL HEAT LOSS THROUGH ADDITIONAL JACKET INSULATION
96 OF HOT WATER TANK : ',G10.4)
97 WRITE(6,1003) SUM3
98 1003 FORMAT(1H,'ANNUAL ENERGY SAVING BY ADDITIONAL INSULATION OF HOT W
99 ATER TANK : ',G10.4)
100 WRITE(6,1004) SUM4
101 1004 FORMAT(1H,'ANNUAL HOT WATER REQUIREMENT,INCLUDING JACKET HEAT LOS
102 S : ',G10.4)
103 WRITE(6,1005) SUM7
104 1005 FORMAT(1H,'ANNUAL HOT WATER REQUIREMENT,EXCLUDING JACKET HEAT LOS
105 S : ',G10.4)
106 WRITE(6,1006) SUM5
107 1006 FORMAT(1H,'ANNUAL HEAT GAIN THROUGH DUCTS & PIPES FOR SPACE COOLI
108 NG : ',G10.4)
109 WRITE(6,1007) SUM6
110 1007 FORMAT(1H,'ANNUAL HEAT LOSS THROUGH DUCTS & PIPES FOR SPACE HEATI
111 NG : ',G10.4)
112 1000 FORMAT(1H,'40X,'SHBTU = ',F15.0,5X,'SCBTU = ',F15.0)
113 1010 FORMAT(7H,TBTU=,F15.0)
114 STOP
END

```

030303*CONSP6(1).HCLD(5)

```

1      SUBROUTINE HCLD (B, R, HLHWH1, HLHWH2, SAVE, QQC, QQH, WHREQ, SUM1, SUM2)
2      C
3      C *****
4      C *****
5      C *****
6      C *****
7      C *****
8      C *****
9      COMMON/HR/HRDAY(12), HRNIT(12)
10     DIMENSION TOD(12), TON(12), TID(12), TIN(12), RINFIL(12),
11     1 RH(2,12), QISD(12), QISN(12), QILD(12), QILN(12),
12     2 XIDT(12), XIDD(12), QGD1(12), QCN1(12), QCD2(12), QCN2(12),
13     3 QCD3(12), QCN3(12), QCD4(12), QCN4(12), QCD(12), QCN(12),
14     4 QSC(12), SATD(12), SATN(12), GD1(12), CN1(12), GD2(12),
15     5 CN2(12), CD3(12), CN3(12), CD4(12), CN4(12), QDD(12),
16     6 QDN(12), QCD(12), QCN(12), FO(12), TWD1(12), TWN1(12),
17     7 ATD(12), ATN(12), QFD(12), QFN(12), CRAWLD(12), CRAWLN(12),
18     8 QRD(12), QRN(12), TOT(12), B(350), R(50),
19     9 QID(12), QIN(12), QTD(12), QTN(12), HC(12), HL(12),
20     A RLHC(12), HREQ(12), CREQ(12),
21     B QWD(12), QWN(12), ZT(12),
22     C TE(12), TC(12), H(12), BSMTD(12), BSMTN(12), TOWN(4)
23     D ,TWD2(12), TWN2(12), TWD(12), TWN(12)
24     DIMENSION DAYS(12)/31.,28.,31.,30.,31.,30.,31.,31.,30.,31.,30.,31.
25     */
26     DIMENSION XIDTS(12), XIDDS(12), XIDTW(12), XIDDW(12), XIDTN(12),
27     1 XIDDN(12), XIDTE(12), XIDDE(12), AA(32), BQFD(12), BQFN(12),
28     2 ATQCD(12), ATQCN(12), WHREQ(12), QDD1(12), QDN1(12), QDD2(12),
29     3 QDN2(12), QDD3(12), QDN3(12), QDD4(12), QDN4(12), XT901(12),
30     4 XD901(12), XT902(12), XD902(12), XT903(12), XD903(12), XT904(12),
31     5 XQ904(12), RHM(12), RHA(12), XX(12), WS(12), HLEWH1(12),
32     6 HLHWH2(12), SAVE(12), QC1(12), QC2(12), QC3(12), QC4(12),
33     7 SCD(12), QH1(12), QH2(12), QH3(12), QH4(12), QQC(12),
34     8 QQH(12), CFAC(12), HFAC(12), SCD1(12), SCD2(12), SCD3(12),
35     9 SCD4(12), ZK(12)
36     DATA AA/3HTID,3HTIN,3HTOD,3HTON,5HXIDTS,5HXIDDS,5HXIDTW,5HXIDDW,
37     1 5HXIDTN,5HXIDDN,5HXIDTE,5HXIDDE,3HQID,3HQIN,3HQWD,3HQWN,3HQDD,
38     2 3HQDN,3HQCD,3HQCN,3HQCD,3HQCN,3HQFD,3HQFN,3HQRD,3HQRN,3HQTD,3HQTN
39     3 ,5HHRDAY,5HHRNIT,3HSCD,2HZK/
40     DATA FO/6.,6.,5.,5.,4.,4.,5.,5.,5.,6./
41     V = B(1) @ (INFIL) VOLUME OF THE ROOM, FT3 L*W*H
42     ACHS = B(2) @ (INFIL) STD AIR CHANGE DATA, AC/HR
43     DO 10 I=1,12
44     TOD(I) = B(I+2) @ DAYTIME OUTDOOR TEMPERATURE TO
45     TOT(I) = B(I+14)
46     TON(I) = 2.*TOT(I)-TOD(I)
47     TID(I) = B(I+26) @ DAYTIME INDOOR TEMP RMDBS/W
48     10 TIN(I) = B(I+38) @ NIGHTTIME INDOOR TEMP RMDBS/W
49     IACNV=B(51)
50     DO 20 I=1,12
51     20 WS(I) = B(I+53) @ (INFIL) WIND SPEED, MPH
52     ORT1 = B(68) @ ORIENTATION (OS,90W,180N,270E) AZW
53     XLAT = B(69) @ LAT
54     RHO = B(70) @ (SOLDAT)
55     ZIP = B(71) @ (SOLDAT) NOT USED---ALPHANUMERIC TITLE
56     AC1 = B(72) @ (QC) CLASS AREA A
57     SC1 = B(73) @ (QC) SHADING COEFFICIENT SHADE

```

53	UC1	= B(74)	@	(QC)	HEAT TRANSFER COEFFICIENT U
59	SHDW1	= B(75)	@	(QC)	EXTERNAL SHADOW FACTOR SHDW
60	ORT2	= B(76)			
61	AC2	= B(77)			
62	SC2	= B(78)			
63	UC2	= B(79)			
64	SHDW2	= B(80)			
65	ORT3	= B(81)			
66	AC3	= B(82)			
67	SC3	= B(83)			
68	UC3	= B(84)			
69	SHDW3	= B(85)			
70	ORT4	= B(86)			
71	AC4	= B(87)			
72	SC4	= B(88)			
73	UC4	= B(89)			
74	SHDW4	= B(90)			
75	WLT1	= B(91)	@	(SOLDAT)	TILT ANGLE 0-90 DEG FROM HOR. SURF.
76	SA	= B(92)	@	(QS)	SOLAR COLLECTOR EFFICIENCY FACTORS
77	SB	= B(93)	@	(QS)	SOLAR COLLECTOR EFFICIENCY FACTORS
78	DO 30	I=1, 12			
79	30 TE(1)	= B(1+93)	@	(SEU, QS)	INLET FLUID TEMP. TO THE COLLECTOR
80	SUF	= B(106)	@	(SEU)	SOLAR HEAT UTILIZATION FACTOR
81	AS	= B(107)	@	(SEU)	COLLECTOR AREA, FT2
82	WALL11	= B(108)	@		ROOF OVERHANG OVER WALL
83	WALL12	= B(109)	@		HEIGHT OF WALL 1
84	WALL13	= B(110)	@	SHDW (QC, SAT)	EXTERNAL SHADOW FACTOR (0.0 - 1.0)
85	WALL14	= B(111)	@	AB (SAT)	SURFACE ABSORPTIVITY ABSP
86	WALL15	= B(124)	@	U (QECHC)	OVERALL HEAT TRANSFER COEFFICIENT
87	WALL16	= B(125)	@	A (QECHC)	AREA
88	WALL21	= B(126)	@		ROOF OVERHANG OVER WALL 2
89	WALL22	= B(127)	@		HEIGHT OF WALL 2
90	WALL23	= B(128)	@	SHDW	
91	WALL24	= B(129)	@	AB	
92	WALL25	= B(130)	@	U	
93	WALL26	= B(131)	@	A	
94	WALL31	= B(132)	@		ROOF OVERHANG OVER WALL 3
95	WALL32	= B(133)	@		HEIGHT OF WALL 3
96	WALL33	= B(134)	@	SHDW	
97	WALL34	= B(135)	@	AB	
98	WALL35	= B(136)	@	U	
99	WALL36	= B(137)	@	A	
100	WALL41	= B(138)	@		ROOF OVERHANG OVER WALL 4
101	WALL42	= B(139)	@		HEIGHT OF WALL 4
102	WALL43	= B(140)	@	SHDW	
103	WALL44	= B(141)	@	AB	
104	WALL45	= B(142)	@	U	
105	WALL46	= B(143)	@	A	
106	SOGFRC	= B(144)			
107	CRVFRC	= B(145)			
108	BSMFRC	= B(146)			
109	TIC	= B(147)			
110	TIN	= B(148)			
111	ROOF1	= B(150)	@	SHDW (SAT)	ATTICLESS
112	ROOF2	= B(151)	@	AB (SAT)	ATTICLESS
113	ROOF3	= B(152)	@	U / UR (QECHC/ATTIC)	ATTICLESS-WITH ATTIC
114	AEWH	= B(153)			
115	ISOLHW	= B(154)			

116 ISOLSH = B(155)
117 ROOF4 = B(149)
118 AW = B(157)
119 ACAT=B(158)
120 UCEIL = B(159) @ UC / U (ATTIC/QECHG) U-VALUE CLG / HTC UCELNG
121 AEW5 = B(160) @ UW / A (ATTIC/QECHG) U-VALUE WALL/AREA UENDW/A
122 UFLR1 = B(161) @ U (CF) FLOOR HEAT TRANSFER COEFF. (HTC)
123 BWT = B(163)
124 RSTART = B(164)
125 NLAST = B(165)
126 INDEXD = B(166)
127 INDEXC = B(167)
128 ZL = B(168) @ EXPOSED PERIMETER LENGTH OF THE FLOOR
129 DO 50 I=1,12
130 50 TG(I) = B(1+168) @ (CRAWL,CF) GROUND TEMP, SEASONAL TGS/TCW
131 ACCS=B(181)
132 UFLR2 = B(182) @ UF / U (CRAWL/QECHG) FLOOR HTC/OVERALL HTC U
133 UCLW = B(183) @ UW / U (CRAWL/QECHG) WALL HTC/OVERALL HTC U
134 HCL = B(184)
135 AWCL = B(185) @ AW / A (CRAWL/QECHG) CRAWL SPACE WALL AREA A
136 NPD = B(186) @ (QR) NO. DAYTIME OCCUPANTS QOCUP
137 NPN = B(187) @ (QR) NO. NIGHTTIME OCCUPANTS QOCUP
138 WTD = B(188) @ (QR) AVG. DAYTIME LIGHTING QLITX
139 WTN = B(189) @ (QR) AVG. NIGHTTIME LIGHTING QLITX
140 WED = B(190) @ (QR) AVG. DAYTIME EQUIPMENT QEQUX
141 WEN = B(191) @ (QR) AVG. NIGHTTIME EQUIPMENT QEQUX
142 FLOORA = B(192) @ AF (QR) FLOOR AREA
143 ATFLR = B(193)
144 UBW = B(194)
145 ISYS = B(195) @ (EREQ) SYSTEM INDEX
146 UFW = B(196)
147 BWA = B(197) @ (BSMT) BASEMENT WALL AREA
148 UBF = B(198)
149 UFF = B(199)
150 QBHG = B(200) @ (BSMT) HEAT GAIN FROM FURNACE, BOILER, ETC
151 THTC = B(201)
152 ZKS = B(202) @ (CF) GROUND THERMAL CONDUCTIVITY
153 DX = B(203) @ (CF) SIDE HOUSE DISTANCE
154 DY = B(204) @ (CF) FRONT HOUSE DISTANCE
155 E = B(205) @ (CF) WALL THICKNESS
156 DO 60 I=1,12
157 60 H(I) = B(1+213) @ (SOLDAT) DAILY TOTAL HORIZONTAL RADIATION
158 EH = B(226)
159 EC = B(232)
160 PUH=B(240) @ PICK UP HOURS
161 DO 80 I=1,12
162 RH(1,I) = B(1 + 240)
163 RH(2,I) = B(1 + 252)
164 80 CONTINUE
165 RHM(1) = B(265)
166 RHM(2) = B(266)
167 RHM(3) = B(267)
168 RHM(4) = B(268)
169 RHM(5) = B(269)
170 RHM(6) = B(270)
171 RHM(7) = B(271)
172 RHM(8) = B(272)
173 RHM(9) = B(273)

174	RHM(10) = B(274)
175	RHM(11) = B(275)
176	RHM(12) = B(276)
177	RHA(1) = B(277)
178	RHA(2) = B(278)
179	RHA(3) = B(279)
180	RHA(4) = B(280)
181	RHA(5) = B(281)
182	RHA(6) = B(282)
183	RHA(7) = B(283)
184	RHA(8) = B(284)
185	RHA(9) = B(285)
186	RHA(10) = B(286)
187	RHA(11) = B(287)
188	RHA(12) = B(288)
189	DOOR13=B(290)
190	DOOR14=B(291)
191	DOOR15=B(292)
192	DOOR16=B(293)
193	DOOR23=B(295)
194	DOOR24=B(296)
195	DOOR25=B(297)
196	DOOR26=B(298)
197	DOOR33=B(300)
198	DOOR34=B(301)
199	DOOR35=B(302)
200	DOOR36=B(303)
201	DOOR43=B(305)
202	DOOR44=B(306)
203	DOOR45=B(307)
204	DOOR46=B(308)
205	TOUT = 140.0
206	ICHECK=B(309)
207	AJAC=B(310)
208	D1 =B(311)
209	RAM1=B(312)
210	D2 =B(313)
211	RAM2=B(314)
212	TCSUPA= B(315)
213	TCSUPW= B(316)
214	THSUPA= B(317)
215	THSUPW= B(318)
216	ADUCT1= B(319)
217	UDUCT1= B(320)
218	APIPE1= B(321)
219	VPIPE1= B(322)
220	ADUCT2= B(323)
221	UDUCT2= B(324)
222	APIPE2= B(325)
223	VPIPE2= B(326)
224	ADUCT3= B(327)
225	UDUCT3= B(328)
226	APIPE3= B(329)
227	VPIPE3= B(330)
228	ADUCT4= B(331)
229	UDUCT4= B(332)
230	APIPE4= B(333)
231	VPIPE4= B(334)


```

232 AIRLOS= P(335)
233 CAPCL= B(336)
234 CAPHT= B(337)
235 DO 70 I=1,12
236 IF(TIN(I).GT.TID(I)) TIN(I)=TID(I)
237 70 CONTINUE
238 IF(ICHECK.NE.1) GO TO 9901
239 WRITE(6,75)(B(I),I=338,345)
240 75 FORMAT(1H,50X,'CITY NAME : '4A6/51X,'HOUSE NAME: '4A6//56X,'INPUT DATA LISTING'//)
241 * DATA LISTING'//)
242 WRITE(6,90)(I,B(I),I=1,337)
243 90 FORMAT(10(14,F9.3))
244 9901 CONTINUE
245 C
246 C01 ** WINDOW HEAT GAIN ** WINDOW NO. 1 TO 4 -- START FROM NORTH WINDOW AND
247 C MOVE TO EAST, SOUTH, AND WEST
248 DO 304 I =1,12
249 QCD1(I)=0.0
250 QCN1(I)=0.0
251 QCD2(I)=0.0
252 QCN2(I)=0.0
253 QCD3(I)=0.0
254 QCN3(I)=0.0
255 QCD4(I)=0.0
256 QCN4(I)=0.0
257 SCD1(I)=0.0
258 SCD2(I)=0.0
259 SCD3(I)=0.0
260 SCD4(I)=0.0
261 304 CONTINUE
262 TILT=90.0
263 CALL SOLDAT(ZT,H,ORT1,TILT,WALL11,WALL12,XLAT,RHO,TOWN,XT901,XD901
264 *)
265 IF(AG1.EQ.0.0) GO TO 305
266 CALL QC (AG1, SC1, UC1, TOD, TON, TID, TIN, SHDW1, XT901,XD901,
267 1 QCD1, QCN1,SCD1)
268 305 DO 300 I=1,12
269 XIDTN(I)=XT901(I)
270 XIDDN(I)=XD901(I)
271 300 CONTINUE
272 C IF(ICHECK.EQ.1) WRITE(6,8002)
273 C8002 FORMAT(1H,'WINDOW HEAT GAIN ROUTINE NO1. COMPLETED')
274 CALL SOLDAT(ZT,H,ORT2,TILT,WALL21,WALL22,XLAT,RHO,TOWN,XT902,XD902
275 *)
276 IF(AG2.EQ.0.0) GO TO 306
277 CALL QC (AG2, SC2, UC2, TOD, TON, TID, TIN, SHDW2, XT902,XD902,
278 1 QCD2, QCN2, SCD2)
279 306 DO 301 I=1,12
280 XIDTE(I)=XT902(I)
281 XIDDE(I)=XD902(I)
282 301 CONTINUE
283 C IF(ICHECK.EQ.1) WRITE(6,8003)
284 C8003 FORMAT(1H,'WINDOW HEAT GAIN ROUTINE NO2. COMPLETED')
285 CALL SOLDAT(ZT,H,ORT3,TILT,WALL31,WALL32,XLAT,RHO,TOWN,XT903,XD903
286 *)
287 IF(AG3.EQ.0.0) GO TO 307
288 CALL QC (AG3, SC3, UC3, TOD, TON, TID, TIN, SHDW3, XT903,XD903,
289 1 QCD3, QCN3, SCD3)

```

```

298 DO 302 I=1,12
299 XIDTS(I)=XT903(I)
300 XIDDS(I)=XD903(I)
301 302 CONTINUE
302 IF(ICHECK.EQ.1) WRITE(6,8004)
303 C8004 FORMAT(1H,'WINDOW HEAT GAIN ROUTINE NO3. COMPLETED')
304 CALL SOLDAT(ZT,H,ORT4,TILT,WALL41,WALL42,XLAT,RHO,TOWN,XT904,XD904
305 *)
306 IF(AC4.EQ.0.0) GO TO 308
307 CALL QC (AC4, SC4, UC4, TOD, TON, TID, TIN, SHDW4, XT904,XD904,
308 I QCD4, QCN4, SCD4)
309 DO 303 I=1,12
310 SCD(I)=SCD1(I)+SCD2(I)+SCD3(I)+SCD4(I)
311 XIDTW(I)=XT904(I)
312 XIDDW(I)=XD904(I)
313 303 CONTINUE
314 IF(ICHECK.EQ.1) WRITE(6,8005)
315 8005 FORMAT(1H,'WINDOW HEAT GAIN ROUTINE COMPLETED')
316 DO 102 I = 1, 12
317 QCD(I)=QCD1(I)+QCD2(I)+QCD3(I)+QCD4(I)
318 QCN(I)=QCN1(I)+QCN2(I)+QCN3(I)+QCN4(I)
319 102 CONTINUE
320 C
321 C02 ** SOLAR ENERGY UTILIZATION **
322 CALL SOLDAT(ZT,H,0.0,WLT1,0., 10., XLAT,RHO,TOWN,XIDT,XIDD)
323 CALL SEU(SA,SB,TE,TOD,XIDT,SUF,AS,QS,ISOLHW, ISOLSH)
324 DO 103 I=1,12
325 QS(I)=QS(I)*DAYS(I)
326 IF(ICHECK.EQ.1) WRITE(6,8006)
327 8006 FORMAT(1H,'SOLAR ENERGY UTILIZATION ROUTINE COMPLETED')
328 C
329 C03 ** INFILTRATION HEAT GAIN **
330 CALL INFIL (V, ACHS, TOD, TON, TID, TIN, WS, RINFIL,
331 I NSTART,NLAST,IACNV)
332 CALL QI (RINFIL, TOD, TON, TID, TIN, RH, QISD, QISM, QILD,
333 I QILN,RHM,RHA)
334 C
335 IF(ICHECK.EQ.1) WRITE(6,8001)
336 8001 FORMAT(1H,'INFILTRATION HEAT GAIN ROUTINE COMPLETED')
337 C
338 C04 ** WALL HEAT GAIN ** WALL NO. 1 TO 4
339 DO 401 I=1,12
340 CD1(I)=0.0
341 GN1(I)=0.0
342 CD2(I)=0.0
343 GN2(I)=0.0
344 CD3(I)=0.0
345 GN3(I)=0.0
346 CD4(I)=0.0
347 GN4(I)=0.0
348 401 CONTINUE
349 IF(WALL16.EQ.0.0) GO TO 402
350 CALL SAT(XT901,XD901,WALL13,WALL14,FO,90.0,TOD,TON,SATD,SATN)
351 CALL QECHG(SATD,SATN,WALL15,WALL16,TID,TIN,CD1,GN1)
352 402 IF(WALL26.EQ.0.0) GO TO 403
353 CALL SAT(XT902,XD902,WALL23,WALL24,FO,90.0,TOD,TON,SATD,SATN)
354 CALL QECHG(SATD,SATN,WALL25,WALL26,TID,TIN,CD2,GN2)
355 403 IF(WALL36.EQ.0.0) GO TO 404

```

```

348 CALL SAT(XT903, XD903, WALL33, WALL34, FO, 90.0, TOD, TON, SATD, SATN)
349 CALL QECHG(SATD, SATN, WALL35, WALL36, TID, TIN, CD3, CN3)
350 404 IF(WALL46.EQ.0.0) GO TO 405
351 CALL SAT(XT904, XD904, WALL43, WALL44, FO, 90.0, TOD, TON, SATD, SATN)
352 CALL QECHG(SATD, SATN, WALL45, WALL46, TID, TIN, CD4, CN4)
353 465 DO 104 I=1, 12
354 QWD(I)=CD1(I)+CD2(I)+CD3(I)+CD4(I)
355 QWN(I)=CN1(I)+CN2(I)+CN3(I)+CN4(I)
356 104 CONTINUE
357 IF(ICHECK.EQ.1) WRITE(6, 8007)
358 8007 FORMAT(1H, 'WALL HEAT GAIN ROUTINE COMPLETED')
359 C
360 C05 ** DOOR HEAT GAIN **
361 DO 503 I=1, 12
362 QDD1(I)=0.0
363 QDN1(I)=0.0
364 QDD2(I)=0.0
365 QDN2(I)=0.0
366 QDD3(I)=0.0
367 QDN3(I)=0.0
368 QDD4(I)=0.0
369 QDN4(I)=0.0
370 500 CONTINUE
371 IF(DOOR16.EQ.0.0) GO TO 501
372 CALL SAT(XT901, XD901, DOOR14, DOOR15, FO, 90.0, TOD, TON, SATD, SATN)
373 CALL QECHG(SATD, SATN, DOOR15, DOOR16, TID, TIN, QDD1, QDN1)
374 501 IF(DOOR26.EQ.0.0) GO TO 502
375 CALL SAT(XT902, XD902, DOOR23, DOOR24, FO, 90.0, TOD, TON, SATD, SATN)
376 CALL QECHG(SATD, SATN, DOOR25, DOOR26, TID, TIN, QDD2, QDN2)
377 502 IF(DOOR36.EQ.0.0) GO TO 503
378 CALL SAT(XT903, XD903, DOOR33, DOOR34, FO, 90.0, TOD, TON, SATD, SATN)
379 CALL QECHG(SATD, SATN, DOOR35, DOOR36, TID, TIN, QDD3, QDN3)
380 503 IF(DOOR46.EQ.0.0) GO TO 504
381 CALL SAT(XT904, XD904, DOOR43, DOOR44, FO, 90.0, TOD, TON, SATD, SATN)
382 CALL QECHG(SATD, SATN, DOOR45, DOOR46, TID, TIN, QDD4, QDN4)
383 504 CONTINUE
384 DO 505 I=1, 12
385 QDD(I)=QDD1(I)+QDD2(I)+QDD3(I)+QDD4(I)
386 QDN(I)=QDN1(I)+QDN2(I)+QDN3(I)+QDN4(I)
387 505 CONTINUE
388 IF(ICHECK.EQ.1) WRITE(6, 8008)
389 8008 FORMAT(1H, 'DOOR HEAT GAIN ROUTINE COMPLETED')
390 C
391 C06 ** CEILING HEAT GAIN **
392 C
393 DO 16 I=1, 12
394 XX(I)=0.0
395 QCD(I)=0.0
396 QCN(I)=0.0
397 16 CONTINUE
398 C ATTICLESS ROOFS
399 TILT=0.0
400 CALL SOLDAT(ZT, H, 0.0, TILT, 0., 10., XLAT, RHO, TOWN, XIDT, XIDD)
401 CALL SAT(XIDT, XIDD, ROOF1, ROOF2, FO, 0.0, TOD, TON, SATD, SATN)
402 IF(ROOF4.EQ.0.0) GO TO 6
403 CALL QECHG(SATD, SATN, ROOF3, ROOF4, TID, TIN, QCD, QCN)
404 IF(ICHECK.EQ.1) WRITE(6, 8009)
405 8009 FORMAT(1H, 'ATTICLESS ROOFS HEAT GAIN ROUTINE COMPLETED')

```

```

406      6 IF(ATFLR.EQ.0.0) GO TO 66
407      C      ATTIC ROOFS
408      DO 600 I=1,12
409      ATD(I)=TID(I)
410      ATN(I)=TIN(I)
411      600 CONTINUE
412      CALL SAT(XX,XX,0.0,0.0,FO,90.0,TOD,TON,TWD1,TWN1)
413      CALL SAT(XX,XX,0.0,0.0,FO,90.0,TOD,TON,TWD2,TWN2)
414      DO 666 I=1,12
415      TWD(I)=(TWD1(I)+TWD2(I))/2.0
416      TWN(I)=(TWN1(I)+TWN2(I))/2.0
417      666 CONTINUE
418      IF(INDEXD.EQ.0) GO TO 9902
419      CFM=ACAT*ATFLR*AEWH/60.0
420      CALL ATTIC(ATFLR,SATD,SATN,ATFLR,TID,TIN,AW,TWD,TWN,CFM,ROOF3,
421      *      UCEIL,AEW5,TOD,TON,ATD,ATN)
422      C 601 IF(ICHECK.NE.1) GO TO 9902
423      C      WRITE(6,9001)(ATD(K),ATN(K),TWD(K),TWN(K),SATD(K),SATN(K),K=1,12)
424      C9001 FORMAT(1H,6(F9.3))
425      9902 CONTINUE
426      CALL QECHG(ATD,ATN,UCEIL,ATFLR,TID,TIN,ATQCD,ATQCN)
427      GO TO 6666
428      66 DO 166 I=1,12
429      ATQCD(I)=0.0
430      ATQCN(I)=0.0
431      166 CONTINUE
432      6666 DO 106 I=1,12
433      QCD(I)=QCD(I)+ATQCD(I)
434      QCN(I)=QCN(I)+ATQCN(I)
435      106 CONTINUE
436      IF(ICHECK.EQ.1) WRITE(6,8010)
437      8010 FORMAT(1H,'CEILING HEAT GAIN ROUTINE COMPLETED')
438      C
439      C07 ** FLOOR HEAT GAIN **
440      C
441      C      SLAB ON GRADE
442      AF=FLOOR*SOGRFC
443      DO 177 I=1,12
444      QFD(I)=0.0
445      QFN(I)=0.0
446      177 CONTINUE
447      IF(AF.EQ.0.0) GO TO 7
448      CALL CF(AF,ZL,DX,DY,ZKS,E,TOD,TON,UFF,TID,TIN,QFD,QFN)
449      IF(ICHECK.EQ.1) WRITE(6,8011)
450      8011 FORMAT(1H,'SLAB ON GRADE ROUTINE COMPLETED')
451      C      CRAWL SPACE
452      7 DO 701 I=1,12
453      GD1(I)=0.0
454      GN1(I)=0.0
455      GD2(I)=0.0
456      GN2(I)=0.0
457      701 CONTINUE
458      AFCL=FLOOR*CRWFRC
459      IF(AFCL.EQ.0.0) GO TO 702
460      CALL SAT(XX,XX,0.0,0.0,FO,90.0,TOD,TON,SATD,SATN)
461      CFM=ACCS*FLOOR*CRWFRC*HCL/60.0
462      CALL CRAWL(TOD,TON,TC,TID,TIN,SATD,SATN,CFM,UFLR2,UCLW,1.0,AFCL,
463      *      AWCL,CRAWL,CRAWLN)

```

```

464 CALL QECHG(CRAWLD,CRAWLN,UFLR2,AFCL,TID,TIN,CD1,CN1)
465 702 DO 107 I=1,12
466 QFD(I)=CD1(I)+CD2(I)+QFD(I)
467 QFN(I)=CN1(I)+CN2(I)+QFN(I)
468 107 CONTINUE
469 IF(ICHECK.EQ.1) WRITE(6,8012)
470 8012 FORMAT(1H,'CRAWL SPACE ROUTINE COMPLETED')
471 BFA=FLOOR*BSMFRC
472 DO 703 I=1,12
473 BQFD(I)=0.0
474 BQFN(I)=0.0
475 703 CONTINUE
476 IF(BFA.EQ.0.0) GO TO 764
477 C BASEMENT
478 CALL BSMT (UFW,BWA,BFA,UFLR1,UFF,QBHC,TID,TIN,TC,TOD,TON,
479 1 UBW,UBF,BSMTD,BSMTN,BQFD,BQFN)
480 IF(ICHECK.EQ.1) WRITE(6,9999) (BSMTD(I),I=1,12)
481 9999 FORMAT(/1H,12G10.4)
482 IF(ICHECK.EQ.1) WRITE(6,9999) (BSMTN(I),I=1,12)
483 IF(INDEXC.NE.0) CALL QECHG(BSMTD,BSMTN,UFLR1,BFA,TID,TIN,
484 1 BQFD,BQFN)
485 IF(ICHECK.EQ.1) WRITE(6,9999) (BQFD(I),I=1,12)
486 IF(ICHECK.EQ.1) WRITE(6,9999) (BQFN(I),I=1,12)
487 IF(ICHECK.EQ.1) WRITE(6,8013)
488 8013 FORMAT(1H,'BASEMENT ROUTINE COMPLETED')
489 704 DO 1777 I=1,12
490 QFD(I)=QFD(I)+BQFD(I)
491 QFN(I)=QFN(I)+BQFN(I)
492 1777 CONTINUE
493 IF(ICHECK.EQ.1) WRITE(6,8014)
494 8014 FORMAT(1H,'FLOOR HEAT GAIN ROUTINE COMPLETED')
495 C
496 C08 ** INTERNAL HEAT GAIN **
497 DO 109 I=1,12
498 CALL QR(NPD,NPN,WTD,WTN,WED,WEN,QRSN,QRLD,QRLN,HRDAY(I),HRNIT(I))
499 *(I))
500 8015 FORMAT(1H,'INTERNAL HEAT GAIN ROUTINE COMPLETED')
501 C
502 QRD(I)=QRSN
503 QRN(I)=QRSN
504 QID(I)=QISD(I)
505 QIN(I)=QISN(I)
506 109 CONTINUE
507 CALL ZKDN(RINFIL,B,ZK)
508 IF(ICHECK.EQ.1) WRITE(6,8015)
509 C
510 C09 ** HEAT LOSS AND HEAT GAIN **
511 IF(ICHECK.NE.1) GO TO 9900
512 WRITE(6,9005)
513 9005 FORMAT(1H1,60X,'ANNUAL SUMMARY')
514 WRITE(6,9006)
515 9006 FORMAT(1H,60X,14(1H-))
516 WRITE(6,9007)
517 9007 FORMAT(/1H,10X,'J',9X,'F',9X,'M',9X,'A',9X,'M',9X,'J',9X,
518 1 'J',9X,'A',9X,'S',9X,'O',9X,'N',9X,'D'/)
519 WRITE(6,9003) AA(1),(TID(I),I=1,12)
520 9003 FORMAT(1H,A5,12G10.4)
521 WRITE(6,9003) AA(2),(TIN(I),I=1,12)

```

```

522 WRITE(6,9003) AA(3),(TOD(I),I=1,12)
523 WRITE(6,9003) AA(4),(TON(I),I=1,12)
524 WRITE(6,9003) AA(29),HRDAY,AA(30),HRNIT
525 WRITE(6,9003) AA(5),(XIDTS(I),I=1,12)
526 WRITE(6,9003) AA(6),(XIDDS(I),I=1,12)
527 WRITE(6,9003) AA(7),(XIDTW(I),I=1,12)
528 WRITE(6,9003) AA(8),(XIDDW(I),I=1,12)
529 WRITE(6,9003) AA(9),(XIDTN(I),I=1,12)
530 WRITE(6,9003) AA(10),(XIDDN(I),I=1,12)
531 WRITE(6,9003) AA(11),(XIDTE(I),I=1,12)
532 WRITE(6,9003) AA(12),(XIDDE(I),I=1,12)
533 WRITE(6,9003) AA(13),(QID(I),I=1,12)
534 WRITE(6,9003) AA(14),(QIN(I),I=1,12)
535 WRITE(6,9003) AA(15),(QWD(I),I=1,12)
536 WRITE(6,9003) AA(16),(QWN(I),I=1,12)
537 WRITE(6,9003) AA(17),(QDD(I),I=1,12)
538 WRITE(6,9003) AA(18),(QDN(I),I=1,12)
539 WRITE(6,9003) AA(19),(QCD(I),I=1,12)
540 WRITE(6,9003) AA(20),(QCN(I),I=1,12)
541 WRITE(6,9003) AA(21),(QGD(I),I=1,12)
542 WRITE(6,9003) AA(22),(QGN(I),I=1,12)
543 WRITE(6,9003) AA(23),(QFD(I),I=1,12)
544 WRITE(6,9003) AA(24),(QFN(I),I=1,12)
545 WRITE(6,9003) AA(25),(QRD(I),I=1,12)
546 WRITE(6,9003) AA(26),(QRN(I),I=1,12)
547 WRITE(6,9003) AA(31),SGD,AA(32),ZK
548 9004 FORMAT(/1H ,A5,12C10.4)
549 9900 CONTINUE
550 C
551 C
552 CALL HLHG(QID,QIN,QWD,QWN,QDD,QDN,QCD,QCN,QFD,QFN,THTC,PUH,QRD,QRN
553 * ,QTD,QTN,HC,HL,QCD,QCN,NSTART,NLAST,TIN,TON,TID,TOD,IACNV,SGD,
554 * ICHECK,TIC,TIH,ZK)
555 IF(ICHECK.NE.1) GO TO 9010
556 WRITE(6,9004) AA(27),(QTD(I),I=1,12)
557 WRITE(6,9004) AA(28),(QTN(I),I=1,12)
558 9002 FORMAT(1X,14E9.4)
559 9010 CONTINUE
560 IF(ICHECK.EQ.1) WRITE(6,8016)
561 8016 FORMAT(1H , 'HEAT LOSS & HEAT GAIN ROUTINE COMPLETED')
562 C
563 C10 ** HEATING AND COOLING REQUIREMENT **
564 DO 110 I=1,12
565 RLHG(I)=0.0
566 IF(QRLD.GT.0.0) RLHG(I)=RLHG(I)+QRLD
567 IF(QRLN.GT.0.0) RLHG(I)=RLHG(I)+QRLN
568 IF(1.GE.NSTART.AND.1.LE.NLAST.AND.TOD(I).LT.TID(I).AND.
569 1 QRLD.GT.0.0.AND.IACNV.EQ.1) RLHG(I)=RLHG(I)-QRLD
570 IF(1.GE.NSTART.AND.1.LE.NLAST.AND.TON(I).LT.TIN(I).AND.
571 1 QRLN.GT.0.0.AND.IACNV.EQ.1) RLHG(I)=RLHG(I)-QRLN
572 IF(QILD(I).GT.0.0) RLHG(I)=RLHG(I)+QILD(I)
573 IF(QILN(I).GT.0.0) RLHG(I)=RLHG(I)+QILN(I)
574 IF(1.GE.NSTART.AND.1.LE.NLAST.AND.TOD(I).LT.TID(I).AND.
575 1 QILD(I).GT.0.0.AND.IACNV.EQ.1) RLHG(I)=RLHG(I)-QILD(I)
576 IF(1.GE.NSTART.AND.1.LE.NLAST.AND.TON(I).LT.TIN(I).AND.
577 1 QILN(I).GT.0.0.AND.IACNV.EQ.1) RLHG(I)=RLHG(I)-QILN(I)
578 110 CONTINUE
579 IF(ICHECK.EQ.1) WRITE(6,9011) (RLHG(I),I=1,12)

```



```

580 9011 FORMAT(/1H , 'RLHC' , 12G10.4)
581 C
582 CALL HCRT(HL, HC, RLHC, HREQ, CREQ, AIRLOS)
583 DO 200 I = 1, 12
584 HREQ(I) = HREQ(I) * DAYS(I)
585 CREQ(I) = CREQ(I) * DAYS(I)
586 200 CONTINUE
587 DO 202 I = NSTART, NLAST
588 HREQ(I) = 0.0
589 202 CONTINUE
590 DO 203 I = 1, 12
591 IF(I.LT.NSTART.OR.I.GT.NLAST) CREQ(I)=0.0
592 203 CONTINUE
593 DO 207 I = 1, 12
594 QC1(I)=0.0
595 QC2(I)=0.0
596 QC3(I)=0.0
597 QH1(I)=0.0
598 QH2(I)=0.0
599 QH3(I)=0.0
600 CFAC(I)=0.0
601 HFAC(I)=0.0
602 IF(CAPCL.EQ.0.0) GO TO 208
603 CFAC(I)=CREQ(I)/CAPCL/24.0/DAYS(I)
604 208 IF(CAPHT.EQ.0.0) GO TO 207
605 HFAC(I)=-HREQ(I)/CAPHT/24.0/DAYS(I)
606 207 CONTINUE
607 IF(CRWFRQ.EQ.0.0) GO TO 705
608 CALL CSDUPI(ADUCT1, UDUCT1, APIPE1, UPIPE1, TCSUPA, TCSUPW, THSUPA,
609 1 THSUPW, CRAWLD, CRAWLN, NSTART, NLAST, QC1, QH1,
610 2 CFAC, HFAC)
611 705 IF(ICHECK.EQ.1) WRITE(6,9995)
612 9995 FORMAT(1H , 'CSDUPI COMPLETED')
613 IF(ATFLR.EQ.0.0) GO TO 706
614 CALL ASDUPI(ADUCT2, UDUCT2, APIPE2, UPIPE2, TCSUPA, TCSUPW, THSUPA,
615 1 THSUPW, ATD, ATN, NSTART, NLAST, QC2, QH2, CFAC, HFAC)
616 706 IF(ICHECK.EQ.1) WRITE(6,9998)
617 9998 FORMAT(1H , 'ASDUPI COMPLETED')
618 IF(BSMFRQ.EQ.0.0) GO TO 707
619 CALL BMDUPI(ADUCT3, UDUCT3, APIPE3, UPIPE3, TCSUPA, TCSUPW, THSUPA,
620 1 THSUPW, BSMTD, BSMTN, NSTART, NLAST, INDEXC, QC3, QH3,
621 2 CFAC, HFAC)
622 707 IF(ICHECK.EQ.1) WRITE(6,9997)
623 9997 FORMAT(1H , 'BMDUPI COMPLETED')
624 CALL OSDUPI(ADUCT4, UDUCT4, APIPE4, UPIPE4, TCSUPA, TCSUPW, THSUPA,
625 1 THSUPW, TOD, TON, NSTART, NLAST, QC4, QH4, CFAC, HFAC)
626 IF(ICHECK.EQ.1) WRITE(6,9996)
627 9996 FORMAT(1H , 'OSDUPI COMPLETED')
628 DO 206 I = 1, 12
629 QQC(I)=(QC1(I)+QC2(I)+QC3(I)+QC4(I))*DAYS(I)
630 QQH(I)=(QH1(I)+QH2(I)+QH3(I)+QH4(I))*DAYS(I)
631 206 CONTINUE
632 DO 205 I = 1, 12
633 IF(BSMFRQ.EQ.0.0) BSMTD(I)=TID(I)
634 IF(BSMFRQ.EQ.0.0) BSMTN(I)=TIN(I)
635 205 CONTINUE
636 CALL HWHREQ(TOUT, TC, HWT, AJAC, BSMTD, BSMTN, D1, RAM1, D2, RAM2, INLHWH1,
637 1 HLHWH2, SAVE, WHREQ)

```



```

638      DO 204 I=1,12
639          WREQ(I)=WREQ(I)*DAYS(I)
640          HLHW1(I)=HLHW1(I)*DAYS(I)
641          HLHW2(I)=HLHW2(I)*DAYS(I)
642          SAVE(I)=SAVE(I)*DAYS(I)
643      204 CONTINUE
644
645      IF(ICHECK.EQ.1) WRITE(6,8017)
646      8017 FORMAT(1H,'HEATING & COOLING REQUIREMENT ROUTINE COMPLETED')
647      C11 ** ENERGY REQUIREMENT **
648          CALL EREQ(HREQ,CREQ,EH,EC,ISYS,R(1),R(2),WREQ,QS,QQC,QQH)
649          IF(ICHECK.EQ.1) WRITE(6,8018)
650      8018 FORMAT(1H,'ENERGY REQUIREMENT ROUTINE COMPLETED')
651
652      C ** OUTPUT **
653          IF(ICHECK.NE.1) GO TO 9903
654          WRITE(6,9005)
655          WRITE(6,9006)
656          WRITE(6,9007)
657          WRITE(6,9008)(HREQ(I),I=1,12)
658      9008 FORMAT(1H,'HREQ ',12G10.4)
659          WRITE(6,9009)(CREQ(I),I=1,12)
660      9009 FORMAT(1H,'CREQ ',12G10.4)
661      9903 CONTINUE
662          IF(ICHECK.NE.1) GO TO 9904
663          SUM1 = 0.0
664          SUM2 = 0.0
665          DO 201 I = 1, 12
666              SUM1 = SUM1 + HREQ(I)
667              SUM2 = SUM2 + CREQ(I)
668              R(I+2) = HREQ(I)
669              R(I+14) = CREQ(I)
670              R(I+26) = TOD(I)
671              R(I+38) = TON(I)
672      201 CONTINUE
673
674      C
675          IF(ICHECK.NE.1) GO TO 9904
676          WRITE(6,1002)THTC,SUM1,SUM2
677      1002 FORMAT(/1H,'F7.2,60X.6H THT=',G15.7,6H TCT=',G15.7)
678          WRITE(6,1001) ISYS, (R(I),I=1,2)
679      1001 FORMAT(/1H,'12.40X,'SHBTU = ',G10.4,' SCBTU = ',G10.4)
680      9904 CONTINUE
681
682      C
683          RETURN
684          END

```

030303*CONSP6(1).SOLDAT(22)

1 SUBROUTINE SOLDAT(ZKT,H,WAZ,WTLT,OVHANG,WALLHT,XLAT,RHO,TOWN,XIDT,
2 *XIDD)
3 THIS SUBROUTINE CALCULATES MONTHLY AVERAGE SOLAR HEAT RADIATION
4 INCIDENT UPON A GIVEN SURFACE WITH THE OVERHANG.
5 ZKT...LIU/JORDAN FACTOR - DAILY TOTAL RADIATION ON A HORIZONTAL SURFACE /
6 THE SAME IN OUTER SPACE
7 H....DAILY TOTAL RADIATION ON A HORIZONTAL SURFACE
8 TO....DAILY AVERAGE TEMPERATURE
9 XLAT..LATITUDE OF THE LOCATION
10 RHO...REFLECTIVITY OF THE GROUND AROUND THE WINDOW
11 WAZ...SURFACE AZIMUTH ANGLE, DEGREES FROM SOUTH (0S, 90W, 180N, -90E)
12 WTLT..SURFACE TILT ANGLE (90 DEG VERTICAL, 0 DEG HORIZONTAL)
13 XIDT..TOTAL RADIATION INCIDENT UPON A GIVEN SURFACE, BTU/HR,FT**2
14 XIDD..DIFFUSE RADIATION INCIDENT UPON A GIVEN SURFACE, BTU/HR,FT**2
15 OVHANG..OVERHANG OVER A WALL, FT
16 WALLHT..WALL HEIGHT, FT
17 C
18 COMMON/HR/HRDAY(12),HRNIT(12)
19 DIMENSION LDAY(12)/31,28,31,30,31,30,31,31,30,31,30,31/
20 DIMENSION XDEC(12)/-19.51,-10.28,.20,11.56,20.14,23.27,20.26,12.03
21 *,.37,-10.47,-19.58,-23.27/
22 DIMENSION R(12)/1.03,1.0207,1.0057,.9875,.9727,.967,.9692,.9785,
23 *.9945,1.0133,1.0267,1.0327/
24 REAL US(12)/1.13,1.13,1.13,1.13,1.06,1.06,1.06,1.06,1.06,1.13,1.13
25 *,1.13/,H(12),ZKT(12)
26 REAL TOWN(4),ZIT(24),DLITE(12)
27 REAL RST/442.1/,PI/3.1415927/,LAT
28 DIMENSION B(12)/.142,.144,.156,.18,.196,.205,.207,.201,.177,.16,.149,.142/
29 *.49,.142/
30 REAL DNI(24),ASI(24),RSI(24),XIDT(12),XIDD(12)
31 PIOV2=PI/2.
32 XLAX=AINT(XLAT)
33 LAT=(XLAX+(XLAT-XLAX)/0.6)*PI/180.
34 LAX=INT(XLAT)
35 MINUTE=(XLAT-XLAX)*100
36 WTLTX=WTLT*PI/180.
37 WAZX=WAZ*PI/180.
38 DO 1 N=1,12
39 RD=AINT(XDEC(N))
40 DEC=(RD+(XDEC(N)-RD)/0.6)*PI/180.
41 COSWS=-TAN(LAT)*TAN(DEC)
42 IF(COSWS.GT.1..OR.COSWS.LT.-1.) RETURN
43 WS=ACOS(COSWS)
44 TWS=WS*12/PI
45 SUNRIZ=12.-ABS(TWS)
46 SUNSET=12.+ABS(TWS)
47 HRDAY(N)=SUNSET-SUNRIZ
48 HRNIT(N)=24.-HRDAY(N)
49 COSLD=COS(LAT)*COS(DEC)
50 SINLD=SIN(LAT)*SIN(DEC)
51 S=0.
52 DO 500 L=1,39
53 WW=WS*L/40.
54 CZE=COSLD*COS(WW)+SINLD
55 PAR=-B(N)/CZE
56 APA=ABS(PAR)
57 IF(APA.GT.80.) GO TO 501

C 15

```

58      ANS=EXP(PAR)*CZE
59      GO TO 502
60
61 501 ANS=0.
62 502 S=ANS+S
63 500 CONTINUE
64      ANSO=EXP(-B(N)/(COSLD+SINLD))*(COSLD+SINLD)/2.
65      AI=WS/40.*(ANSO+S)
66      HO=24./PI*R(N)*RST*(COSLD*SIN(WS)+WS*SINLD)
67      THH=B(N)
68      ZKT(N)=H(N)/HO
69      ZKD=ZD(ZKT(N))
70      DHH=HO*(ZKT(N)-ZKD)
71      RHH=HO*ZKD
72      A=DHH/(24./PI*AI)
73      FAC=A/ZKT(N)
74      DO 2 I=1,24
75          DN1(I)=0.
76          ASI(I)=0.
77          RSI(I)=0.
78      2 ZIT(I)=0.
79      DLITE(N)=2.*ABS(TWS)
80      DO 3 I=1,24
81          TIME=I-1.
82          WT=ABS(12.-TIME)
83          W=WT*PI/12.
84          IF(TIME-SUNRIZ) 3,3,4
85          4 IF(TIME-SUNSET) 5,3,3
86          5 COSZ=SINLD+COSLD*COS(W)
87          COSW=COS(DEC)*SIN(W)
88          COSS=SQRT(1.-COSW*COSW-COSZ*COSZ)
89          V=TAN(DEC)/TAN(LAT)
90          TEST=COS(W)-V
91          IF(TEST) 9,9,8
92          9 COSS=-COSS
93          8 ALT=ASIN(COSZ)
94          AZM=ASIN(COSW/COSS(ALT))
95          IF(COSS) 23,24,24
96          23 AZM=PI-AZM
97          24 IF(AZM.GT.PI) AZM=2.*PI-AZM
98          IF(TIME.LT.12.) AZM=-AZM
99          AZMP=AZM*180./PI
100         PAR2=-B(N)/COSZ
101         AP2=ABS(PAR2)
102         IF(AP2.GT.80.) GO TO 3
103         DN1(I)=A*EXP(PAR2)
104         IF(DN1(I).LE.0.) DN1(I)=0.
105         DHI=DN1(I)*COSZ
106         IF(DHI.LE.0.) DHI=0.
107         RR=PI/24.*(COS(W)-COS(WS))/(SIN(WS)-WS*COS(WS))
108         IF(RR.LT.0.) RR=0.
109         RHI=RHH*RR
110         IF(WILT.GT.0.) GO TO 25
111         COSTH=COSZ
112         GO TO 26
113 25 CONTINUE
114         SAZM=AZM-WAZX
115         SAZMP=SAZM*180./PI
116         ALTP=ALT*180./PI

```

@ DAILY TOTAL DIRECT ON HORIZONTAL
 @ DAILY TOTAL DIFFUSE ON HORIZONTAL

```

116 IF(WLT.CE.90.) GO TO 50
117 ALPHA=COS(WLT.X)
118 BETA=SIN(WAZX)*SIN(WLT.X)
119 GAMMA=COS(WAZX)*SIN(WLT.X)
120 COSTH=ALPHA*COSZ+BETA*COSW+GAMMA*COSS
121 GO TO 26
122 50 COSTH=COS(SAZM)*COS(ALT)
123 26 CONTINUE
124 SUNLIT=0.
125 IF(COSTH.LE.0.) GO TO 27
126 TEST=COS(SAZM)
127 COSALT=COS(ALT)
128 IF(COSALT.EQ.0.) GO TO 27
129 IF(TEST.NE.0.) TANPRO=TAN(ALT)/TEST
130 C WRITE(6,789) N,I,SAZM,ALT,TEST,COSALT,PROFIL
131 789 FORMAT('/' N I SAZM ALT TEST COSALT PROFIL'/
132 *2I3,5F10.3)
133 IF(TEST.EQ.0.) GO TO 27
134 SUNLIT=(WALLHT-OVHANG*TANPRO)/WALLHT
135 IF(SUNLIT.LE.0.) SUNLIT=0.
136 IF(SUNLIT.CE.1.) SUNLIT=1.
137 27 CONTINUE
138 IF(COSTH.LE.0.) COSTH=0.
139 THP=ACOS(COSTH)*180./PI
140 ASI(1)=C71(1)*COSTH*SUNLIT
141 IF(ASI(1).LE.0.) ASI(1)=0.
142 RSI(1)=(R31+(RH1+DH1)*RHO)/2.
143 IF(WLT.LE.0.) RSI(1)=RH1
144 ZIT(1)=ASI(1)+RSI(1)
145 10 CONTINUE
146 3 CONTINUE
147 SUMN=0.
148 SUMD=0.
149 SUMR=0.
150 SUM=0.
151 DO 14 I=1,24
152 SUMN=SUMN+DNI(I)
153 SUMD=SUMD+ASI(I)
154 SUMR=SUMR+RSI(I)
155 14 SUM=SUM+ZIT(I)
156 XIDT(N)=SUMD+SUMR
157 XIDD(N)=SUMR
158 12 CONTINUE
159 1 CONTINUE
160 RETURN
161 END

```

● DIRECT RADIATION

● DIFFUSE RADIATION

● TOTAL RADIATION

QSQSQS*CONSP6(1).ZD(1)

```
1      FUNCTION ZD(ZT)
2      C      PART OF SOLBAT ROUTINE
3      DIMENSION ZKT(6)/.3,.4,.5,.6,.7,.75/
4      DIMENSION ZKD(6)/.179,.183,.188,.174,.149,.125/
5      IF(ZT-.3) 1,1,2
6      1 ZD=.179
7      GO TO 10
8      2 IF(ZT-.75) 3,3,4
9      4 ZD=.125
10     GO TO 10
11     3 DO 20 J=2,6
12         T1=ZT-ZKT(J-1)
13         T2=ZT-ZKT(J)
14         TEST=T1*T2
15         IF(TEST) 5,6,20
16     5 Y1=ZKD(J-1)
17         Y2=ZKD(J)
18         ZD=Y1+(Y2-Y1)*(ZT-ZKT(J-1))/(ZKT(J)-ZKT(J-1))
19         GO TO 20
20     6 IF(T1) 8,9,8
21     9 ZD=ZKD(J-1)
22         GO TO 20
23     8 ZD=ZKD(J)
24 20 CONTINUE
25 10 RETURN
26 END
```

C-18

050505*CONSP6(1).F(1)

```

1      FUNCTION F(DB,R,INDHTD)
2      C      SLAB-ON-GRADE PERIMETER HEAT LOSS 1972 ASHRAE HANDBOOK
3      C      INDHTD =0 UNHEATED, =1 HEATED
4      REAL TABLE(2,3,9),LINE(3)
5      DATA (TABLE(1,1,N),N=1,9)/34.,32.,30.,28.,27.,25.,24.,22.,21./
6      DATA (TABLE(1,2,N),N=1,9)/51.,48.,45.,43.,40.,38.,36.,33.,31./
7      DATA (TABLE(1,3,N),N=1,9)/67.,64.,60.,57.,54.,51.,48.,44.,42./
8      DATA (TABLE(2,1,N),N=1,9)/46.,44.,41.,39.,37.,35.,32.,30.,25./
9      DATA (TABLE(2,2,N),N=1,9)/69.,66.,61.,59.,55.,52.,48.,45.,38./
10     DATA (TABLE(2,3,N),N=1,9)/92.,88.,82.,78.,74.,70.,64.,60.,50./
11     REAL RVALUE(3)/5.0,3.75,2.50/
12     DBT=DB-1
13     N=(DBT+40.)/5.
14     IF(N.LT.1) N=1
15     IF(N.GT.9) N=9
16     I=INDHTD+1
17     DO 1 L=1,3
18     1      LINE(L)=TABLE(I,L,N)
19     IF(I.EQ.2) RVALUE(2)=3.33
20     DO 2 L=1,3
21     IF(R.GT.RVALUE(L)) GO TO 3
22     2      CONTINUE
23     F=LINE(3)
24     RETURN
25     3      IF(L-2) 4,5,5
26     4      F=LINE(1)
27     RETURN
28     5      F=LINE(L)-(R-RVALUE(L))/(RVALUE(L-1)-RVALUE(L))*(LINE(L)-LINE(L-
29     *1))
30     RETURN
31     END

```

C 19

```

050003*CONST(1),SAT(11)
1 SUBROUTINE SAT(XIDT,XIDD,SHDW,AB,FO,WTLT,TOD,TON,SATD,SATN)
2
3 THIS IS SOL-AIR TEMPERATURE ROUTINE
4
5 *** INPUT ***
6
7 WTLT : TILT ANGLE
8 XIDT : DAILY TOTAL RADIATION
9 XIDD : DAILY DIFFUSE RADIATION
10 SHDW : SHADOW FACTOR
11 AB : SURFACE ABSORPTIVITY
12 FO : SURFACE HEAT TRANSFER COEFFICIENT
13 TOD : DAYTIME TEMPERATURE
14 TON : NIGHTTIME TEMPERATURE
15
16 *** OUTPUT ***
17
18 SATD : DAYTIME SOL-AIR TEMPERATURE
19 SATN : NIGHTTIME SOL-AIR TEMPERATURE
20
21 COMMON/HR/HRDAY(12),HRNIT(12)
22 DIMENSION XIDT(12),XIDD(12),FO(12),TOD(12),TON(12),SATD(12),
23 SATN(12)
24
25 XWTLT=WTLT/180.0*3.14159
26 DO 10 J=1,12
27 R=(XIDT(J)-XIDD(J))*(1.0-SHDW)+XIDD(J)
28 SATD(J)=TOD(J)+AB*R/HRDAY(J)/FO(J)-10.0/FO(J)*COS(XWTLT)
29 SATN(J)=TON(J)-10.0/FO(J)*COS(XWTLT)
30 CONTINUE
31 RETURN
32 END

```


00000*CONSP6(1).ATTIC(1)

```

1      SUBROUTINE ATTIC(AR,TRD,TRN,AC,TAD,TAN,AW,TWD,TWN,CFM,UR,UC,UW,TOD
2      *,TON,ATD,ATN)
3      THIS IS ATTIC TEMPERATURE CALCULATION ROUTINE
4
5      *** INPUT ***
6
7      AR      : ROOF AREA
8      TRD     : DAYTIME SOL-AIR TEMPERATURE
9      TRN     : NIGHTTIME SOL-AIR TEMPERATURE
10     AC      : CEILING AREA
11     TAD     : DAYTIME ROOM TEMPERATURE
12     TAN     : NIGHTTIME ROOM TEMPERATURE
13     AW      : END WALL AREA
14     TWD     : DAYTIME END WALL SOL-AIR TEMPERATURE
15     TWN     : NIGHTTIME END WALL SOL-AIR TEMPERATURE
16     CFM     : AIR FLOW
17     UR      : U-VALUE FOR ROOF
18     UC      : U-VALUE FOR CEILING
19     UW      : U-VALUE FOR WALLS
20     TOD     : DAYTIME OUTDOOR TEMPERATURE
21     TON     : NIGHTTIME OUTDOOR TEMPERATURE
22
23     *** OUTPUT ***
24
25     ATD     : DAYTIME ATTIC TEMPERATURE
26     ATN     : NIGHTTIME ATTIC TEMPERATURE
27     DIMENSION TRD(12),TRN(12),TOD(12),TON(12),ATD(12),
28     *        ATN(12),TWD(12),TWN(12),TAD(12),TAN(12)
29     DO 10 I=1,12
30     ATD(I)=(UR*AR*TRD(I)+UW*AW*TWD(I)+UC*AC*TAD(I)+1.08*CFM*TOD(I))/
31     /(UR*AR+UW*AW+UC*AC+1.08*CFM)
32     ATN(I)=(UR*AR*TRN(I)+UW*AW*TWN(I)+UC*AC*TAN(I)+1.08*CFM*TON(I))/
33     /(UR*AR+UW*AW+UC*AC+1.08*CFM)
34 10 CONTINUE
35     RETURN
36     END

```

QSQSQS*CONSP6(1).CRAWL(1)

```

1 SUBROUTINE CRAWL(TOD,TON,TC,TAD,TAN,TWMD,TWMN,CFM,UF,UW,UC,AF,AW,
2 *CRAWLD,CRAWLN)
3 THIS IS CRAWL SPACE TEMPERATURE CALCULATION ROUTINE
4
5 *** INPUT ***
6 TWMD : DAYTIME WALL SOL-AIR TEMPERATURE
7 TOD : DAYTIME OUTDOOR TEMPERATURE
8 TON : NIGHTTIME OUTDOOR TEMPERATURE
9 TC : GROUND TEMPERATURE
10 TAD : DAYTIME ROOM TEMPERATURE
11 TAN : NIGHTTIME ROOM TEMPERATURE
12 CFM : AIR FLOW RATE
13 UF : FLOOR HEAT TRANSFER COEFFICIENT
14 UW : WALL HEAT TRANSFER COEFFICIENT
15 UC : GROUND SURFACE HEAT TRANSFER COEFFICIENT = 1.0
16 AF : FLOOR AREA
17 AW : WALL AREA
18 TWMN : NIGHTTIME WALL SOL-AIR TEMPERATURE
19 *** OUTPUT ***
20 CRAWLD : DAYTIME CRAWL SPACE TEMPERATURE
21 CRAWLN : NIGHTTIME CRAWL SPACE TEMPERATURE
22 DIMENSION TOD(12),TON(12),TC(12),TAD(12),TAN(12),TWMD(12),TWMN(12)
23 * ,CRAWLD(12),CRAWLN(12)
24
25 DO 10 I=1,12
26 CRAWLD(I)=(UF*TAD(I)*AF+UW*TWMD(I)*AW+UC*(TC(I)+TAD(I))/2.0*AF+
27 *1.08*CFM*TC(I))/(UF*AF+UW*AW+UC*AF+1.08*CFM)
28 CRAWLN(I)=(UF*TAN(I)*AF+UW*TWMN(I)*AW+UC*(TC(I)+TAN(I))/2.0*AF+
29 *1.08*CFM*TON(I))/(UF*AF+UW*AW+UC*AF+1.08*CFM)
30 10 CONTINUE
31 RETURN
32 END

```

C 22

030303*CONSP6(1).CF(14)

```

1      SUBROUTINE CF (AF,P,DX,DY,ZKS,E,TOD,TON,USLAB,TAD,TAN,CFD,CFN)
2      C
3      C      THIS IS GROUND FLOOR HEAT TRANSFER ROUTINE
4      C
5      C      ** INPUT **
6      C
7      C      TOD   : DAYTIME OUTDOOR TEMPERATURE
8      C      TON   : NIGHTTIME OUTDOOR TEMPERATURE
9      C      TC    : GROUND TEMPERATURE
10     C      AF    : FLOOR AREA
11     C      P     : EXPOSED PERIMETER LENGTH
12     C      USLAB  : SLAB THERMAL CONDUCTANCE
13     C               INCLUDING THE SURFACE HEAT TRANSFER COEFFICIENT
14     C      TAD   : DAYTIME ROOM TEMPERATURE
15     C      TAN   : NIGHTTIME ROOM TEMPERATURE
16     C      XL    : LENGTH OF SLAB, FT
17     C      YL    : WIDTH OF SLAB, FT
18     C      DX    : SLAB SPACING ALONG XL, FT
19     C      DY    : SLAB SPACING ALONG YL, FT
20     C      ZKS   : GROUND THERMAL CONDUCTIVITY, BTU/FT/HR/F
21     C      UF    : SLAB THERMAL CONDUCTANCE
22     C      E     : WALL THICKNESS, FT
23     C      *** OUTPUT ***
24     C
25     C      CFD    : DAYTIME GROUND FLOOR HEAT TRANSFER
26     C      CFN    : NIGHTTIME GROUND FLOOR HEAT TRANSFER
27     C      COMMON/HR/HRDAY(12),HRNIT(12)
28     C      DIMENSION TOD(12),TON(12),TAD(12),TAN(12),CFD(12),CFN(12)
29     C      R=1./USLAB
30     C      XL=(0.5*P+SQRT(0.25*P*P-4.*AF))/2.
31     C      YL=AF/XL
32     C      XD=AINT(DX/XL)
33     C      YD=AINT(DY/YL)
34     C      CALL SLABR(XL,YL,XD,YD,E,ZKS,R,UF)
35     C      U=1./(1./UF+R)
36     C      DO 10 I=1,12
37     C
38     C      TAM=(TAD(I)*HRDAY(I)+TAN(I)*HRNIT(I))/24.
39     C      CFD(I)=(U*AF*(TAM-TAD(I)))*HRDAY(I)
40     C      CFN(I)=(U*AF*(TAM-TAN(I)))*HRNIT(I)
41     C
42     C      10 CONTINUE
43     C      RETURN
44     C      END

```

QSQSQ5*CONSP6(1).SLABR(17)

```

1 SUBROUTINE SLABR(XL,YL,XD,YD,E,ZKS,RRR,UW)
2 THIS ROUTINE WAS DEVELOPED BY DR. R.W.R. MUNCEY TO CALCULATE HEAT LOSS
3 FROM SLAB ON GRADE
4 CALCULATES P11/P12 AT STEADY STATE
5 C INPUT DATA
6 C XL LENGTH OF SLAB IN X DIRECTION
7 C YL LENGTH OF SLAB IN Y DIRECTION
8 C XD,YD SLAB SPACING IN X AND Y DIRECTIONS
9 C E EDGE DISTANCE CORRESPONDING TO UNIT TEMPERATURE CHANGE
10 C AT THE TANGENT SLOPE AT 'TEMPERATURE' OF 0.5
11 C ZKS GROUND THERMAL CONDUCTIVITY
12 C R SURFACE THERMAL RESISTANCE
13 REAL LAMBDA
14 COMMON /SLAB/ PISQ,ALPHSQ,BETASQ,LAMBDA,R,COM,FSQ,CSQ
15 DIMENSION COM(8),SX(2500),SY(2500)
16 DATA PI/3.14159265/
17 ALPHA=XL*0.5
18 BETA=YL*0.5
19 F=XD
20 G=YD
21 LAMBDA=ZKS
22 R=RRR
23 PISQ=PI*PI
24 WRITE(6,10)
25 WRITE(6,70)
26 10 FORMAT (//20X,'CALCULATION OF U VALUE FOR GROUND WITH FILM R
27 RESISTANCE ABOVE' )
28 70 FORMAT(/69X,'CALC. FROM TEMPERATURE INPUT',2X,'(',4X
29 '1'CALC. FROM HEAT FLOW INPUT' /
30 23X,'WIDTH LENGTH AREA PERIM F G EDGE DIST. LAMBDA FILM R
31 3', 2(6X,'U R=1/U-FILM R L=LAMBDA',2H*R) /)
32 C CONSTANTS
33 ML=F*ALPHA/E @ NL=G*BETA/E
34 NL=G*BETA/E
35 C99 WRITE(6,140) ALPHA,BETA,F,G,ML,NL,E,LAMBDA,R
36 IF(ML.NE.NL.OR.IFIX(F).NE.IFIX(G)) GO TO 74
37 DO 73 J=1,NL
38 XS=PI*FLOAT(J)/F
39 C999 WRITE(6,140) XS
40 S=SIN(XS)/J @ SX(J)=SY(J)=S*S
41 SY(J)=S*S
42 SX(J)=SY(J)
43 73 CONTINUE
44 GO TO 78
45 74 DO 75 J=1,ML
46 XS=PI*FLOAT(J)/F
47 S=SIN(XS)/J @ SX(J)=S*S
48 SX(J)=S*S
49 75 CONTINUE
50 DO 76 J=1,NL
51 XS=PI*FLOAT(J)/G
52 S=SIN(XS)/J @ SY(J)=S*S
53 SY(J)=S*S
54 76 CONTINUE
55 78 CONTINUE
56 FSQ=F*F @ CSQ=G*G
57 CSQ=G*G

```

C 24

```

58 CM1=2*F/(C*LAMBDA*PISQ)          @ CM2=2*F*LAMBDA/(C*PISQ)
59 CM2=2*F*LAMBDA/(C*PISQ)
60 CN1=2*C/(F*LAMBDA*PISQ)          @ CN2=2*C*LAMBDA/(F*PISQ)
61 CN2=2*C*LAMBDA/(F*PISQ)
62 CMN1=4*F*C/(LAMBDA*PISQ*PISQ)    @ CMN2=4*F*C*LAMBDA/(PISQ*PISQ)
63 CMN2=4*F*C*LAMBDA/(PISQ*PISQ)
64 ALPHSQ=ALPHA*ALPHA          @ BETASQ=BETA*BETA
65 BETASQ=BETA*BETA
66 SMT=0.
67 SNW=0.
68 SNT=0.
69 SNW=0.
70 SMNT=0.
71 SMNW=0.
72 DO 110 M=1,ML
73 CALL GAMMAR(M,0,EF,CH)          @ SMW=SMW+CH*SX(M)
74 SMT=SMT+EF*SX(M)
75 SNW=SNW+CH*SX(M)
76 110 CONTINUE
77 DO 130 N=1,NL
78 CALL GAMMAR(0,N,EF,CH)
79 SNT=SNT+EF*SY(N)
80 SNW=SNW+CH*SY(N)
81 DO 120 M=1,ML
82 CALL GAMMAR(M,N,EF,CH)          @ SMNW=SMNW+CH*SX(M)*SY(N)
83 SMNT=SMNT+EF*SX(M)*SY(N)
84 SMNW=SMNW+CH*SX(M)*SY(N)
85 120 CONTINUE
86 130 CONTINUE
87 C P11/P12 = - HEAT FLOW
88 UW=((F*C-1)/(F*C))*((SMW*CM2+SNW*CN2+SMNW*CMN2)
89 RESW=1/UW -R          @ DW=RESW*LAMBDA
90 DW=RESW*LAMBDA
91 C AV. TEMPERATURE OVER SLAB
92 TM=((F*C-1)/(F*C))*((SMT*CH1+SNT*CN1+SMNT*CMN1)
93 C P11/P12 = -1/TM
94 UT=((F*C-1)/(F*C))*2/TM
95 REST=1/UT - R          @ DT=REST*LAMBDA
96 DT=REST*LAMBDA
97 ALPHA2=2*ALPHA
98 BETA2=2*BETA
99 ALPHAB=4*ALPHA*BETA
100 ABETA=4*ALPHA+4*BETA
101 IF=IFIX(F)
102 IC=IFIX(C)
103 WRITE(6,140) ALPHA2,BETA2,ALPHAB,ABETA,IF,IC
104 1,E,LAMBDA,R,UW,RESW,DW,UT,REST,DT
105 140 FORMAT(F6.1,3F7.1,2I4,F8.2,F12.3,F9.2,2(2F9.3,F14.3,2X))
106 145 CONTINUE
107 RETURN
108 END

```

QSQSQ3*CONSP6(1).GAMMAR(4)

```
1      SUBROUTINE GAMMAR(M,N,EF,CH)
2      REAL LAMBDA
3      C THIS IS A SUBROUTINE USED IN SLABR
4      C CALCULATES EF = (1+GAMMA*LAMBDA*R)/GAMMA
5      C CALCULATES CH = GAMMA/(1+GAMMA*LAMBDA*R)
6      C FOR STEADY STATE WITH FILM RESISTANCE R
7      COMMON /SLAB/ PISQ,ALPHSQ,BETASQ,LAMBDA,R,COM,FSQ,CSQ
8      REAL COM(8)
9      IF(M.NE.0) GO TO 20
10     AM=0.
11     GO TO 50
12     20 AM=PISQ*M*M/(FSQ*ALPHSQ)
13     30 IF(N.NE.0) GO TO 50
14     40 AN=0.
15     GO TO 60
16     50 AN=PISQ*N*N/(CSQ*BETASQ)
17     60 A=AM+AN
18     SCAM=SQRT(A)
19     EF=(1.+R*LAMBDA*SCAM)/SCAM
20     CH=1./EF
21     RETURN
22     END
END PRT
```

OPRT,S CONSP6.BSMT,.QECHG,.QC,.INFIL,.QI,.DBRH,.PVSF,.QR,.HLHC,.THTCX,.HCRT,.SEU

C
26

080908*CONSP6(1).BSMT(5)

```

1 SUBROUTINE BSMT (UFW,BWA,BFA,UFLR1,UFF,QBHG,TID,TIN,TC,TOD,TON,
2     1 UBW,UBF,BSMTD,BSMTN,BQFD,BQFN)
3
4     C THIS IS BASEMENT TEMPERATURE CALCULATION
5     C
6     C *** INPUT ***
7     C
8     C BWA = BASEMENT WALL AREA , FT**2
9     C BFA = BASEMENT FLOOR AREA , FT**2
10    C UFLR1 = FLOOR HEAT TRANSFER COEFFICIENT , BT/FT**2.F
11    C UFF = FLOOR-GROUND HEAT TRANSFER COEFFICIENT, =0.1
12    C UFW = WALL-GROUND HEAT TRANSFER COEFFICIENT, =0.164
13    C QBHG = BASEMENT HEAT GAIN FROM FURNACE, BOILER, OR OTHER
14    C EQUIPMENT, BTU/HR
15    C TID = DAYTIME TEMPERATURE OF THE ROOM ABOVE THE BASEMENT ,F
16    C TIN = NIGHTTIME TEMPERATURE OF THE ROOM ABOVE THE BASEMENT
17    C
18    C
19    C
20    C *** OUTPUT ***
21    C
22    C BSMTD = DAYTIME BASEMENT TEMPERATURE
23    C BSMTN = NIGHTTIME BASEMENT TEMPERATURE
24    C BQFD
25    C BQFN
26    C
27    C COMMON/HR/HRDAY(12),HRNIT(12)
28    C DIMENSION TID(12), TIN(12), BSMTD(12), BSMTN(12)
29    C DIMENSION TC(12), TOD(12), TON(12), BQFD(12), BQFN(12)
30    C
31    C UW=UFW
32    C IF(UBW.EQ.0.0) GO TO 20
33    C UW=1.0/(1.0/UFW+1.0/UBW)
34    C 20 UF=UFF
35    C IF(UBF.EQ.0.0) GO TO 30
36    C UF=1.0/(1.0/UFF+1.0/UBF)
37    C 30 CONTINUE
38    C DO 10 I = 1, 12
39    C TO=(TOD(I)*HRDAY(I)+TON(I)*HRNIT(I))/24.
40    C BSMTD(I)=(UW*TO*BWA+UF*TC(I)*BFA+UFLR1*TID(I)*BFA+QBHG)
41    C /((UW*BWA+UF*BFA+UFLR1*BFA)
42    C BSMTN(I)=(UW*TO*BWA+UF*TC(I)*BFA+UFLR1*TIN(I)*BFA+QBHG)
43    C /((UW*BWA+UF*BFA+UFLR1*BFA)
44    C BQFD(I)=(-UW*(TID(I)-TO)*BWA-UF*(TID(I)-TC(I))*BFA)*HRDAY(I)
45    C BQFN(I)=(-UW*(TIN(I)-TO)*BWA-UF*(TIN(I)-TC(I))*BFA)*HRNIT(I)
46    C 10 CONTINUE
47    C RETURN
48    C END

```

C 27

000008*CONSP6(1).QECHG(3)

```
1 SUBROUTINE QECHG (SATD, SATN, U, A, TID, TIN, GD,CN)
2 C
3 C THIS IS OPAQUE ENVELOPE CONDUCTION HEAT GAIN CALCULATIONS
4 C
5 C *** INPUT ***
6 C
7 C SATD : DAYTIME SOL-AIR (OR ATTIC OR CRAWL SPACE) TEMPERATURE
8 C SATN : NIGHTTIME SOL-AIR(OR ATTIC OR CRAWL SPACE) TEMPERATURE
9 C U : OVERALL HEAT TRANSFER COEFFICIENT
10 C A : AREA *
11 C TID : DAYTIME INDOOR TEMPERATURE
12 C TIN : NIGHTTIME INDOOR TEMPERATURE
13 C
14 C *** OUTPUT ***
15 C
16 C GD : DAYTIME HEAT GAIN
17 C CN : NIGHTTIME HEAT GAIN
18 C
19 COMMON/HR/HRDAY(12),HRNIT(12)
20 DIMENSION SATD(12), SATN(12), TID(12), TIN(12), GD(12), CN(12)
21 C
22 DO 10 I=1,12
23 GD(I)=U*A*(SATD(I)-TID(I)) * HRDAY(I)
24 CN(I)=U*A*(SATN(I)-TIN(I)) * HRNIT(I)
25 10 CONTINUE
26 RETURN
27 END
```

Q3Q3*CONSP6(1).QC(9)

```

1  SUBROUTINE QG (AC, SC, UC, TOD, TON, TID, TIN, SHDW, XIDT, XIDD,
2      QGD, QGN, SCD)
3      C  THIS IS WINDOW HEAT GAIN ROUTINE
4      C
5      C  *** INPUT ***
6      C
7      C      AC      : GLASS AREA
8      C      SC      : SHADING COEFFICIENT
9      C      UC      : HEAT TRANSFER COEFFICIENT
10     C      TOD     : DAYTIME OUTDOOR TEMPERATURE
11     C      TON     : NIGHTTIME OUTDOOR TEMPERATURE
12     C      TID     : DAYTIME INDOOR TEMPERATURE
13     C      TIN     : NIGHTTIME INDOOR TEMPERATURE
14     C      SHDW    : EXTERNAL SHADOW FACTOR
15     C                  0.0 = NO SHADOW
16     C                  0.5 = PARTIAL SHADOW
17     C                  1.0 = COMPLETE SHADOW
18     C      XIDT    : DAILY TOTAL RADIATION
19     C      XIDD    : DAILY DIFFUSE RADIATION
20     C
21     C  *** OUTPUT ***
22     C
23     C      QGD     : DAYTIME WINDOW HEAT GAIN
24     C      QGN     : NIGHTTIME WINDOW HEAT GAIN
25     C
26     COMMON/HR/HRDAY(12),HRNIT(12)
27     DIMENSION TOD(12), TON(12), TID(12), TIN(12), XIDT(12), XIDD(12),
28     QGD(12), QGN(12), SCD(12)
29     REAL I
30     DO 10 J = 1, 12
31     I = (XIDT(J) - XIDD(J)) * (1.0 - SHDW) + XIDD(J)
32     SCD(J) = AC * I * SC
33     QGD(J) = AC * (I * SC * 0.87 + UC * (TOD(J) - TID(J)) * HRDAY(J))
34     QGN(J) = AC * (UC * (TON(J) - TIN(J)) * HRNIT(J))
35 10 CONTINUE
36     RETURN
37     END

```

C 29

020202*CONSP6(1).INFIL(10)

```
1      SUBROUTINE INFIL (V, ACHS, TOD, TON, TID, TIN, WS,  
2          RINFIL, K, L, IACNV)  
3      THIS IS INFILTRATION CALCULATION ROUTINE  
4  
5      *** INPUT ***  
6  
7      V      = VOLUME OF THE ROOM  
8      ACHS   = STANDARD AIR CHANGE DATA  
9      TOD    = DAYTIME OUTDOOR TEMPERATURE  
10     TON    = NIGHTTIME OUTDOOR TEMPERATURE  
11     TID    = DAYTIME INDOOR TEMPERATURE  
12     TIN    = NIGHTTIME INDOOR TEMPERATURE  
13     WS     = WIND SPEED  
14  
15     *** OUTPUT ***  
16  
17     RINFIL = INFILTRATION RATE  
18  
19     DIMENSION TOD(12), TON(12), TID(12), TIN(12), RINFIL(12)  
20     DIMENSION WS(12)  
21  
22     DO 10 I = 1, 12  
23     TO = ( TOD( I) + TON( I) ) / 2.0  
24     TI = ( TID( I) + TIN( I) ) / 2.0  
25     AC = ACHS / 0.693 * (0.15 + 0.013 * WS(I) + 0.005 * ABS(TO - TI))  
26     RINFIL( I) = V * AC / 60.0  
27 10 CONTINUE  
28     RETURN  
29     END
```

C-30

Q3Q3Q3*CONSP6(1).Q1(10)

1 SUBROUTINE Q1 (INFILT,TOD, TON, TID, TIN, RH, QID, QIN, QILD,
2 QILN, RHM, RHA)
3
4 THIS IS INFILTRATION HEAT GAIN CALCULATION ROUTINE
5
6 *** INPUT ***
7
8 INFIL = INFILTRATION RATE CFM
9 TOD = DAYTIME OUTDOOR TEMPERATURE
10 TON = NIGHTTIME OUTDOOR TEMPERATURE
11 TID = DAYTIME INDOOR TEMPERATURE
12 TIN = NIGHTTIME INDOOR TEMPERATURE
13 RH = ROOM RELATIVE HUMIDITY
14 RHM = MORNING OUTDOOR RELATIVE HUMIDITY
15 RHA = AFTERNOON OUTDOOR RELATIVE HUMIDITY
16
17 *** OUTPUT ***
18
19 QID = DAYTIME SENSIBLE HEAT GAIN
20 QIN = NIGHTTIME SENSIBLE HEAT GAIN
21 QILD = DAYTIME LATENT HEAT GAIN
22 QILN = NIGHTTIME LATENT HEAT GAIN
23
24 COMMON/HR/HRDAY(12),HRNIT(12)
25 DIMENSION TOD(12), TON(12), TID(12), TIN(12), RH(2, 12),
26 QID(12), QIN(12), QILD(12), QILN(12), WID(12), WIN(12),
27 WOD(12), WON(12),RHM(12),RHA(12)
28 REAL INFILT(12)
29 DO 10 I = 1,12
30 QID(I) = 1.05 * INFILT(I)* (TOD(I) - TID(I)) * HRDAY(I)
31 QIN(I) = 1.05 * INFILT(I)* (TON(I) - TIN(I)) * HRNIT(I)
32 10 CONTINUE
33
34 DO 20 I = 1, 12
35 CALL DBRH (TID(I), RH(1, I), WID(I))
36 CALL DBRH (TIN(I), RH(2, I), WIN(I))
37 CALL DBRH (TOD(I),RHA(I),WOD(I))
38 CALL DBRH (TON(I),RHM(I),WON(I))
39 QILD(I) = 4.5 * INFILT(I)* (WOD(I) - WID(I)) * 1061.0 * HRDAY(I)
40 QILN(I) = 4.5 * INFILT(I)* (WON(I) - WIN(I)) * 1061.0 * HRNIT(I)
41 20 CONTINUE
42 RETURN
43 END

Q3Q2Q3*CONSP6(1).DBRH(2)

1
2
3
4
5
6
7
8
9
10
11

C
C
C
C
C
C
C
C
C
C
C

SUBROUTINE DHRH (DB,RH,W)

PSYCHROMETRIC ROUTINE TO DETERMINE HUMIDITY RATIO, GIVEN DB AND RH

PVS=PVSF(DB)

PV=RH*PVS/100.

W=0.622*PV/(29.92-PV)

RETURN

END

000002*CONSP6(1).PVSF(2)

```

1
2      C      FUNCTION PVSF (X)
3      C      SATURATION VAPOR PRESSURE, INCHES OF MERCURY
4      C      *****
5      DIMENSION A(6) /-7.90298,5.02E08,-1.3816E-7,11.344,
6      2 B.1323E-3,-3.49149/ ,B(4) /-9.09718,-3.56E54,0.876793,0.0060273/
7      3,P(4)
8      T=(X+459.688)/1.8
9      IF (T.LT.273.16) GO TO 10
10     Z=373.16/T
11     P(1)=A(1)*(Z-1)
12     P(2)=A(2)*LOG10(Z)
13     Z1=A(4)*(1-1/Z)
14     P(3)=A(3)*(10**Z1-1)
15     Z1=A(6)*(Z-1)
16     P(4)=A(5)*(10**Z1-1)
17     GO TO 20
18     C
19     10     Z=273.16/T
20     P(1)=B(1)*(Z-1)
21     P(2)=B(2)*LOG10(Z)
22     P(3)=B(3)*(1-1/Z)
23     P(4)=LOG10(B(4))
24     20     SUM=0
25     DO 30 I=1,4
26     30     SUM=SUM+P(I)
27     PVSF=29.92!*10**SUM
28     RETURN
29     C
30     END

```

C 33

C
34

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31

CCCCCCCCCCCCCCCCCC

CCCCCCCC

CCCCCCCC

CCCCCCCC

CCCCC

C

C

C

C

C35 C35 Q3Q3*CONSP6(1).HLHC(57)

```

1      SUBROUTINE HLHC(QID,QIN,QWD,QWN,QDD,QDN,QCD,QCN,QFD,QFN,THTC,PUH,
2      *QRD,QRN,QTD,QTN,HC,HL,QCD,QCN,K,L,TIN,TON,TID,TOD,IACNV,SGD,ICHECK
3      *,TIC,TIH,ZK)
4      THIS IS HEAT LOSS AND HEAT GAIN CALCULATIONS
5
6      *** INPUT ***
7      QCD : DAYTIME CEILING HEAT GAIN
8      QID : DAYTIME INFILTRATION HEAT GAIN
9      QIN : NIGHTTIME INFILTRATION HEAT GAIN
10     QWD : DAYTIME WALL HEAT GAIN
11     QWN : NIGHTTIME WALL HEAT GAIN
12     QDD : DAYTIME DOOR HEAT GAIN
13     QDN : NIGHTTIME DOOR HEAT GAIN
14     QCD : DAYTIME WINDOW HEAT GAIN
15     QCN : NIGHTTIME WINDOW HEAT GAIN
16     QFD : DAYTIME FLOOR HEAT GAIN
17     QFN : NIGHTTIME FLOOR HEAT GAIN
18     QRD : DAYTIME INTERNAL HEAT GAIN
19     QRN : NIGHTTIME INTERNAL HEAT GAIN
20     THTC : THERMAL TIME CONSTANT
21     QCN : NIGHTTIME CEILING HEAT GAIN
22     SGD : DAYTIME SOLAR HEAT GAIN
23     PUH : PICK UP HOURS
24     IACNV : NATURAL VENTILATION INDEX
25             = 0 IF WINDOW ALWAYS CLOSED
26             = 1 IF WINDOW OPENS WHEN OUTDOOR TEMPERATURE IS LESS THAN THE
27               THERMOSTAT SET POINT IN SUMMER
28     TIC : COOLING THERMOSTAT SETTING -- NOT USED
29     TIH : HEATING THERMOSTAT SETTING -- NOT USED
30     ZK : OVERALL HEAT TRANSFER FACTOR
31     K : FIRST COOLING MONTH
32     L : LAST COOLING MONTH
33
34     *** OUTPUT ***
35     QTD : DAYTIME HEAT LOSS AND HEAT GAIN
36     QTN : NIGHTTIME HEAT LOSS AND HEAT GAIN
37     HL : DAILY HEAT LOSS
38     HC : DAILY HEAT GAIN
39
40     COMMON/HR/HRDAY(12),HRNIT(12)
41     DIMENSION QID(12),QIN(12),QWD(12),QWN(12),QDD(12),QDN(12),
42     *QCD(12),QCN(12),QFD(12),QFN(12),QRD(12),QRN(12),
43     *QTD(12),QTN(12),HC(12),HL(12),QCD(12),QCN(12),
44     *TIN(12),TON(12),TID(12),TOD(12),SGD(12),AA(10),
45     *BB(10,12),ZK(12)
46     DATA AA/2HZK,4HDHCD,4HDHWU,3HPUH,6HPULDN,6HPICKUP,3HCLD,3HCLN,
47     *3HHLD,3HHLN/
48     DO 10 I=1,12
49     HLD=0.
50     CLD=0.
51     HLN=0.
52     CLN=0.
53     PICKUP=0.
54     PULDN=0.
55     DRCD=0.
56     DHWU=0.
57     QTD(I)=QID(I)+QWD(I)+QDD(I)+QCD(I)+QFD(I)+QRD(I)+QCN(I)

```

```

58 QTN(1)=QIN(1)+QWN(1)+QDN(1)+QCN(1)+QFN(1)+QRN(1)+QCN(1)
59 IF(TID(1).NE.TIN(1)) GO TO 11
60 IF(QTD(1).GT.0.) CLD=QTD(1)
61 IF(QTN(1).GT.0.) CLN=QTN(1)
62 IF(QTD(1).LT.0.) HLD=QTD(1)
63 IF(QTN(1).LT.0.) HLN=QTN(1)
64 GO TO 9
65 11 IF(QTD(1).GE.0.AND.QTN(1).GE.0.AND.TID(1).GE.TIN(1)) IX=1
66 IF(QTD(1).GE.0.AND.QTN(1).GE.0.AND.TID(1).LT.TIN(1)) IX=2
67 IF(QTD(1).GE.0.AND.QTN(1).LE.0.AND.TID(1).GE.TIN(1)) IX=3
68 IF(QTD(1).GE.0.AND.QTN(1).LT.0.AND.TID(1).LT.TIN(1)) IX=4
69 IF(QTD(1).LE.0.AND.QTN(1).LE.0.AND.TID(1).GE.TIN(1)) IX=5
70 IF(QTD(1).LE.0.AND.QTN(1).LE.0.AND.TID(1).LT.TIN(1)) IX=6
71 IF(QTD(1).LT.0.AND.QTN(1).GE.0.AND.TID(1).GE.TIN(1)) IX=7
72 IF(QTD(1).LT.0.AND.QTN(1).GE.0.AND.TID(1).LT.TIN(1)) IX=8
73 GO TO (1,2,3,4,5,6,7,8), IX
74 1 DT=TID(1)-TID(1)
75 CALL THTCX(TON(1),TID(1),DT,PULDOWN,ZK(1),PUH,THTC,2)
76 DT=TID(1)-TIN(1)
77 Q=(QRD(1)+SCD(1))/HRDAY(1)
78 CALL THTCX(TOD(1),TIN(1),DT,Q,ZK(1),DHWU,THTC,1)
79 IF(DHWU.GE.HRDAY(1)) DHWU=HRDAY(1)
80 CLD=QTD(1)*(1.-DHWU/HRDAY(1))
81 CLN=PULDOWN*PUH+QTN(1)*(1.-PUH/HRNIT(1))
82 GO TO 9
83 2 DT=TIN(1)-TID(1)
84 Q=QRN(1)/HRNIT(1)
85 CALL THTCX(TON(1),TID(1),DT,Q,ZK(1),DHWU,THTC,1)
86 IF(DHWU.GE.HRNIT(1)) DHWU=HRNIT(1)
87 DT=TID(1)-TIN(1)
88 CALL THTCX(TOD(1),TIN(1),DT,PULDOWN,ZK(1),PUH,THTC,2)
89 CLD=QTD(1)*(1.-PUH/HRDAY(1))+PULDOWN*PUH
90 CLN=QTN(1)*(1.-DHWU/HRNIT(1))
91 GO TO 9
92 3 DT=TIN(1)-TID(1)
93 Q=QRN(1)/HRNIT(1)
94 CALL THTCX(TON(1),TID(1),DT,Q,ZK(1),DHCD,THTC,1)
95 IF(DHCD.LT.HRNIT(1)) DHCD=HRNIT(1)
96 DT=TID(1)-TIN(1)
97 Q=(QRD(1)+SCD(1))/HRDAY(1)
98 CALL THTCX(TOD(1),TIN(1),DT,Q,ZK(1),DHWU,THTC,1)
99 IF(DHWU.GE.HRDAY(1)) DHWU=HRDAY(1)
100 HLN=QTN(1)*(1.-DHCD/HRNIT(1))
101 CLD=QTD(1)*(1.-DHWU/HRDAY(1))
102 GO TO 9
103 4 DT=TIN(1)-TID(1)
104 CALL THTCX(TON(1),TID(1),DT,PICKUP,ZK(1),PUH,THTC,2)
105 DT=TID(1)-TIN(1)
106 CALL THTCX(TOD(1),TIN(1),DT,PULDOWN,ZK(1),PUH,THTC,2)
107 CLD=QTD(1)*(1.-PUH/HRDAY(1))+PICKUP*PUH
108 HLN=QTN(1)*(1.-PUH/HRNIT(1))+PULDOWN*PUH
109 GO TO 9
110 5 DT=TID(1)-TIN(1)
111 CALL THTCX(TOD(1),TIN(1),DT,PICKUP,ZK(1),PUH,THTC,2)
112 Q=QRN(1)/HRNIT(1)
113 DT=TIN(1)-TID(1)
114 CALL THTCX(TON(1),TID(1),DT,Q,ZK(1),DHCD,THTC,1)
115 IF(DHCD.GE.HRNIT(1)) DHCD=HRNIT(1)

```

```

116 HLN=QTN(I)*(1.-DHCD/HRNIT(I))
117 HLD=QTD(I)*(1.-PUH/HRDAY(I))+PICKUP*PUH
118 GO TO 9
119 6 DT=TIN(I)-TID(I)
120 CALL THTCX(TON(I),TID(I),DT,PICKUP,ZK(I),PUH,THTC,2)
121 Q=(QRD(I)+SGD(I))/HRDAY(I)
122 DT=TID(I)-TIN(I)
123 CALL THTCX(TOD(I),TIN(I),DT,Q,ZK(I),DHCD,THTC,1)
124 IF(DHCD.GE.HRDAY(I)) DHCD=HRDAY(I)
125 HLD=QTD(I)*(1.-DHCD/HRDAY(I))
126 HLN=PICKUP*PUH+QTN(I)*(1.-PUH/HRNIT(I))
127 GO TO 9
128 7 DT=TIN(I)-TID(I)
129 CALL THTCX(TON(I),TID(I),DT,PULDWN,ZK(I),PUH,THTC,2)
130 DT=TID(I)-TIN(I)
131 CALL THTCX(TOD(I),TIN(I),DT,PICKUP,ZK(I),PUH,THTC,2)
132 HLD=PICKUP*PUH+QTD(I)*(1.-PUH/HRDAY(I))
133 CLN=PULDWN*PUH+QTN(I)*(1.-PUH/HRNIT(I))
134 GO TO 9
135 8 DT=TID(I)-TIN(I)
136 Q=(QRD(I)+SGD(I))/HRDAY(I)
137 CALL THTCX(TOD(I),TIN(I),DT,Q,ZK(I),DHCD,THTC,1)
138 IF(DHCD.GE.HRDAY(I)) DHCD=HRDAY(I)
139 DT=TIN(I)-TID(I)
140 Q=QRN(I)/HRNIT(I)
141 CALL THTCX(TON(I),TID(I),DT,Q,ZK(I),DHWU,THTC,1)
142 IF(DHWU.GE.HRNIT(I)) DHWU=HRNIT(I)
143 HLD=QTD(I)*(1.-DHCD/HRDAY(I))
144 CLN=QTN(I)*(1.-DHWU/HRNIT(I))
145 9 HC(I)=CLD+CLN
146 HL(I)=HLD+HLN
147 BB(1,I)=ZK(I)
148 BB(2,I)=DHCD
149 BB(3,I)=DHWU
150 BB(4,I)=PUH
151 BB(5,I)=PULDWN
152 BB(6,I)=PICKUP
153 BB(7,I)=CLD
154 BB(8,I)=CLN
155 BB(9,I)=HLD
156 BB(10,I)=HLN
157 10 CONTINUE
158 DC 20 J=1,10
159 IF(JCHECK.EQ.1) WRITE(6,2000) AA(J),(BB(J,KK),KK=1,12)
160 2000 FORMAT(1H ,A6,12G10.4)
161 20 CONTINUE
162 RETURN
163 END

```

020206*CONSP6(1).THTCX(5)

```

1 SUBROUTINE THTCX(TO,TI,DT,Q,ZK,DH,THTC,IX)
2 C TO OUTSIDE TEMPERATURE
3 C TI INITIAL INDOOR TEMPERATURE, F
4 C DT TEMPERATURE RISE AFTER DH HOURS
5 C Q INTERNAL HEAT GAIN, BTU/DAY
6 C ZK HEAT LOSS FACTOR, BTU/(HR)(F)
7 C DH TIME DURATION, HR
8 C THTC THERMAL TIME CONSTANT
9 C IX CALCULATION INDEX
10 C IX = 1 CALCULATE DH
11 C IX = 2 CALCULATE ZQ
12 C IX = 3 CALCULATE DT
13 C WRITE(6,5) TO,TI,DT,Q,ZK,DH,THTC,IX
14 C 5 FORMAT(' TO='F12.6,' TI='F12.6,' DT='F12.6,' Q='F12.6,
15 C * ' ZK='F12.6,' DH='F12.6,' THTC='F12.6,' IX='I2)
16 IF(IX.EQ.1) GO TO 1
17 Z1=EXP(-DH/THTC)
18 Z2=1.-Z1
19 1 GO TO (2,3,4), IX
20 2 Z3=TO-TI+Q/ZK
21 Z4=TO-(TI+DT)+Q/ZK
22 Z6=Z3/Z4
23 IF(Z6) 5,5,6
24 5 DH=24.
25 RETURN
26 C WRITE(6,6) Z3,Z4,Z6
27 C 6 FORMAT(' Z3='F12.6,' Z4='F12.6,' Z6='F12.6)
28 6 Z5=ALC(X(Z3/Z4))
29 DH=THTC*Z5
30 IF(DH.LE.0.) DH=24.
31 RETURN
32 3 Z6=TI-TO
33 Z7=Z6+DT/Z2
34 Q=-ZK*Z7
35 RETURN
36 4 Z3=TO-TI+Q/ZK
37 DT=Z3*Z2
38 RETURN
39 END

```

Q3Q3Q3*CONSP6(1).HCRT(7)

```
1 SUBROUTINE HCRT (HL, HG, LHC, HREQ, CREQ, AIRLOS)
2 C
3 C THIS IS HEATING AND COOLING REQUIREMENT ROUTINE
4 C
5 C *** INPUT ***
6 C
7 C HL : SENSIBLE HEAT LOSS
8 C HG : SENSIBLE HEAT GAIN
9 C LHC : LATENT HEAT GAIN
10 C AIRLOS : AIR LEAKAGE THROUGH DUCTS, PERCENT OF DELIVERED AIR
11 C
12 C
13 C *** OUTPUT ***
14 C
15 C HREQ : HEATING REQUIREMENT
16 C CREQ : COOLING REQUIREMENT
17 C
18 C DIMENSION HL(12), HG(12), LHC(12), HREQ(12), CREQ(12)
19 C REAL LHC
20 C DO 10 I = 1, 12
21 C HREQ(I) = (HL(I)+LHC(I)) * (1.0 + AIRLOS/100.0)
22 C IF(HREQ(I).GE.0.) HREQ(I)=0.
23 C CREQ(I) = (HG(I) + LHC(I))*(1.0 + AIRLOS/100.0)
24 C 1) CONTINUE
25 C RETURN
26 C END
```

QSQSQ*CONSP6(1).SEU(10)

```
1 SUBROUTINE SEU(SA,SB,TE,TOD,I,SUF,AS,QS,ISOLHW,ISOLSH)
2 C
3 C THIS IS SOLAR ENERGY UTILIZATION
4 C
5 C *** INPUT ***
6 C
7 C SA : COLLECTOR NORMAL EFFICIENCY CURVE DATA A
8 C SB : COLLECTOR NORMAL EFFICIENCY CURVE DATA B
9 C TE : INLET FLUID TEMPERATURE
10 C TOD : DAYTIME OUTDOOR TEMPERATURE
11 C I : DAILY TOTAL SOLAR RADIATION
12 C SUF : SOLAR HEAT UTILIZATION FACTOR
13 C AS : COLLECTOR AREA
14 C ISOLHW : SOLAR HOT WATER INDEX, 0 FOR NO, 1 FOR YES
15 C ISOLSH : SOLAR SPACE HEATING INDEX, 0 FOR NO, 1 FOR YES
16 C
17 C *** OUTPUT ***
18 C
19 C QS : SOLAR HEAT UTILIZED
20 C
21 COMMON/HR/HRDAY(12),HRNIT(12)
22 DIMENSION TE(12),TOD(12),I(12),QS(12)
23 REAL I
24 C
25 DO 10 J=1,12
26 QS(J)=0.0
27 IF (ISOLHW.EQ.0.AND.ISOLSH.EQ.0) GO TO 10
28 QS(J)=AS*SA*(1.0-HRDAY(J)*(TE(J)-TOD(J))/SB/I(J))*SUF*I(J)
29 IF ((TE(J)-TOD(J))/I(J).GT.SB) QS(J) = 0.0
30 IF ((TE(J)-TOD(J))/I(J).LT.0.) QS(J) = AS*SA*SUF*I(J)
31 10 CONTINUE
32 RETURN
33 END
```

END PRT

@PRT,S CONSP6.EREQ,.BWHREQ,.CSDUPI,.ASDUPI,.BMDUPI,.QSDUPI,.ZKDN,.PSY2,.WBF

050505*CONSP6(1).EREQ(14)

```

1      SUBROUTINE EREQ(HREQ,CREQ,EH,EC,ISYS,SHBTU,SCBTU,WHREQ,QS,QQC,QQH)
2
3      C      THIS IS ENERGY REQUIREMENT CALCULATION ROUTINE
4
5      C      *** INPUT ***
6
7      C      HREQ : HEATING REQUIREMENT
8      C      CREQ : COOLING REQUIREMENT
9      C      EH   : HEATING EFFICIENCY
10     C      EC   : COOLING EFFICIENCY
11     C      WHREQ : HOT WATER HEATING REQUIREMENT
12     C      QS    : ENERGY FROM SOLAR COLLECTOR
13     C      QQC   : HEAT GAIN THROUGH DUCTS & PIPES
14     C      QQH   : HEAT LOSS THROUGH DUCTS & PIPES
15     C      ISYS  : SYSTEM INDEX
16     C              1 = HEATING + NO COOLING
17     C              2 = NO HEATING + COOLING
18     C              3 = HEATING + COOLING
19
20     C      *** OUTPUT ***
21
22     C      SHBTU : HEATING ENERGY REQUIREMENT AFTER USING ENERGY FROM SOLAR
23     C               COLLECTOR, INCLUDING HOT WATER ENERGY REQUIREMENT
24     C      SCBTU : SPACE COOLING ENERGY REQUIREMENT
25
26     C      DIMENSION HREQ(12),CREQ(12),WHREQ(12),QS(12),QQC(12),QQH(12)
27
28     C      GO TO (100,101,102), ISYS
29
30     C      100 SCBTU=0.0
31     C      SHBTU=0.0
32     C      DO 200 I=1,12
33     C      X=(HREQ(I)+WHREQ(I)+QS(I)+QQH(I))/EH
34     C      IF(X.GT.0.0) X=0.0
35     C      SHBTU=SHBTU+X
36     C      200 CONTINUE
37     C      GO TO 999
38
39     C      101 SHBTU=0.0
40     C      SCBTU=0.0
41     C      DO 201 I=1,12
42     C      Y=(WHREQ(I)+QS(I))/EH
43     C      IF(Y.GT.0.0) Y=0.0
44     C      SHBTU=SHBTU+Y
45     C      SCBTU=SCBTU+(CREQ(I)+QQC(I))/EC
46     C      201 CONTINUE
47     C      GO TO 999
48
49     C      102 SHBTU=0.0
50     C      SCBTU=0.0
51     C      DO 202 I=1,12
52     C      Z=(HREQ(I)+WHREQ(I)+QS(I)+QQH(I))/EH
53     C      IF(Z.GT.0.0) Z=0.0
54     C      SHBTU=SHBTU+Z
55     C      SCBTU=SCBTU+(CREQ(I)+QQC(I))/EC
56     C      202 CONTINUE
57

```

999 RETURN
END

58
59

C 42

000000*CONSP6(1).HWHREQ(12)

1 SUBROUTINE HWHREQ(TOUT,TIN,HWT,A,BSMTD,BSMTN,D1,RAM1,D2,RAM2,
2 HLHWH1,HLHWH2,SAVE,WHREQ)
3
4 C THIS IS HOT WATER HEATING REQUIREMENT ROUTINE
5 C *** INPUT ***
6 C
7 C TOUT : HOT WATER OUTLET TEMPERATURE
8 C TIN : HOT WATER INLET TEMPERATURE = GROUND TEMPERATURE
9 C HWT : HOT WATER USAGE 75. GALLON/DAY
10 C A : TOTAL JACKET AREA
11 C BSMTD : DAYTIME BASEMENT TEMPERATURE
12 C BSMTN : NIGHTTIME BASEMENT TEMPERATURE
13 C D1 : THICKNESS OF ALREADY INSTALLED INSULATION
14 C RAM1 : THERMAL CONDUCTIVITY OF ALREADY INSTALLED INSULATION
15 C D2 : THICKNESS OF ADDITIONAL INSULATION
16 C RAM2 : THERMAL CONDUCTIVITY OF ADDITIONAL INSULATION
17 C
18 C *** OUTPUT ***
19 C
20 C HLHWH1 : HEAT LOSS THROUGH NON-ADDITIONAL JACKET
21 C HLHWH2 : HEAT LOSS THROUGH ADDITIONAL JACKET
22 C SAVE : ENERGY SAVING BY ADDITIONAL INSULATION
23 C WHREQ : HOT WATER HEATING REQUIREMENT
24 C
25 COMMON/HR/HRDAY(12),HRNIT(12)
26 DIMENSION TIN(12),WHREQ(12),BSMTD(12),BSMTN(12),HLHWH1(12),
27 HLHWH2(12),SAVE(12)
28 C
29 UX=0.685
30 IF(RAM1.EQ.0.0) GO TO 10
31 UX=0.685+D1/RAM1
32 10 U1=1.0/UX
33 C
34 UY=0.685
35 IF(RAM1.NE.9.0.AND.RAM2.NE.0.0) UY=0.685+D1/RAM1+D2/RAM2
36 IF(RAM1.NE.0.0.AND.RAM2.EQ.0.0) UY=0.685+D1/RAM1
37 IF(RAM1.EQ.0.0.AND.RAM2.NE.0.0) UY=0.685+D2/RAM2
38 U2=1.0/UY
39 C
40 DO 20 I=1,12
41 QD1=U1*A*(BSMTD(I)-TOUT)*HRDAY(I)
42 QN1=U1*A*(BSMTN(I)-TOUT)*HRNIT(I)
43 QD2=U2*A*(BSMTD(I)-TOUT)*HRDAY(I)
44 QN2=U2*A*(BSMTN(I)-TOUT)*HRNIT(I)
45 HLHWH1(I)=QD1+QN1
46 HLHWH2(I)=QD2+QN2
47 SAVE(I)=HLHWH2(I)-HLHWH1(I)
48 WHREQ(I)=590.0/60.0*(TIN(I)-TOUT)*HWT+HLHWH2(I)
49 IF(WHREQ(I).GT.0.0) WHREQ(I)=0.0
50 20 CONTINUE
51 RETURN
52 END

QSQSQS*CONSP5(1).CSDUPI(5)

```

1      SUBROUTINE CSDUPI(ADUCT, UDUCT, APIPE, UPIPE, TCSUPA, TCSUPW, THSUPA,
2      1      THSUPW, CRAWLD, CRAWLN, NSTART, NLAST, QC, QH,
3      2      CFAC, HFAC)
4      C      THIS IS HEAT LOSS & GAIN THROUGH DUCTS & PIPES IN CRAWL SPACE
5      C
6      C      *** INPUT ***
7      C      ADUCT = TOTAL SURFACE AREA OF DUCT IN CRAWL SPACE
8      C      UDUCT = U VALUE OF DUCT
9      C      APIPE = TOTAL SURFACE AREA OF PIPE IN CRAWL SPACE
10     C      UPIPE = U VALUE OF PIPE
11     C      TCSUPA = SUPPLY CHILLED AIR TEMPERATURE
12     C      TCSUPW = SUPPLY CHILLED WATER TEMPERATURE
13     C      THSUPA = SUPPLY HOT AIR TEMPERATURE
14     C      THSUPW = SUPPLY HOT WATER TEMPERATURE
15     C      CRAWLD = DAYTIME CRAWL TEMPERATURE
16     C      CRAWLN = NIGHTTIME CRAWL TEMPERATURE
17     C
18     C      *** OUTPUT ***
19     C
20     C      QC = HEAT GAIN THROUGH DUCTS & PIPES
21     C      QH = HEAT LOSS THROUGH DUCTS & PIPES
22     C
23     COMMON/HR/HRDAY(12), HRNIT(12)
24     DIMENSION CRAWLD(12), CRAWLN(12), QC(12), QH(12),
25     1      CFAC(12), HFAC(12)
26     C
27     DO 10 I=1,12
28     DUCTCD=ADUCT*UDUCT*(CRAWLD(I)-TCSUPA)*HRDAY(I)*CFAC(I)
29     DUCTCN=ADUCT*UDUCT*(CRAWLN(I)-TCSUPA)*HRNIT(I)*CFAC(I)
30     PIPECD=APIPE*UPIPE*(CRAWLD(I)-TCSUPW)*HRDAY(I)*CFAC(I)
31     PIPECN=APIPE*UPIPE*(CRAWLN(I)-TCSUPW)*HRNIT(I)*CFAC(I)
32     QC(I)=DUCTCD+DUCTCN+PIPECD+PIPECN
33     IF(I.LT.NSTART.OR.I.GT.NLAST) QC(I)=0.0
34     DUCTCD=ADUCT*UDUCT*(CRAWLD(I)-THSUPA)*HRDAY(I)*HFAC(I)
35     DUCTCN=ADUCT*UDUCT*(CRAWLN(I)-THSUPA)*HRNIT(I)*HFAC(I)
36     PIPECD=APIPE*UPIPE*(CRAWLD(I)-THSUPW)*HRDAY(I)*HFAC(I)
37     PIPECN=APIPE*UPIPE*(CRAWLN(I)-THSUPW)*HRNIT(I)*HFAC(I)
38     QH(I)=DUCTCD+DUCTCN+PIPECD+PIPECN
39     IF(I.GE.NSTART.AND.I.LE.NLAST) QH(I)=0.0
40 10 CONTINUE
41     RETURN
42     END

```

030603*CONSP6(1).ASDUP1(4)

```

1 SUBROUTINE ASDUP1(ADUCT,UDUCT,APIPE,UPIPE,TCSUPA,TCSUPW,THSUPA,
2 THSUPW,ATD,ATN,NSTART,NLAST,QC,QH,CFAC,HFAC)
3 THIS IS HEAT LOSS & GAIN THROUGH DUCTS & PIPES IN ATTIC SPACE
4
5 *** INPUT ***
6 ADUCT : TOTAL SURFACE AREA OF DUCT IN ATTIC SPACE
7 UDUCT : U VALUE OF DUCT
8 APIPE : TOTAL SURFACE AREA OF PIPE IN ATTIC SPACE
9 UPIPE : U VALUE OF PIPE
10 TCSUPA : SUPPLY CHILLED AIR TEMPERATURE
11 TCSUPW : SUPPLY CHILLED WATER TEMPERATURE
12 THSUPA : SUPPLY HOT TEMPERATURE
13 THSUPW : SUPPLY HOT WATER TEMPERATURE
14 ATD : ATTIC DAYTIME TEMPERATURE
15 ATN : ATTIC NIGHTTIME TEMPERATURE
16
17 *** OUTPUT ***
18
19 QC : HEAT GAIN THROUGH DUCTS & PIPES
20 QH : HEAT LOSS THROUGH DUCTS & PIPES
21
22 COMMON/HR/HRDAY(12),HRNIT(12)
23 DIMENSION ATD(12), ATN(12), QC(12), QH(12),CFAC(12),HFAC(12)
24
25 DO 10 I=1,12
26 DUCTAD=ADUCT*UDUCT*(ATD(I)-TCSUPA)*HRDAY(I)*CFAC(I)
27 DUCTAN=ADUCT*UDUCT*(ATN(I)-TCSUPA)*HRNIT(I)*CFAC(I)
28 PIPEAD=APIPE*UPIPE*(ATD(I)-TCSUPW)*HRDAY(I)*CFAC(I)
29 PIPEAN=APIPE*UPIPE*(ATN(I)-TCSUPW)*HRNIT(I)*CFAC(I)
30 QC(I)=DUCTAD+DUCTAN+PIPEAD+PIPEAN
31 IF(I.LT.NSTART.OR.I.GT.NLAST) QC(I)=0.0
32 DUCTAD=ADUCT*UDUCT*(ATD(I)-THSUPA)*HRDAY(I)*HFAC(I)
33 DUCTAN=ADUCT*UDUCT*(ATN(I)-THSUPA)*HRNIT(I)*HFAC(I)
34 PIPEAD=APIPE*UPIPE*(ATD(I)-THSUPW)*HRDAY(I)*HFAC(I)
35 PIPEAN=APIPE*UPIPE*(ATN(I)-THSUPW)*HRNIT(I)*HFAC(I)
36 QH(I)=DUCTAD+DUCTAN+PIPEAD+PIPEAN
37 IF(I.LE.NSTART.AND.I.LE.NLAST) QH(I)=0.0
38 10 CONTINUE
39 RETURN
40 END

```

020202*CORSP6(1).BMDUP1(8)

```

1      SUBROUTINE BMDUP1(ADUCT, UDUCT, APIPE, UPIPE, TCSUPA, TCSUPW, THSUPA,
2      THSUPW, BSMTD, BSMTN, NSTART, NLAST, INDEXC, QC, QH,
3      CFAC, EFAC)
4      C
5      C      THIS IS HEAT LOSS & GAIN THROUGH DUCTS & PIPES IN BASEMENT
6      C
7      C      *** INPUT ***
8      C
9      C      ADUCT : TOTAL SURFACE AREA OF DUCT IN BASEMENT
10     C      UDUCT : U VALUE OF DUCT
11     C      APIPE : TOTAL SURFACE AREA OF PIPE IN BASEMENT
12     C      UPIPE : U VALUE OF PIPE
13     C      TCSUPA : SUPPLY CHILLED AIR TEMPERATURE
14     C      TCSUPW : SUPPLY CHILLED WATER TEMPERATURE
15     C      THSUPA : SUPPLY HOT AIR TEMPERATURE
16     C      THSUPW : SUPPLY HOT WATER TEMPERATURE
17     C      BSMTD : BASEMENT DAYTIME TEMPERATURE
18     C      BSMTN : BASEMENT NIGHTTIME TEMPERATURE
19     C      INDEXC : =0 IF BASEMENT HEATED; =1 IF UNHEATED
20     C
21     C      *** OUTPUT ***
22     C
23     C      QC      : HEAT GAIN THROUGH DUCTS & PIPES
24     C      QH      : HEAT LOSS THROUGH DUCTS & PIPES
25     C
26     COMMON/HR/HRDAY(12), HRNIT(12)
27     DIMENSION BSMTD(12), BSMTN(12), QC(12), QH(12),
28     1      CFAC(12), HFAC(12)
29     DO 10 I=1,12
30     DUCTBD=ADUCT*UDUCT*(BSMTD(I)-TCSUPA)*HRDAY(I)*CFAC(I)
31     DUCTBN=ADUCT*UDUCT*(BSMTN(I)-TCSUPA)*HRNIT(I)*CFAC(I)
32     PIPEBD=APIPE*UPIPE*(BSMTD(I)-TCSUPW)*HRDAY(I)*CFAC(I)
33     PIPEBN=APIPE*UPIPE*(BSMTN(I)-TCSUPW)*HRNIT(I)*CFAC(I)
34     QC(I)=DUCTBD+DUCTBN+PIPEBD+PIPEBN
35     IF(I.LT.NSTART.OR.I.GT.NLAST) QC(I)=0.0
36     DUCTBD=ADUCT*UDUCT*(BSMTD(I)-THSUPA)*HRDAY(I)*HFAC(I)
37     DUCTBN=ADUCT*UDUCT*(BSMTN(I)-THSUPA)*HRNIT(I)*HFAC(I)
38     PIPEBD=APIPE*UPIPE*(BSMTD(I)-THSUPW)*HRDAY(I)*HFAC(I)
39     PIPEBN=APIPE*UPIPE*(BSMTN(I)-THSUPW)*HRNIT(I)*HFAC(I)
40     QH(I)=DUCTBD+DUCTBN+PIPEBD+PIPEBN
41     IF(I.GE.NSTART.AND.I.LE.NLAST) QH(I)=0.0
42     IF(INDEXC.EQ.0) QH(I)=0.0
43 10 CONTINUE
44 RETURN
45 END

```

C 47

```

1 SUBROUTINE OSDUPI(ADUCT, UDUCT, APIPE, UPIPE, TCSUPA, TCSUPW, THSUPA,
2 THSUPW, TOD, TON, NSTART, NLAST, QC, QH, CFAC, HFAC)
3
4 THIS IS HEAT LOSS & GAIN THROUGH DUCTS & PIPES IN OUTSIDE
5
6 *** INPUT ***
7
8 ADUCT : TOTAL SURFACE AREA OF DUCT IN OUTSIDE
9 UDUCT : U VALUE OF DUCT
10 APIPE : TOTAL SURFACE AREA OF PIPE IN OUTSIDE
11 UPIPE : U VALUE OF PIPE
12 TCSUPA : SUPPLY CHILLED AIR TEMPERATURE
13 TCSUPW : SUPPLY CHILLED WATER TEMPERATURE
14 THSUPA : SUPPLY HOT AIR TEMPERATURE
15 THSUPW : SUPPLY HOT WATER TEMPERATURE
16 TOD : DAYTIME OUTSIDE TEMPERATURE
17 TON : NIGHTTIME OUTSIDE TEMPERATURE
18
19 *** OUTPUT ***
20
21 QC : HEAT GAIN THROUGH DUCTS & PIPES
22 QH : HEAT LOSS THROUGH DUCTS & PIPES
23
24 COMMON/HR/HRDAY(12), HRNIT(12)
25 DIMENSION TOD(12), TON(12), QC(12), QH(12), CFAC(12), HFAC(12)
26
27 DO 10 I=1,12
28 DUCTOD=ADUCT*UDUCT*(TOD(I)-TCSUPA)*HRDAY(I)*CFAC(I)
29 DUCTON=ADUCT*UDUCT*(TON(I)-TCSUPA)*HRNIT(I)*CFAC(I)
30 PIPEOD=APIPE*UPIPE*(TOD(I)-TCSUPW)*HRDAY(I)*CFAC(I)
31 PIPEON=APIPE*UPIPE*(TON(I)-TCSUPW)*HRNIT(I)*CFAC(I)
32 QC(I)=DUCTOD+DUCTON+PIPEOD+PIPEON
33 IF (I.LT.NSTART.OR.I.GT.NLAST) QC(I)=0.0
34 DUCTOD=ADUCT*UDUCT*(TOD(I)-THSUPA)*HRDAY(I)*HFAC(I)
35 DUCTON=ADUCT*UDUCT*(TON(I)-THSUPA)*HRNIT(I)*HFAC(I)
36 PIPEOD=APIPE*UPIPE*(TOD(I)-THSUPW)*HRDAY(I)*HFAC(I)
37 PIPEON=APIPE*UPIPE*(TON(I)-THSUPW)*HRNIT(I)*HFAC(I)
38 QH(I)=DUCTOD+DUCTON+PIPEOD+PIPEON
39 IF (I.GE.NSTART.AND.I.LE.NLAST) QH(I)=0.0
40
41 10 CONTINUE
42 RETURN
43 END

```

030808*CONSP6(I).ZKDN(4)

```
1 SUBROUTINE ZKDN(RINFIL,B,ZK)
2 C THIS ROUTINE DETERMINES THE OVERALL ENVELOPE HEAT TRANSFER FACTOR
3 C A SUBROUTINE OF HLEG ROUTINE
4 REAL RINFIL(12),B(350)
5 REAL ZK(12)
6 SUMZK=B(72)*B(74)+B(77)*B(79)+B(82)*B(84)+B(87)*B(89)+B(124)*B(125
7 *)+B(130)*B(131)+B(136)*B(137)+B(142)*B(143)+B(292)*B(293)+B(297)*B
8 *(298)+B(302)*B(303)+B(307)*B(308)+B(152)*B(192)
9 DO 1 I=1,12
10 ZZ=SUMZK+RINFIL(I)*1.08
11 ZK(I)=ZZ
12 RETURN
13 END
```

000000*CONSP6(1).PSY2(1)

```

1      SUBROUTINE PSY2 (DB,DP,PB,WB,PV,W,H,V,RH)
2      C
3      C *****
4      C
5      C THIS SUBROUTINE CALCULATES THE FOLLOWINGS WHEN DRY-BULB TEMPERATURE
6      C (DB),DEW-POINT TEMPERATURE(DP),AND BAROMETRIC PRESSURE(PB) ARE GIVEN
7      C WB WET-BULB TEMPERATURE
8      C W HUMIDITY RATIO
9      C H ENTHALPY
10     C V VOLUME
11     C PV VAPOR PRESSURE
12     C RH RELATIVE HUMIDITY
13     IF (DP-DB) 20,10,10
14     10 DP=DB
15     20 PV=PVSF(DP)
16     PVS=PVSF(DB)
17     RH=PV/PVS
18     W=0.622*PV/(PB-PV)
19     V=0.754*(DB+459.7)*((1+7000*W/4360)/PB
20     H=0.24*DB+(1061+0.444*DB)*W
21     IF (H) 30,30,40
22     30 WB=DP
23     RETURN
24     C
25     40 WB=WBH(H,PB)
26     RETURN
27     C
28     END

```

030303*CONSP6(1).WBF(1)

1 FUNCTION WBF (H,PB)

2 C

3 C

4 C

5 C

6 C

7

8 10

9

10

11

12 C

13 20

14

15 C

16 30

17

18

19

20

21 40

22

23

24

25

26

27 50

28

29

30 C

31 60

32 70

33

34 C

35 80

36

37 C

38 90

39

40 100

41 C

42

THIS PROGRAM APPROXIMATES THE WET-BULB TEMPERATURE WHEN
ENTHALPY IS GIVEN

IF (H) 30,30,10

Y=LOG(H)

IF (H.GT.11.758) GO TO 20

WBF=0.6041+3.4841*Y+1.3601*Y*Y+0.97307*Y*Y*Y

GO TO 100

WBF=30.9185-39.68200*Y+20.5841*Y*Y-1.758*Y*Y*Y

GO TO 100

WB1=150.

PV1=PVSF(WB1)

W1=0.622*PV1/(PB-PV1)

X1=0.24*WB1+(1061+0.444*WB1)*W1

Y1=H-X1

WB2=WB1-1

PV2=PVSF(WB2)

W2=0.622*PV2/(PB-PV2)

X2=0.24*WB2+(1061+0.444*WB2)*W2

Y2=H-X2

IF (Y1*Y2) 90,60,50

WB1=WB2

Y1=Y2

GO TO 40

IF (Y1) 80,70,80

WBF=WB1

GO TO 100

WBF=WB2

GO TO 100

Z=ABS(Y1/Y2)

WBF=(WB2*Z+WB1)/(1+Z)

RETURN

END

END PRT

@PRT,S CONSP6,DECDAY,.LINT,.MAX,.MIN

C 50

080803*CONSP6(1).DEGDAY(5)

```

1 SUBROUTINE DEGDAY(R,CDEG,HDEG,THT,TCT)
2 C THIS ROUTINE DETERMINES ANNUAL HEATING AND COOLING REQUIREMENTS
3 C BY THE VARIABLE DEGREE DAY METHOD
4 C HREQ MONTHLY HEATING REQUIREMENT (NEGATIVE)
5 C CREQ MONTHLY COOLING REQUIREMENT (POSITIVE)
6 C TOD MONTHLY NORMAL DAYTIME TEMPERATURE
7 C TON MONTHLY NORMAL NIGHTTIME TEMPERATURE
8 C CDEG COOLING DEGREE DAY AT DIFFERENT BASE TEMPERATURE
9 C HDEG HEATING DEGREE DAY AT DIFFERENT BASE TEMPERATURE
10 C THT ANNUAL HEATING REQUIREMENT
11 C TCT ANNUAL COOLING REQUIREMENT
12 DIMENSION HREQ(12),CREQ(12),TOD(12),TON(12),TO(12),CDEG(16),HDEG(16)
13 16),R(50),DAYS(12)/31.,28.,31.,30.,31.,30.,31.,31.,30.,31.,30.,31./
14 WRITE(6,5)
15 DO 1 I=1,12
16 HREQ(I)=R(I+2)/DAYS(I)
17 CREQ(I)=R(I+14)/DAYS(I)
18 TOD(I)=R(I+26)
19 TON(I)=R(I+33)
20 1 TO(I)=(TOD(I)+TON(I))/2.
21 CALL MAX(CREQ,QC2,IMAX,12)
22 CALL MIN(CREQ,QC1,IMIN,12)
23 TC1=TO(IMIN)
24 TC2=TO(IMAX)
25 TBC=(TC1*QC2-TC2*QC1)/(QC2-QC1)
26 WRITE(6,2) TC1,TC2,QC1,QC2,TBC
27 CALL MAX(HREQ,QH1,IMAX,12)
28 CALL MIN(HREQ,QH2,IMIN,12)
29 2 FORMAT(' TC1='F15.1,6X,' TC2='F15.1,6X,' QC1='F15.1,6X,' QC2='F15.
30 *1,6X,' TBC='F15.1/)
31 TH1=TO(IMAX)
32 TH2=TO(IMIN)
33 TBH=(TH1*QH2-TH2*QH1)/(QH2-QH1)
34 WRITE(6,3) TH1,TH2,QH1,QH2,TBH
35 3 FORMAT(' TH1='F15.1,6X,' TH2='F15.1,6X,' QH1='F15.1,6X,' QH2='F15.
36 *1,6X,' TBH='F15.1/)
37 CALL LINT(60.,CDEG,TBC,CDD,16)
38 CALL LINT(45.,HDEG,TBH,HDD,16)
39 TCT=QC2/(TC2-TBC)*CDD
40 THT=QH2/(TBH-TH2)*HDD
41 WRITE(6,4) CDD,HDD,THT,TCT
42 4 FORMAT(' CDD='F15.1,6X,' HDD='F15.1,6X,' THT='F15.1,6X,' TCT='
43 *F15.1/)
44 5 FORMAT(//18X,'THE ANNUAL HEATING AND COOLING REQUIREMENT ANALYSIS
45 *CALCULATED BY THE VARIABLE DEGREE-DAY METHOD'/51X,'TBC: BALANCE PO
46 *INT FOR COOLING'/51X,'TBH: BALANCE POINT FOR HEATING'/)
47 RETURN
48 END

```

000008*CONSP6(1).LINT(3)

C 52

```

1  SUBROUTINE LINT(X,Y,XX,YY,N)
2  THIS ROUTINE DOES THE LINEAR INTERPOLATION BETWEEN TWO CONSECUTIVE POINTS.
3  DIMENSION Y(N)
4  X1=X
5  XN=X+(N-1)
6  IF(XX.GE.X1.AND.XX.LE.XN) GO TO 6
7  IF(XX.GT.XN) GO TO 7
8  Z=(X1-XX)/(X1+1.-XX)
9  YY=(Z*Y(2)-Y(1))/(Z-1.)
10 GO TO 5
11
12 7 Z=(XX-XN)/(XX-XN+1.)
13 YY=(Y(N)-Y(N-1)*Z)/(1.-Z)
14 GO TO 5
15
16 6 DO 4 I=1,N
17 X1=X+(I-1)
18 X2=X+I
19 IF(XX.NE.X1) GO TO 1
20 YY=Y(I)
21 GO TO 5
22
23 1 IF(XX.NE.X2) GO TO 2
24 YY=Y(I+1)
25 GO TO 5
26
27 2 IF(XX.LT.X1.OR.XX.GT.X2) GO TO 4
28 Z1=(XX-X1)/(X2-X1)
29 Z2=Y(I+1)-Y(I)
30 YY=Y(I)+Z1*Z2
31 GO TO 5
32
33 4 CONTINUE
34
35 5 RETURN
36 END

```

• ALSO WORKS FOR EXTRAPOLATION

CSQSQS*CONSP6(1).MAX(1)

```
1 SUBROUTINE MAX(A,AMAX,IMAX,N)
2 DIMENSION A(N)
3 C INITIALIZE AMAX TO FIRST NON-ZERO VALUE AND IMAX TO ITS SUBSCRIPT
4 DO 3 M=1,N
5 IF(A(M).NE.0.) GO TO 2
6 3 CONTINUE
7 2 AMAX=A(M)
8 IMAX=M
9 DO 1 I=M,N
10 IF(A(I).EQ.0.) GO TO 1
11 IF(A(I).LE.AMAX) GO TO 1
12 AMAX=A(I)
13 IMAX=I
14 1 CONTINUE
15 RETURN
16 END
```

Q3Q3Q3*CONSP6(1).MIN(1)

```
1 SUBROUTINE MIN(A,AMIN,IMIN,N)
2 DIMENSION A(N)
3 C INITIALIZE AMIN TO FIRST NON-ZERO VALUE AND IMIN TO ITS SUBSCRIPT
4 DO 3 M=1,N
5 IF(A(M).NE.0.) GO TO 2
6 3 CONTINUE
7 2 AMIN=A(M)
8 IMIN=M
9 DO 1 I=1,N
10 IF(A(I).EQ.0.) GO TO 1
11 IF(A(I).GE.AMIN) GO TO 1
12 AMIN=A(I)
13 IMIN=I
14 1 CONTINUE
15 RETURN
16 END
```

END PRT

@PACK,P CONSP6.

END PREP. Q3Q3Q3*CONSP6(1) 39 REL 39 ENTRY_PT(S)-NO DUP(S)
END PACK. TEXT=25,TOC=2,SYN=40,REL=39

@MAP,IN

MAP 30R1 S74T11 06/02/80 19:00:26

END MAP. ERRORS: 0 TIME: 10.556 STORAGE: 17792/5/036777/073777

EXQT

CITY NAME : WASHINGTON DC
HOUSE NAME: HASTINGS HOUSE

INPUT DATA LISTING

1 9600.000 2 .500 3 38.400 4 39.600 5 48.100 6 57.500 7 67.700 8 76.200 9 79.900 10 77.900
11 72.200 12 60.900 13 50.200 14 40.200 15 35.600 16 37.300 17 45.100 18 56.400 19 66.200 20 74.600
21 78.700 22 77.100 23 70.600 24 59.800 25 48.000 26 37.400 27 70.000 28 70.000 29 70.000 30 70.000
31 78.000 32 78.000 33 78.000 34 78.000 35 78.000 36 70.000 37 70.000 38 70.000 39 65.000 40 65.000
41 65.000 42 65.000 43 78.000 44 78.000 45 78.000 46 78.000 47 78.000 48 65.000 49 65.000 50 65.000
51 1.000 52-9999.000 53-9999.000 54 9.900 55 10.400 56 10.900 57 10.500 58 9.200 59 8.700 60 8.100
61 6.000 62 8.200 63 8.500 64 9.200 65 9.400 66-9999.000 67-9999.000 68 180.000 69 38.500 70 .200
7120234.000 72 55.100 73 .800 74 1.130 75 .000 76 270.000 77 .000 78 .000 79 .100 80 .000
81 .000 82 72.000 83 .800 84 1.130 85 .000 86 90.000 87 .000 88 .000 89 .100 90 .000
91 90.000 92 .750 93 1.000 94 70.000 95 70.000 96 70.000 97 70.000 98 70.000 99 70.000 100 70.000
101 70.000 102 70.000 103 70.000 104 70.000 105 70.000 106 .000 107 .000 108 .000 109 10.000 110 .000
111 .900 112-9999.000 113-9999.000 114-9999.000 115-9999.000 116-9999.000 117-9999.000 118-9999.000 119-9999.000 120-9999.000
121-9999.000 122-9999.000 123-9999.000 124 .100 125 244.900 126 1.000 127 10.000 128 .000 129 .900 130 .100
131 240.000 132 1.000 133 10.000 134 .000 135 .900 136 .100 137 248.000 138 1.000 139 10.000 140 .000
141 .900 142 .100 143 240.000 144 1.000 145 .000 146 .000 147 80.000 148 60.000 149 .000 150 .000
151 .900 152 .200 153 .625 154 1.000 155 1.000 156-9999.000 157 37.500 158 3.000 159 .050 160 .400
161-9999.000 162 .100 163 75.000 164 6.000 165 9.000 166 1.000 167 1.000 168 140.000 169 60.000 170 62.000
171 64.000 172 66.000 173 67.000 174 68.000 175 67.000 176 66.000 177 65.000 178 64.000 179 62.000 180 61.000
181 .000 182 .000 183 .000 184 .000 185 .000 186 1.790 187 3.000 188 116.400 189 260.400 190 846.000
191 508.800 192 1200.000 193 1200.000 194 1.000 195 3.000 196 .164 197 .000 198 1.000 199 .100 200 .000
201 20.000 202 1.000 203 500.000 204 500.000 205 1.000 206 .516 207 .553 208 .524 209 .516 210 .520
211 .506 212 .464 213 .460 214 632.400 215 901.500 216 1255.000 217 1600.400 218 1846.800 219 2080.800 220 1929.900
221 1712.200 222 1446.100 223 1083.400 224 763.500 225 594.100 226 .670 227-9999.000 228-9999.000 229-9999.000 230-9999.000
231-9999.000 232 2.100 233-9999.000 234-9999.000 235-9999.000 236-9999.000 237-9999.000 238-9999.000 239-9999.000 240 2.000
241 20.000 242 20.000 243 20.000 244 20.000 245 20.000 246 60.000 247 60.000 248 60.000 249 60.000 250 20.000
251 20.000 252 20.000 253 20.000 254 20.000 255 20.000 256 20.000 257 20.000 258 60.000 259 60.000 260 60.000
261 60.000 262 20.000 263 20.000 264 20.000 265 69.000 266 67.000 267 68.000 268 68.000 269 72.000 270 75.000
271 75.000 272 79.000 273 80.000 274 79.000 275 73.000 276 71.000 277 54.000 278 52.000 279 49.000 280 47.000
281 51.000 282 52.000 283 52.000 284 54.000 285 55.000 286 51.000 287 52.000 288 57.000 289-9999.000 290 .000
291 .900 292 .490 293 20.000 294-9999.000 295 .000 296 .000 297 .000 298 .000 299-9999.000 300 .000
301 .000 302 .000 303 .000 304-9999.000 305 .000 306 .000 307 .460 308 .000 309 1.000 310 40.000
311 .080 312 .025 313 .000 314 .000 315 62.000 316 41.000 317 140.000 318 176.000 319 100.000 320 .570
321 .000 322 1.460 323 .000 324 .570 325 .000 326 1.460 327 100.000 328 .570 329 .000 330 1.460
331 .000 332 1.460 333 .000 334 4.100 335 10.000 336 .000 32764000.000

WINDOW HEAT GAIN ROUTINE COMPLETED
SOLAR ENERGY UTILIZATION ROUTINE COMPLETED
INFILTRATION HEAT GAIN ROUTINE COMPLETED
WALL HEAT GAIN ROUTINE COMPLETED
DOOR HEAT GAIN ROUTINE COMPLETED
CEILING HEAT GAIN ROUTINE COMPLETED

CALCULATION OF U VALUE FOR GROUND WITH FILM RESISTANCE ABOVE

WIDTH	LENGTH	AREA	PERIM	F	G	EDGE DIST.	LAMBDA	FILM R	U	U	U	U
									CALC. FROM TEMPERATURE INPUT (		CALC. FROM HEAT FLOW INPUT	
									R=1/U-FILM R L=LAMBDA*R		R=1/U-FILM R L=LAMBDA	
40.0	30.0	1200.0	140.0	12	16	1.00	1.000	10.00	.047	11.146	11.146	.040
SLAB ON GRADE ROUTINE COMPLETED												
CRAWL SPACE ROUTINE COMPLETED												
FLOOR HEAT GAIN ROUTINE COMPLETED												
INTERNAL HEAT GAIN ROUTINE COMPLETED												

ANNUAL SUMMARY

56

	J	F	M	A	M	J	J	A	S	O	N	D
TID	70.00	70.00	70.00	70.00	78.00	78.00	78.00	78.00	78.00	70.00	70.00	70.00
TIN	63.00	65.00	65.00	65.00	78.00	78.00	78.00	78.00	78.00	65.00	65.00	65.00
TOD	33.40	39.60	48.10	57.50	67.70	76.20	79.90	77.90	72.20	60.90	50.20	40.20
TON	32.60	35.00	42.10	55.30	64.70	73.00	77.50	76.30	69.00	53.70	45.80	34.60
HRDAY	9.747	10.86	12.04	13.31	14.30	14.72	14.33	13.32	12.07	10.82	9.733	9.275
HRNIT	14.25	13.14	11.96	10.69	9.699	9.275	9.573	14.68	11.93	13.18	14.27	14.72
XIDTS	852.0	900.1	897.6	780.1	686.9	672.2	698.8	822.2	1042.	1150.	1107.	948.7
XIDDS	200.4	280.7	372.7	466.2	522.9	547.6	525.1	469.2	384.3	293.6	213.7	179.1
XIDTW	386.5	533.1	706.3	868.4	953.2	1053.	991.1	913.7	799.9	630.8	466.2	372.1
XIDDW	200.4	280.7	372.7	466.2	522.9	547.6	525.1	469.2	384.3	293.6	213.7	179.1
XIDTW	200.4	280.7	372.7	479.3	578.3	642.3	584.7	482.5	384.3	293.6	213.7	179.1
XIDDN	200.4	280.7	372.7	466.2	522.9	547.6	525.1	469.2	384.3	293.6	213.7	179.1
XIDTE	386.5	533.1	706.3	868.4	958.2	1053.	991.1	913.7	799.9	630.8	466.2	372.1
XIDDE	200.4	280.7	372.7	466.2	522.9	547.6	525.1	469.2	384.3	293.6	213.7	179.1
QID	-1.1678+05	-1.1790+05	-1.1323+05	-7072.	-6017.	-922.9	875.8	-38.50	-2554.	-3661.	-8794.	-1.1452+05
QIN	-1.2500+05	-1.2138+05	-1.1375+05	-4410.	-5269.	-1615.	-155.6	-524.8	-3920.	-3085.	-1.1250+05	-1.2352+05
QWD	-1.2328+05	-1.2390+05	-1.1389+05	-3083.	-436.6	-1.1609+05	-1.2047+05	-1.1698+05	6447.	2294.	-8836.	-1.2002+05
QWN	-1.4465+05	-1.3835+05	-1.2666+05	-1.1009+05	-1.1255+05	-4512.	-470.6	-1767.	-1.1045+05	-2976.	-1.2665+05	-1.4355+05
QSD	-2724.	-2823.	-1926.	-784.5	-423.4	1157.	1556.	1951.	-8.002	7.5	-1512.	-2445.
QDN	-4498.	-3863.	-2685.	-1017.	-1204.	-454.5	-47.40	-177.9	-1053.	3.5	-2685.	-4327.
QCD	-1.1218+05	-1.1172+05	-4984.	2303.	4958.	1.1615+05	1.1749+05	1.1420+05	6067.	2109.	-4030.	-1.1079+05
QCN	-1.2385+05	-1.2055+05	-1.1463+05	-6040.	-7219.	-3252.	-1221.	-1937.	-6323.	-5207.	-1.1482+05	-1.2332+05
QCD	6141.	8458.	2141+05	3359+05	3544+05	5451+05	6135+05	5951+05	5689+05	5473+05	3600+05	1471+05
QCN	-1.6591+05	-1.5662+05	-1.3935+05	-1.1490+05	-1.1853+05	-6661.	-694.6	-2608.	-1.1543+05	-1.1192+05	-1.3934+05	-1.6429+05
QFD	-1115.	-1145.	-1156.	-1142.	-1.5255+03	-1.5410+03	.0000	-4894+03	-1.4433+03	-1145.	-1115.	-1096.
QFN	1115.	1145.	1156.	1142.	-1.3564+03	-1.3408+03	.0000	-1.3924+03	-1.4385+03	1145.	1115.	1096.
QRD	1.2479+05	1.2762+05	1.3061+05	1.3384+05	1.3637+05	1.3744+05	1.3643+05	1.3387+05	1.3068+05	1.2753+05	1.2475+05	1.2359+05
QRN	1.3926+05	1.3620+05	1.3296+05	1.2946+05	1.2672+05	1.2555+05	1.2665+05	1.2942+05	1.2888+05	1.3630+05	1.3930+05	1.4057+05
SCD	1.5791+05	1.6422+05	1.6813+05	1.6606+05	1.6506+05	1.6703+05	1.6682+05	1.6863+05	1.7695+05	1.7917+05	1.7319+05	1.6254+05
ZK	545.2	544.9	540.9	533.2	531.6	525.5	522.9	519.6	527.2	527.9	536.3	543.3
ZK	545.2	544.9	540.9	533.2	531.6	525.5	522.9	519.6	527.2	527.9	536.3	543.3
DHCD	3.381	3.654	11.96	14.87	.0000	.0000	.0000	.0000	.0000	.0000	14.27	3.603
DHWU	.0000	.0000	12.04	13.31	.0000	.0000	.0000	.0000	.0000	8.404	9.733	.0000
PUH	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000	2.000
PULDWN	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.2177+05	.0000	.0000
PICKUP	-1.4315+05	-1.4247+05	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	-1.4202+05
CLD	.0000	.0000	.0000	.0000	.6989+05	1.1244+06	1.1382+06	1.1256+06	1.9753+05	1.1820+05	.0000	.0000
CLN	.0000	.0000	.0000	.0000	.0000	9058.	1.2406+05	1.2236+05	.0000	1.5061+05	.0000	.0000
HLD	-1.1642+05	-1.1421+05	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	-6475.
HLN	-1.1925+06	-1.1726+06	.0000	2284.	-1.1811+05	.0000	.0000	.0000	-4295.	.0000	.0000	-1.1855+06
QTD	-1.2515+05	-1.2142+05	1.1683+05	1.5764+05	1.6989+05	1.1244+06	1.1382+06	1.1256+06	1.9753+05	1.8141+05	1.3566+05	-1.1059+05
QTN	-1.1235+06	-1.1034+06	-1.6296+05	-5854.	-1.1811+05	9058.	1.2406+05	1.2236+05	-4295.	8338.	-1.5538+05	-1.1174+06
HEAT LOSS & HEAT GAIN ROUTINE COMPLETED												
RLHC	1.2655+05	1.2714+05	1.3059+05	1.3779+05	1.4413+05	-1.1221-03	1.1059+05	-1.1221-03	-1.1221-03	1.4343+05	1.3423+05	1.2762+05
CSDUPI	COMPLETED											
ASDUPI	COMPLETED											
BMDUPI	COMPLETED											
OSDUPI	COMPLETED											
HEATING & COOLING REQUIREMENT ROUTINE COMPLETED												
ENERGY REQUIREMENT ROUTINE COMPLETED												

ANNUAL SUMMARY

	J	F	M	A	M	J	J	A	S	O	N	D
HREQ	-.6215+07	-.4919+07	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	.0000	-.5604+07
CREQ	.0000	.0000	.0000	.0000	.0000	.4403+07	.5893+07	.5045+07	.3218+07	.0000	.0000	.0000

29.00

THT= -.1673822+08 TCT= .1856163+08

3

SHBTU = -.5993+08 SCBTU = .8839+07
SHBTU = -59929121. SCBTU = 8838883.

TBTU= 68768004.

THE ANNUAL HEATING AND COOLING REQUIREMENT ANALYSIS CALCULATED BY THE VARIABLE DEGREE-DAY METHOD

TBC: BALANCE POINT FOR COOLING

TBH: BALANCE POINT FOR HEATING

TC1=	70.6	TC2=	78.7	QC1=	107282.7	QC2=	190112.0	TBC=	60.1
TH1=	37.3	TH2=	35.6	QH1=	-175663.6	QH2=	-200496.4	TBH=	49.3
CDD=	2232.9	HDD=	1341.0	THT=	-19588311.0	TCT=	22832792.0		

ANNUAL HEAT LOSS THROUGH NON-ADDITIONAL JACKET INSULATION OF HOT WATER TANK : -.6155+07

ANNUAL HEAT LOSS THROUGH ADDITIONAL JACKET INSULATION OF HOT WATER TANK : -.6155+07

ANNUAL ENERGY SAVING BY ADDITIONAL INSULATION OF HOT WATER TANK : .0000

ANNUAL HOT WATER REQUIREMENT, INCLUDING JACKET HEAT LOSS : -.2341+08

ANNUAL HOT WATER REQUIREMENT, EXCLUDING JACKET HEAT LOSS : -.1726+08

ANNUAL HEAT GAIN THROUGH DUCTS & PIPES FOR SPACE COOLING : .0000

ANNUAL HEAT LOSS THROUGH DUCTS & PIPES FOR SPACE HEATING : .0000

●BREKT PRINTS

APPENDIX D
ELEMENTS OF DATA STATEMENT IN MAIN PROGRAM

Number*	Variable	Type	Comments	Units	Meaning
B(1)	V	F		ft ³	Volume (L*W*H) of Heated Living Area
B(2)	ACRM	F	Tight = .5 Average = 1.0 Leaky = 1.5 Very Leaky = 2.0	AC/hr	Standard Air Leakage Data
B(3-14)	TOD(X)	F(12)		deg F	Daytime Outdoor Temperature (Month)
B(15-26)	TOT(X)	F(12)		deg F	Daily Temperature (Month)
B(27-38)	TID(X)	F(12)		deg F	Daytime Indoor Temperature (Month)
B(39-50)	TIN(X)	F(12)		deg F	Nighttime Indoor Temperature (Month)
B(51)	IACNV	I	0-Never open windows 1-Open windows in summer when temp. < thermostat setting Default = 0		
B(52)	X1	F	Unused		
B(53)	X2	F	Unused		
B(54-65)	WS(X)	F(12)		mph	Wind Speed
B(66)	X3	F	Unused		
B(67)	X4	F	Unused		
B(68)	ORT1	F	0.0 - 359.0	deg	Orientation from south of window/ wall/door No. 1
B(69)	XLAT	F		deg	Latitude (North)

* Number shows position of element at data statement in main program.

Number	Variable	Type	Comments	Units	Meaning
B(70)	REO	F	0.2 = Dark 0.4 = Medium 0.6 = Light	---	Ground Surface Reflectance
B(71)	ZIP	I			Zip Code
B(72)	AG1	F		ft ²	Window 1 Area
B(73)	SC1	F	Default = 0.55 if Shades Else 0	---	Window 1 Shading Coefficient
B(74)	UG1	F	1.13 = Single Glaze 0.55 = Double Glaze Default = 1.13	Btuh*	Window 1 U Value
B(75)	SHADW1	F	1.0 = All Shadow 0.5 = Part Shadow 0.0 = No Shadow Default = 0.0	---	Window 1 Shadow
B(76)	ORT2	F	0.0 - 359.0	deg	Orientation from South of Window/ Wall/Door No. 2
B(77)	AG2	F		ft ²	Window 2 Area
B(78)	SC2	F	Default = 0.55 if Shades Else 0	---	Window 2 shading coefficient
B(79)	UG2	F	1.13 = Single Glaze 0.55 = Double Glaze Default = 1.13	Btuh	Window 2 U value
B(80)	SHADW2	F	1.0 = All Shadow 0.5 = Part Shadow 0.0 = No Shadow Default = 0.0	---	Window 2 Shadow
B(81)	ORT3	F	0.0 - 359.0	deg	Orientation from South of Window/ Wall/Door No. 3
B(82)	AG3	F		ft ²	Window 3 Area
B(83)	SC3	F	Default = 0.55 If Shades Else 0	---	Window 3 Shading Coefficient
B(84)	UGE	F	1.13 = Single Glaze 0.55 = Double Glaze Default = 1.13	Btuh	Window 3 U Value

* Btuh = Btu/hr ft² F
all the U values hereafter will be expressed in this unit

Number	Variable	Type	Comments	Units	Meaning
B(85)	SHADW3	F	1.0 = All Shadow 0.5 = Part Shadow 0.0 = No Shadow Default = 0.0	----	Window 3 Shadow
B(86)	ORT4	F	0.0 - 359.0	deg	Orientation from South of Window/ Wall/Door No. 4
B(87)	AG4	F	0.0 - 359.0	ft ²	Window 4 Area
B(88)	SC4	F	Default = 0.55 If Shades Else 0	---	Window 4 Shading Coefficient
B(89)	UG4	F	1.13 = Single Glaze 0.55 = Double Glaze Default = 1.13	Btuh	Window 4 U Value
B(90)	SHDW4	F	1.0 = All Shadow 0.5 = Part Shadow 0.0 = No Shadow Default = 0.0	---	Window 4 Shadow
B(91)	WTILT1	F	Default = 50.0	deg from horiz	Solar Collector Tilt Angle
B(92)	SA	F	High Performance = 0.8 Medium Performance = 0.75 Low Performance = 0.7 Default = 0.7	---	Solar Collector Efficiency (Y Axis) (Absorption Factor From Glass)
B(93)	SB	F	High Performance = 1.2 Medium Performance = 1.0 Low Performance = 0.8 Default = 0.8	---	Solar Collector Efficiency (X Axis) (Water Temp - Outdoor Temp)/Solar Radiation
B(94-105)	TE(X)	F(12)	Default = 70.0	deg F	Inlet Fluid Temperature to Solar Collector (Month)
B(106)	SUF	F	Default = 1.0	---	Sollar Collector Utilization
B(107)	AS	F	Default = 0.0	ft ²	Solar Collector Area = 0 to Signal No Sollar Collector
B(108)	X5	F	Default = 1.0	ft	Roof overhang projection over wall 1
B(109)	X6	F	Default = 10.0	ft	Height of wall 1
B(110)	WALL13	F	Much = 1.0 Part = 0.5 None = 0.0 Default = 0.0	---	Wall 1 Shadow Factor

Number	Variable	Type	Comments	Units	Meaning
B(11)	WALL14	F	Dark = 0.95 Medium = 0.7 Light = 0.4 Default = 0.4	---	Wall 1 Surface Absorptivity
B(112-123)	X7	F(12)	Unused		
B(124)	WALL15	F	Wood Insulated = 0.07 Wood Uninsulated=0.23 Masonry Insulated=0.13 Masonry Uninsulated=0.29	Btuh	Wall 1 U Value U of Mobile Home = U of Wood Insulated Home
B(125)	WALL16	F		ft ²	Wall 1 Area Excludes Windows and Doors 0 if Attached Includes Above-Ground Basement Wall Area
B(126)	X8	F	Default = 1.0	ft	Roof overhang projection over wall 2
B(127)	X9	F	Default = 10.0	ft	Height of wall 2
B(128)	WALL 23	F	Much = 1.0 Part = 0.5 None = 0.0 Default = 0.0	---	Wall 2 Shadow Factor
B(129)	WALL 24	F	Dark = 0.95 Medium = 0.7 Light = 0.4 Default = 0.4	---	Wall 2 Surface Absorptivity
B(130)	WALL 25	F	Wood Insulated=0.07 Wood Uninsulated=0.23 Masonry Insulated=0.13 Masonry Uninsulated=0.29	Btuh	Wall 2 U Value U of Mobile Home = U of Wood Insulated Home
B(131)	WALL 26	F		ft ²	Wall 2 Area Excludes Windows and Doors 0 if attached Includes Above-Ground Basement Wall Area
B(132)	X10	F	Default = 1.0	ft	Roof overhang projection over wall 3
B(133)	X11	F	Default = 10.0	ft	Height of wall 3

Number	Variable	Type	Comments	Units	Meaning
B(134)	WALL 33	F	Much = 1.0 Part = 0.5 None = 0.0 Default = 0.0	---	Wall 3 Shadow Factor
B(135)	WALL 34	F	Dark = 0.95 Medium = 0.7 Light = 0.4 Default = 0.4	---	Wall 3 Surface Absorptivity
B(136)	WALL 35	F	Wood Insulated=0.07 Wood Uninsulated=0.23 Masonry Insulated=0.13 Masonry Uninsulated=0.29	Btuh	Wall 3 U Value U of Mobile Home = U of Wood Insulated Home
B(137)	WALL 36	F		ft ²	Wall 3 Area Excludes Windows and Doors 0 if Attached Includes Above-Ground Basement Wall Area
B(138)	X12	F	Default = 1.0	ft	Roof overhang projection over wall 4
B(139)	X13	F	Default = 10.0	ft	Height of wall 4
B(140)	WALL 43	F	Much = 1.0 Part = 0.5 None = 0.0 Default = 0.0	---	Wall 4 Shadow Factor
B(141)	WALL 44	F	Dark = 0.95 Medium = 0.7 Light = 0.4 Default = 0.4	---	Wall 4 Surface Absorptivity
B(142)	WALL 45	F	Wood Insulated=0.07 Wood uninsulated=0.23 Masonry Insulated=0.13 Masonry Uninsulated=0.29	Btuh	Wall 4 U Value U of Mobile Home = U of Wood Insulated Home
B(144)	SOGFRC	F	0.0-1.0 (SUM B (144-146) = 1)	---	Fraction of Floor Which is SOG

Number	Variable	Type	Comments	Units	Meaning
B(145)	CRWFRC	F	0.0-1.0 (SUM B(144-146) = 1)	---	Fraction of Floor Which is Crawl Space
B(146)	BSMFRC	F	0.0-1.0 (SUM B(144-146) = 1)	---	Fraction of Floor Which is Basement
B(147-148)	X14	F(2)	Unused		
B(149)	ROOF4 (ANATT)	F	Default = 0.0	ft ²	Non-Attic Roof Area (AFLOOR - ATFLR)
B(150)	ROOF1	F	Default = 0.0 1.0 = All Shadow 0.5 = Part Shadow 0.0 = No Shadow	---	Roof Shadow Factor
B(151)	ROOF2	F	Default = 0.9 Dark = 0.95 Medium = 0.7 Light = 0.4	---	Roof Absorptivity
B(152)	ROOF3	F	Default = 0.2 0.55 With Vented or No Attic 0.2 With Unvented Attic	Btuh	Roof U Value
B(153)	AEWH	F	Default = 4.0	ft	Attic End Wall Height
B(154)	SOLHW	I	0 = Not Used for Hot Water 1 = Is Used	---	Use of Solar Collector for Hot Water Heating
B(155)	SOLSH	I	0 = Not Used for Hot Heating 1 = Is Used	---	Use of Solar Collector For Space Heating
B(156)	X23	I	Unused		
B(157)	AW	F		ft ²	Attic End Wall Area
B(158)	ACAT	F	20.0 = Attic Fan 6.0 = Soffit Vent and Ridge Vent 3.0 = Gable Vent 0.0 = No vent Default = 3.0	AC/hr	Air Change per Hour
B(159)	UCEIL	F	Default = 0.1	Btuh	Ceiling U Value - Only When There is an Attic

Number	Variable	Type	Comments	Units	Meaning
B(160)	AEW5	F	Default = 0.25 Same as Wall U B(124)	Btuh	Attic End Wall U Value
B(161)	X15	F	Unused		
B(162)	UFLRI	F	Default = 0.30	Btuh	Floor U Value (Floor Above Basement)
B(163)	HWT	F	Default = 75.0	gal/day	Hot Water Usage
B(164)	NSTART	I	1-12	---	First Month of Cooling
B(165)	NLAST	I	1-12	---	Last Month of Cooling Season
B(166)	INDEXES	I	0-Attic is Temp Controlled 1-Attic Not Temp Controlled = 1 If There is an Attic Else 0	---	Attic Temperature Control Index
B(167)	INDEXC	I	0 = Basement Heated 1 = Basement Unheated	---	Basement Temperature Control Index
B(168)	ZL	F		ft	Exposed Perimeter Length of SOG
B(169-180)	TG(X)	F(12)		deg F	Ground Temperature (Month)
B(181)	ACCS	F	0.0 = Unvented 3.0 = Vented	AC/hr	Crawl Space Air Change/Hour
B(182)	UFLR2	F	Default = 0.30	Btuh	Crawl Space Floor U Value (Floor Above Crawl Space)
B(183)	UCLW	F	Default = 0.25	Btuh	Crawl Space Wall U Value
B(184)	HCL	F		ft	Crawl Space Height
B(185)	AWCL	F		ft ²	Crawl Space Wall Area
B(186)	NPD	I	Default = 3	---	Daytime Occupancy
B(187)	NPN	I	Default = 3	---	Nighttime Occupancy
B(188)	WTD	F	Default = $0.097 * ft^2$	watt	Average Daytime Lighting
B(189)	WTN	F	Default = $0.217 * ft^2$	watt	Average Nighttime Lighting

Number	Variable	Type	Comments	Units	Meaning
B(190)	WED	F	Default = $0.705 * ft^2$	watt	Average Daytime Electric Equipment For Gas Appliance, Use Electric Equivalent Value
B(191)	WEN	F	Default = $0.424 * ft^2$	watt	Average Nighttime Electric Equipment For Gas Appliance, Use Electric Equivalent Value
B(192)	FLOORA	F	Default = 1200.0	ft^2	Floor Area (Flat Projection of House)
B(193)	ATFLR	F	Default = 1200.0	ft^2	Area of Attic Floor
B(194)	UBW	F	Default = 1.0	Btuh	Basement Wall Heat Conductance
B(195)	ISYS	I	1 = Heat, No Cool 2 = Cool, No Heat 3 = Heat + Cool	---	System Index
B(196)	UFW	F	Default = 0.164	Btuh	Ground Heat Conductance for Wall
B(197)	BWA	F		ft^2	Basement Wall Area
B(198)	UBF	F	Default = 1.0	Btuh	Basement Floor Heat Conductance
B(199)	UFF	F	Default = 0.1	Btuh	Ground Heat Conductance for Floor
B(200)	QBHG	F	Default = 0.0	Btuh	Basement Heat Gain From Furnace and Other Equipment
B(201)	THTC	F	Table on page E-2 Default = 15.0	hr	Thermal Time Constant
B(202)	ZKS	F	Default = 1.0	Btuh-ft	Ground Thermal Conductivity
B(203)	DX	F	Default = 500	ft	Side Distance from Adjacent House
B(204)	DY	F	Default = 500	ft	Front to Back Distance from Adjacent House
B(205)	E	F	Default = 0.5	ft	Wall Thickness
B(206-213)			unused		
B(214-225)	H(X)	F(12)		Btu/day/ ft^2	Total Horizontal Solar Insolation (Month)
B(226)	EH	F	Value = F(Fuel EFF, Mod Factor)	---	Heating Efficiency
B(227-231)	X(16)	F(5)	Unused		

Number	Variable	Type	Comments	Units	Meaning
B(232)	EC	F	Value = F(Fuel EFF, Mod Factor)	---	Cooling Efficiency
B(233-239)	X(17)	F(7)	Unused		
B(240)	X(18)	F	Unused		
B(241-252)	RH(1,X)	F(2,12)	Default Summer = 50.0 WIN = 20.0 If No Humidifier WIN = 35.0 if + Humidifier	pct*	Indoor Daytime Rel Humid (Month)
B(253-264)	RH(2,X)		Same	pct	Indoor Nighttime Rel Humid (Month)
B(265-276)	RHM (X)	F(12)		pct	Outdoor Morning Rel Humid (Month)
B(277-288)	RHA (X)	F(12)		pct	Outdoor Afternoon Rel Humid (Month)
B(289)	X(19)	F	Unused		
B(290)	DOOR13	F	Same as Wall Shadow	---	Door 1 Shadow
B(291)	DOOR14	F	Same as Wall Absorptivity	---	Door 1 Absorptivity
B(292)	DOOR15	F	Default = 0.5	Btuh	Door 1 U Value
B(294)	X20	F	Unused		
B(295)	DOOR23	F	Same as Wall Shadow	---	Door 2 Shadow
B(296)	DOOR24	F	Same as Wall Absorptivity	---	Door 2 Absorptivity
B(297)	DOOR25	F	Default = 0.5	Btuh	Door 2 U Value
B(298)	DOOR26	F		ft ²	Door 2 Area Excludes Sliding Glass Doors
B(299)	X21	F	Unused		
B(300)	DOOR33	F	Same as Wall Shadow	---	Door 3 Shadow
B(301)	DOOR34	F	Same as Wall Absorptivity	---	Door 3 Absorptivity
B(302)	DOOR35	F	Default = 0.5	Btuh	Door 3 U Value
B(303)	DOOR36	F		ft ²	Door 3 Area Excludes Sliding Glass Doors

* pct = percent

Number	Variable	Type	Comments	Units	Meaning
B(304)	X22	F	Unused		
B(305)	DOOR43	F	Same as Wall Shadow	---	Door 4 Shadow
B(306)	DOOR44	F	Same as Wall Absorptivity	---	Door 4 Absorptivity
B(307)	DOOR45	F	Default = 0.5	Btuh	Door 4 U Value
B(308)	DOOR46	F		ft ²	Door 4 Area Excludes Sliding Glass Doors
B(309)	ICHECK	F	Default = 0.0	---	= 1 To Get Debug Output From Thermodynamic Model
B(310)	AJAC	F	Default = 40	ft ²	Total Jacket Area
B(311)	D1	F	Default = 0.08	ft	Thickness of Existing Insulation
B(312)	RAM1	F	Default = 0.025	Btuh-ft	Thermal Conductivity of the Above
B(313)	D2	F		ft	Thickness of Additional Insulation
B(314)	RAM2	F	Default = 0.025	Btuh-ft	Thermal Conductivity of the Above
B(315)	TCSUPA	F	Default = 62	deg F	Supply Cold Air Temp.
B(316)	TCSUPW	F	Default = 41.0	deg F	Supply Chilled Water Temp.
B(317)	THSUPA	F	Default = 95.0	deg F	Supply Hot Air Temp.
B(318)	THSUPW	F	Default = 113.0 for Heat Pump Default = 176.0 for Boiler	deg F deg F	Supply Hot Water Temp.
B(319)	ADUCT1	F	Default = 100	ft ²	Surface Area of Duct in the Crawl Space
B(320)	UDUCT1	F	Default = 1.46 If Not Insulated 0.15 If Insulated	Btuh	U Value of Duct in the Crawl Space

Number	Variable	Type	Comments	Units	Meaning
B(321)	APIPE1	F	Default = 1.5	ft ²	Surface Area of Pipe in Crawl Space
B(322)	UPIPE1	F	Default = 1.46 If Not Insulated 0.15 If Insulated	Btuh	U Value of Pipe in Crawl Space
B(323)	ADUCT2	F	Same as the Crawl Space	ft ²	Surface Area of Duct in Attic
B(324)	UDUCT2	F		Btuh	U Value of Duct in Attic
				ft ²	Surface Area of Pipe in Attic
B(326)	UPIPE2	F		Btuh,	U Value of Duct in Attic
B(327)	ADUCT3	F		ft ²	Surface Area of Duct in Basement
B(328)	UDUCT3	F		Btuh	U Value of Duct in Basement
B(329)	APIPE3	F		ft ²	Surface Area of Pipe in Basement
B(330)	UPIPE3	F		Btuh	U Value of Pipe in Basement
B(331)	ADUCT4	F		ft ²	Surface Area of Outdoor Duct
B(332)	UDUCT4	F		Btuh	U Value of Duct Outdoors
B(333)	APIPE4	F		ft ²	Surface Area of Outdoor Pipe
B(334)	UPIPE4	F		Btuh	U Value of Pipe Outdoors
B(335)	AIRLOS	F	Percentage To Total Air Flow Rate; Default = 10.0	pct	Air Leakage Through Duct
B(336)	CAPCL	F	Default = 24000	Btu/h	Capacity of Cooling Equipment
B(337)	CAPHT	F	Default = 64000	Btu/h	Capacity of Heating Equipment
R(1)	SHBTU	F		Btu/yr	Annual Heating Energy Requirement After Using Energy From Solar Collector
R(2)	SCBTU	F		Btu/yr	Annual Space Cooling Energy Requirement

APPENDIX E

Thermal Time Constant and Its Application

The thermal time constant of a building is a parameter to indicate the speed of indoor temperature response to a sudden change of building heating and cooling operation. The heavier the thermal mass of a building, the slower its response, compared to a lighter building, to cool down or heat up when the building heating system is turned off and on, respectively. The thermal time constant is defined as a ratio between the equivalent thermal mass of the building and the building overall heat transfer factor. Whereas the overall heat transfer factor may be approximated by the heat transfer coefficients, U value, multiplied by the areas, A, of all the elements, such as walls, doors, windows, roof and floors, and the air leakage rate multiplied by the specific heat of air, the equivalent building thermal mass is rather difficult to ascertain. The building mass is distributed in a complex manner, with respect to its size and shape, position in the insulated structure, and floor interface with the earth.

Although difficult to calculate, the overall building thermal time constant can readily be determined by a simple cool-down test during a heating season based upon the following mathematical relationship.

When the heating system and all the heat sources in a house are suddenly shut off during a steady cold night (outdoor temperature of T_o), its temperature would decay from the initial setpoint of T_1 according to the following equation:

$$MC \frac{dT}{dH} = -K (T - T_o) \quad E-(1)$$

where

MC = overall thermal mass, Btu/°F
K = overall heat transfer factor, Btu/hr, °F
H = hour

The thermal time constant, THTC, is defined as

$$THTC = \frac{MC}{K}, \text{ in the unit of hour}$$

The differential equation E-(1) becomes then

$$\frac{dT}{T - T_o} = - \frac{dH}{THTC}, \quad E-(2)$$

which has a following solution:

$$THTC = \frac{H}{\ln \left(\frac{T_1 - T_o}{T - T_o} \right)} \quad E-(3)$$

Thus, by measuring a logarithmic decay of the building temperature, from initial value of T_1 to T during a time span of H hours, one can readily calculate the value of the thermal time constant.

According to Nash's data^{7/}, typical THTC for residences are:

	Light Weight	Medium Weight	Heavy Weight
One-story house	10	15	20
Two-story house	30	35	40

When a building heat transfer process is simulated by a simple thermal capacity model, its temperature change may similarly be represented by the following first order differential equation

$$MC \frac{dT}{dH} = -K(T - T_o) + SPHG \quad E-(4)$$

- T = building temperature, °F
- T_o = outdoor temperature, °F
- MC = building thermal capacity, Btu/°F
- K = overall heat transfer factor, Btu/hr °F
- $SPHG$ = total space heat gain due to internal heat, heating systems, solar heat gain through windows, and occupancy, Btu/hr
- H = elapsed time, hour.

APPENDIX E

Thermal Time Constant and Its Application

The thermal time constant of a building is a parameter to indicate the speed of indoor temperature response to a sudden change of building heating and cooling operation. The heavier the thermal mass of a building, the slower its response, compared to a lighter building, to cool down or heat up when the building heating system is turned off and on, respectively. The thermal time constant is defined as a ratio between the equivalent thermal mass of the building and the building overall heat transfer factor. Whereas the overall heat transfer factor may be approximated by the heat transfer coefficients, U value, multiplied by the areas, A, of all the elements, such as walls, doors, windows, roof and floors, and the air leakage rate multiplied by the specific heat of air, the equivalent building thermal mass is rather difficult to ascertain. The building mass is distributed in a complex manner, with respect to its size and shape, position in the insulated structure, and floor interface with the earth.

Although difficult to calculate, the overall building thermal time constant can readily be determined by a simple cool-down test during a heating season based upon the following mathematical relationship.

When the heating system and all the heat sources in a house are suddenly shut off during a steady cold night (outdoor temperature of T_o), its temperature would decay from the initial setpoint of T_1 according to the following equation:

$$MC \frac{dT}{dH} = -K (T - T_o) \quad E-(1)$$

where

MC = overall thermal mass, Btu/°F
K = overall heat transfer factor, Btu/hr, °F
H = hour

The thermal time constant, THTC, is defined as

$$THTC = \frac{MC}{K}, \text{ in the unit of hour}$$

The differential equation E-(1) becomes then

$$\frac{dT}{T - T_o} = - \frac{dH}{THTC}, \quad E-(2)$$

which has a following solution:

$$THTC = \frac{H}{\ln \left(\frac{T_1 - T_o}{T - T_o} \right)} \quad E-(3)$$

Thus, by measuring a logarithmic decay of the building temperature, from initial value of T_1 to T during a time span of H hours, one can readily calculate the value of the thermal time constant.

According to Nash's data^{7/}, typical THTC for residences are:

	Light Weight	Medium Weight	Heavy Weight
One-story house	10	15	20
Two-story house	30	35	40

When a building heat transfer process is simulated by a simple thermal capacity model, its temperature change may similarly be represented by the following first order differential equation

$$MC \frac{dT}{dH} = -K(T - T_o) + SPHG \quad E-(4)$$

- T = building temperature, °F
- T_o = outdoor temperature, °F
- MC = building thermal capacity, Btu/°F
- K = overall heat transfer factor, Btu/hr °F
- $SPHG$ = total space heat gain due to internal heat, heating systems, solar heat gain through windows, and occupancy, Btu/hr
- H = elapsed time, hour.

General solution to the above equation is

$$\frac{Q - T_1 + T_o}{Q - T + T_o} = e^{\frac{H}{THTC}} \quad E-(5)$$

where

$$Q = \frac{SPHG}{K} = \text{heat source constant, } ^\circ F$$

$$THTC = \frac{MC}{K} = \text{thermal time constant, hr}$$

$$T_1 = \text{value of } T \text{ when } H = 0, ^\circ F.$$

Equation E-(5) permits, for example, the determination of the duration, DH, for which the house temperature reaches from the daytime set point TID to the nighttime set point TIN, which is usually lower.

Since Q is very small during that period, referring to Figure E-(1),

$$DH = THTC * \ln \left[\frac{TID - TON}{TIN - TON} \right] \quad E-(6)$$

Likewise equation E-(5) may be used to determine the early morning pick-up heating load (or the early evening pull-down cooling load), MPUL, by specifying the required temperature recovery time or pick-up time, PUH, (or pull down time, PHD) as follows

$$\frac{\frac{MPUL}{K} - TIN + TOD}{\frac{MPUL}{K} - TID + TOD} = e^{\frac{PUH}{THTC}} \quad E-(7)$$

By rearranging the term, MPUL can be determined by

$$MPUL = K * \left[(TIN - TOD) + \frac{TID - TIN}{1 - e^{-PUH/THTC}} \right] \quad E-(8)$$

Another example of the use of THTC is to approximate the benefit of excess solar heat gain during a sunny winter day to offset the heat loss during the night.

The procedure used is first to determine the indoor temperature rise TR, due to the excess heat gain, above the daytime indoor temperature setpoint TID by the following equation





Figure E-1. Temperature and heating requirement profile during the nighttime thermostat setback.

$$TR = \frac{QTD}{K*12} * \left[1 - e^{\frac{-(H_2 - H_1)}{THTC}} \right] \quad E-(9)$$

where QTD is the excess daytime heat gain during hour from H_1 to H_2 , which is the balance of heat gain above what is required to cancel the envelope heat loss.

The equation E-(6) will now be used to determine the "off" period of the heating system except that TID in equation (6) is now replaced by the new starting temperature TID + TR.

A similar concept may be used to determine the effect of night heat loss during the cooling season to offset the daytime cooling requirement as follows:

The temperature drop of the room air from the set point of TIN during the cool night due to the excess heat loss QTN is

$$TD = \frac{QTN}{K*12} * \left(1 - e^{-\frac{HN}{THTC}} \right) \quad E-(10)$$

where HN is the nighttime hours

The period when the air-conditioning system could be off due to this night cooling is then

$$DH = THTC * \ln \left(\frac{\frac{TD}{K*12} - TIN + TD + TOD}{\frac{QTD}{K*12} - TID + TOD} \right) \quad E-(11)$$

provided that $(TIN - TD) < TID$.

Figure E-2 depicts indoor temperatures, cooling and heating periods, and other notations such as DH, PDH, PUH and TD in cooling season. Figure E-2(a) shows indoor temperatures and cooling period in a day when $QTD \geq 0$ and $QTN \geq 0$. The daytime indoor temperature rises from TIN to TID during early morning pickup hours, DH, while the cooling system is turned off. After this period, the temperature is maintained at TID during daytime, followed by a pull down to TID at the beginning of nighttime for a period of PHD hours. The cooling system is, therefore, assumed to be running all day except for the period of DH.

Figure E-2(b) shows the case of $QTD \geq 0$ and $QTN \geq 0$. In this case, the nighttime indoor temperature decreases from TIN to TIN-TD according to the nighttime heat losses, while the cooling system is turned on during a period of PDH. Because of the night heat loss the indoor temperature

is lower than T_{IN} by T_D at the beginning of daytime. During an early morning period of DH , the temperature naturally rises to T_{ID} because of the daytime heat gains. Consequently, the cooling system continues to operate throughout the day except periods DH and PDH .

There is a limitation on input of daytime and nighttime indoor temperatures, T_{ID} and T_{IN} , in that T_{ID} is always equal to or higher than T_{IN} . The reason of this limitation is to avoid algorithm complexities.

Figures E-2(c) and (d) depict indoor temperatures profile during the heating period.

Figure E-2(c) shows indoor temperatures and heating period in a day when $Q_{TD} > 0$ and $Q_{TN} \leq 0$. The daytime indoor temperature goes up to $T_{ID} + T_D$ at the end of daytime because the cooling system is not running in spite of $Q_{TD} > 0$ during the daytime. The nighttime indoor temperature goes down from $T_{ID} + T_R$ to T_{IN} during a period of PH because $Q_{TN} \leq 0$ and the heating system is turned off. After the temperature reached to T_{IN} , the heating system is turned on.

Figure E-2(d) shows indoor temperatures and heating period in a day when $Q_{TD} \leq 0$ and $Q_{TN} \leq 0$. The nighttime indoor temperature decreases to T_{IN} from T_{ID} because of night setback. During a period of DH , the heating system is turned off. PUH is pick-up time, during which the indoor temperature goes up to T_{ID} from T_{IN} because of the heating system.

If there is a case of $Q_{TD} \leq 0$ and $Q_{TN} \geq 0$, it is neglected, meaning that the heating and cooling requirements should be equal to zero because the case should seldom occur in the cooling season.

The heating and cooling requirement are both set equal to zero during the heating season when the daytime and nighttime heat balance, Q_{TD} and Q_{TN} , are both positive. Likewise Q_{TD} and Q_{TN} are both set equal to zero during the cooling season if Q_{TD} and Q_{TN} are both negative.

REFERENCES

1. "DOE-2 Program Manual," Los Alamos Scientific Laboratory LA-7688-17, and Lawrence Berkeley Laboratory LBL-8705, Feb 1979.
2. T. Kusuda and K. Ishii, "Hourly Solar Radiation Data for Vertical and Horizontal Surfaces on Average Days in the United States and Canada" National Bureau of Standards Building Science Series 96, April 1977.
3. R. W. R. Muncey and J. W. Spencer, "Heat Flow into the Ground under a Home". Energy Conservation in Heating, Cooling and Ventilating Buildings, Vol 2 pp 649-660. Hemisphere Publishing Corporation Washington DC, 1978.
4. ASHRAE Task Group "Procedure for Determining Heating and Cooling Loads for Computerizing Energy Calculations" Energy Calculation 1 ASHRAE 1976.
5. D. Goldstein and M. Levine, "Economic Analysis of Proposed Building Energy Performance Standards." Battelle Pacific Northwest Laboratory PNL-3044 Sept 1979.
6. E. Stamper, "Weather Data" ASHRAE Journal, February 1977, p. 47.
7. Robert T. Nash, "Thermal and Hygroscopic Fluctuations in Small Structures," Vanderbilt University, Dec 1975.

