



AIVC April Workshop



Jelle Laverge
Operating Agent
IEA-EBC Annex 86

Series of four webinars

Organised in collaboration with IEA-EBC Annex 86 'Energy efficient IAQ management'

April 1, Building ventilation: How does it affect SARS-CoV-2 transmission?

April 8, IAQ and ventilation Metrics

April 13, Big data, IAQ and ventilation -part 1

April 21, Big data, IAQ and ventilation -part 2

Register at www.aivc.org

1



Introduction: context of the webinar

- The IEA-EBC ExCo approved the start of the preparation year of 'Annex 86' in June 2020
- AIVC TechNote 68 'Ventilation and Health'
- AIVC CR 17 and 19

2

Partners

42 institutes from 24 countries

Active participation by companies encouraged!

List of annex participants per country:

Australia: CSIRO
 Austria: University of Innsbruck
 Belgium: UGent, KUL, BBRI, University of Antwerp
 Brazil: Pontifical Catholic University of Parana
 Canada: NRC
 Chile: PUC
 China: Nanjing University, BUCE and Tsinghua University
 Denmark: DTU and Aalborg University Copenhagen
 Finland: Aalto University
 France: La Rochelle University, ENS PSL, CEREMA, Université de Lille, UPJV and CETIAT
 Germany: TH Rosenheim
 Ireland: NUIG
 Italy: EURAC research center
 New Zealand: BRANZ
 Netherlands: Technical University of Eindhoven, BBA/TU Delft and Zehnder
 Norway: Oslo Metropolitan University and SINTEFF
 Portugal: University of Coimbra, Polytechnic Institute of Viseu and University of Porto
 Singapore: National University of Singapore
 Spain: Eduardo Torroja Institute for Construction Sciences – CSIC
 Sweden: Chalmers University and KTH
 Switzerland: ETH
 Turkey: TTMD
 United Kingdom: University of Strathclyde, Lancaster University and University of Nottingham
 USA: Syracuse University, UMD, UTexas and LBL

5

Workplan

6 Subtasks

ST 1 and 2: methodology

ST 3 and 4: application to technology

ST 5: new opportunities through IoT

ST 6: dissemination and management

Subtask 1 Metrics and development of an IAQ management strategy rating method

This subtask is devoted to the development of a general rating method for the benchmarking of the performance of IAQ management systems. In addition to relevant metrics, a set of appropriate tools, consistent modeling assumptions and monitoring protocols are also proposed.

Subtask 2 Source characterization and typical exposure in residential buildings

This ST creates consistent input values for the assessment method developed in ST 1 and control strategies in ST 4. It starts from information available in literature, adding new experimental results where needed and reviewing and developing models (empirical, semi-empirical or physical models) for characterizing relevant residential sources.

Subtask 3 Smart materials as an IAQ management strategy

This ST identifies opportunities to use the building structure and (bio-based) building materials (focussing on hemp concrete) and the novel functional materials inside it to actively/passively manage the IAQ, for example, through active paint, wallboards, textiles coated with advanced sorbents or hemp concrete, and quantifies their potential based on the assessment framework developed in ST 1.

Subtask 4 Ensuring performance of smart ventilation

This subtask focuses on practical conditions that assure reliable, cost effective and robust implementation of smart ventilation. This includes both installation and operation. A poor performance of smart ventilation systems can not only lead to waste of energy and aggravated IAQ. It can also create a bad reputation of smart ventilation among relevant stakeholders - designers, installers as well as occupants. This, in the end, can lead to adoption of more primitive, less efficient (in terms of energy use) and less effective (in terms of IAQ) forms of IAQ management. The subtask defines a smart ventilation according to the AIVC

Subtask 5 Energy savings and IAQ: improvements and validation through cloud data and IoT connected devices

This subtask is exploring the potential of the new generation of IoT connected devices (both standalone and embedded in eg. AHU's) for smart IAQ management. What can we learn from big data? Can we benchmark system energy and IAQ performance based on this data? How can we make sure that the data is available and can be accessed? Can we update what we think we know about what happens in dwellings based on what we see in big data rollouts? What are the best protocols and ontologies? How to create viable services out of the data/business plans? How can we integrate data with smart grids?

Subtask 6 Dissemination, management and interaction

The final subtask assures the close alignment of the activities within the annex and the interaction with the AIVC. This subtask includes the outreach of the annex, eg. by managing the dedicated section of the IEA EBC webpage. It uses the different platforms that the AIVC provides to interact with the broader target audience. This task will also ensure the continuation of the link with (the results from) other ongoing and ended annexes, especially annex 68.

6

Workplan

6 Subtasks

ST 1 and 2: methodology

ST 3 and 4: application to technology

ST 5: new opportunities through IoT

ST 6: dissemination and management

Subtask 1 Metrics and development of an IAQ management strategy rating method

This subtask is devoted to the development of a general rating method for the benchmarking of the performance of IAQ management systems. In addition to relevant metrics, a set of appropriate tools, consistent modeling assumptions and monitoring protocols are also proposed.

Subtask 2 Source characterization and typical exposure in residential buildings

This ST creates consistent input values for the assessment method developed in ST 1 and control strategies in ST 4. It starts from information available in literature, adding new experimental results where needed and reviewing and developing models (empirical, semi-empirical or physical models) for characterizing relevant residential sources.

Subtask 3 Smart materials as an IAQ management strategy

This ST identifies opportunities to use the building structure and (bio-based) building materials (focussing on hemp concrete) and the novel functional materials inside it to actively/passively manage the IAQ, for example, through active paint, wallboards, textiles coated with advanced sorbents or hemp concrete, and quantifies their potential based on the assessment framework developed in ST 1.

Subtask 4 Ensuring performance of smart ventilation

This subtask focuses on practical conditions that assure reliable, cost effective and robust implementation of smart ventilation. This includes both installation and operation. A poor performance of smart ventilation systems can not only lead to waste of energy and aggravated IAQ. It can also create a bad reputation of smart ventilation among relevant stakeholders - designers, installers as well as occupants. This, in the end, can lead to adoption of more primitive, less efficient (in terms of energy use) and less effective (in terms of IAQ) forms of IAQ management. The subtask defines a smart ventilation according to the AIVC

Subtask 5 Energy savings and IAQ: improvements and validation through cloud data and IoT connected devices

This subtask is exploring the potential of the new generation of IoT connected devices (both standalone and embedded in eg. AHU's) for smart IAQ management. What can we learn from big data? Can we benchmark system energy and IAQ performance based on this data? How can we make sure that the data is available and can be accessed? Can we update what we think we know about what happens in dwellings based on what we see in big data rollouts? What are the best protocols and ontologies? How to create viable services out of the data/business plans? How can we integrate data with smart grids?

Subtask 6 Dissemination, management and interaction

The final subtask assures the close alignment of the activities within the annex and the interaction with the AIVC. This subtask includes the outreach of the annex, eg. by managing the dedicated section of the IEA EBC webpage. It uses the different platforms that the AIVC provides to interact with the broader target audience. This task will also ensure the continuation of the link with (the results from) other ongoing and ended annexes, especially annex 68.



IAQ and Ventilation Metrics

webinar
2021.04.08

Objectives:

- To discuss the road towards a robust comprehensive IAQ metric for the assessment of the performance of ventilation
- To set the starting stage for subtask 1 of IEA EBC Annex 86

09:00 | Introduction, **Jelle Laverge – EBC Annex 86 Operating Agent, Ghent University, Belgium**

09:10 | Annex 68 IAQ metrics: what was proposed, what works, what not, what are the remaining questions? **Marc Abadie – University of La Rochelle, France**

09:30 | DALY as an integrated IAQ metric: methodological updates, **Benjamin Jones – University of Nottingham, UK**

09:50 | TAIL a new rating scheme of indoor environmental quality, **Pawel Wargocki – DTU, Denmark**

10:10 | Questions and Answers

10:30 | Closing & End of webinar



IAQ and Ventilation Metrics

webinar
2021.04.08



Marc Abadie
La Rochelle Université,
France



Benjamin Jones
University of Nottingham,
UK



Pawel Wargocki
Danmarks Tekniske
Universitet, Denmark

Webinar management



Maria Kapsalaki
(INIVE, BE)



Valérie Leprince
(INIVE, BE)



webinar
2020.04.08

How to ask questions during the webinar

Locate the **Q&A** box

Select **All Panelists** | Type your question | Click on Send

Note: Please **DO NOT**
use the chat box to ask
your questions!

Q&A

All (0)

Ask: All Panelists

What is the percentage of non compliant buildings?

Send



NOTES:

- The webinar will be **recorded and published** at www.aivc.org within a few days, along with the presentation slides.
- After the end of the webinar you will be redirected to our **post event survey**. Your feedback is valuable so take some minutes of your time to fill it in.

Organized by: www.aivc.org

Facilitated by



Disclaimer: The sole responsibility for the content of presentations and information given orally during AIVC webinars lies with the authors. It does not necessarily reflect the opinion of AIVC. Neither AIVC nor the authors are responsible for any use that may be made of information contained therein.