

Ventilation Performance Assessment Tool



Van Holsteijn en Kemna B.V.





1

EVIA members



2

1. Goal: promotion of high performance ventilation systems



3

2. Methodology

The methodology assesses the actual occurring air exchange rates on room type level during presence and absence.

The Air Exchange Performance (AEP) determines to which extent the ventilation system is able to remove and/or dilute pollutant concentrations in the various rooms, especially during presence when exposure occurs.

Compared to current practice, where only the air exchange rate over the building is assessed, this represents a major step towards more relevant ventilation performance assessment. Current practice after all does not differentiate between the places in which the air exchanges occur nor between periods of presence or absence.



Van Holsteijn en Kemna B.V.



4

2. Methodology



VENTILATION PERFORMANCE ASSESSMENT TOOL

Calculation method for assessing the air exchange performance of residential mechanical ventilation units

Documentation related to the Excel Calculation Models
Version December 2022

Client: European Ventilation Industry Association (EVIA)

Prepared by

VHK (R.C.A. van Holsteijn and W. Li)
UGent (J. Laverge)



Van Holsteijn en Kemna BV (VHK)
Rotterdamseweg 390 816, 2629 HG Delft,
The Netherlands www.vhk.nl



Department of Architecture and Urban Planning
Josef Plateaustraat 22, 9000 Gent, Belgium
www.ugent.be

Delft, December 2022

Ventilation Performance Assessment Tool Indoor Air Performance Label calculation

User manual

VPA-tool was developed by VHK and UGhent
for and in cooperation with EVIA

Brussels, December 2022

Prepared by: VHK (R. van Holsteijn, W. Li), UGhent (J. Laverge)
and EVIA (Y. Lambert, L. van Bohemen)



Van Holsteijn en Kemna B.V.



5

2. Methodology



Assessment Method

Defining room types and ventilation strategy (1)

Habitable spaces: **HS** (living rooms, bedrooms, study, etc.)

Pollutants : Bio-effluents, building material emissions, emissions from interior products, pollutants from human activities

Exposure : Inhabitants during presence

Occupancy time: Long / very long

Reference ventilation strategy

Air-exchange : During presence, supply of sufficient fresh outdoor air is key
During absence, basic ventilation rates are required to prevent accumulation of building- and interior products emissions

6

2. Methodology

Assessment Method

Defining room types and ventilation strategy (2)

Wet or Extract spaces: ES (kitchen, bathroom, toilet, laundry room)

Pollutants : Moisture, odour, building material emissions, emissions from human activities

Exposure : Inhabitants during presence / building to high humidity levels

Occupancy time: Short

Reference ventilation strategy

Air-exchange : During presence, extraction of sufficient air (incl. moisture/odour) is key (supply is adjusted accordingly)

During absence, extraction of air until humidity levels are below threshold values; basic ventilation rates after that.

2. Methodology

Assessment Method

Defining technical system parameters

1. Ventilation System Type (VST) and associated air-exchange provisions in ES and HS
2. Type of MDE/MDS fan and type of NDS (natural direct supply)-grids used in the VST
3. Installed maximum and minimum airflow capacity (limiting factor for achievable air exchange rates)
4. Type of operation / controls (affects system's ability to achieve requested air-exchanges at the right time in the right place)
5. Type of dwelling: number and type of ES and HS, surface of HS, airtightness

2. Methodology

Ventilation System Type

UVU

BVU

VST	roomtype	air exchange provision		abbrev.
1	habitable spaces	supply	natural direct supply	NDS
		extract	natural indirect extract	NIE
	exhaust spaces	supply	natural indirect supply	NIS
		exhaust	natural direct exhaust	NDE
2	habitable spaces	supply	mechanical indirect supply	MIS
		exhaust	natural direct exhaust	NDE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	natural direct exhaust	NDE
3	habitable spaces	supply	natural direct supply	NDS
		extract	mechanical indirect extract	MIE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical direct exhaust	MDE
4	habitable spaces	supply	natural direct supply	NDS
		exhaust	mechanical direct exhaust	MDE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical exhaust	MDE
5	habitable spaces	supply	mechanical direct supply	MDS
		extract	mechanical indirect extract	MIE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical direct exhaust	MDE
6	habitable spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical direct exhaust	MDE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical direct exhaust	MDE
7	habitable spaces	supply	mechanical direct supply	MDS
		exhaust	mechanical direct exhaust	MDE
	exhaust spaces	supply	mechanical indirect supply	MIS
		exhaust	mechanical direct exhaust	MDE



9

2. Methodology

Assessment Method

Principle for calculating occurring AER : $AER = q_{v;inst} * P_{q;inst} * f_{ctrl}$ (1)

$q_{v;inst}$ = Installed min. and max. ventilation capacity in ES and HS

$P_{q;inst}$ = The probability that installed ventilation capacity in ES & HS is actually achieved.

This is calculated, taking into account the following parameters:

- Driving force (natural versus mechanical)
- Number and position of internal doors (i.e. open or closed, applicable to certain VSTs)
- Airtightness of the dwelling and location of leakages (applicable to certain VSTs)
- Duct leakages RVU (reducing intended mech. supply/exhaust airflows)
- Filter compensation BVU (reducing supply airflow due to clogging filters, acc EN13142)
- Internal leakage BVU (reducing share of air that is supplied or extracted, acc. EN13142)
- Airflow sensitivity 'v' (sensitivity RVU for pressure variations over façade, acc. EN13141-8)
- Indoor/outdoor airtightness 'qvio' of (local) RVU (acc. EN13141-8)



10

2. Methodology

Assessment Method

Principle for calculating occurring **AER**: $AER = qv;inst * Pqv;inst * fctrl$ (2)

$fctrl$ = The probability that the controls of the ventilation provisions are in the right position to achieve the required airflow rate.

$fctrl$ is calculated, taking into account the **PCO**-values of the related controls. For a list of *Ctrl*-types **PCO** values have been determined for **ES** and **HS** for both periods of presence and absence.

For **all ES** and combined **HS** the occurring **AER** is calculated for periods of presence and absence.

2. Methodology

Assessment Method

Principle for calculating Air Exchange Performance **AEP**: $AEP = AER / AERref$ (1)

$AERref$ = The reference air exchange rate; a value is determined for **ES** and **HS** and for periods of presence and absence based on EN 16798-1, Annex B, Category II

$AERref$	$AERref$ for HS	$AERref$ for ES		
		bathroom	kitchen	toilet
During presence	0,47 l/s/m ²	20 l/s	10 l/s	10 l/s
During absence	0,13 l/s/m ²	4 l/s	2 l/s	2 l/s

For **all ES** and combined **HS** the **AEP** is calculated for periods of presence and absence.

3. Input/output sheet

VST 5	EXHAUST SPACES (ES)	HABITABLE SPACES (HS)
SUPPLY PROVISIONS	MIS	MDS
EXHAUST PROVISIONS	MDE	MIE

> ALTER ONLY THE YELLOW CELLS! <

1. Dwelling airtightness airtightness parameter n50 value: **2,00** air changes per hour

2. Specify number of Exhaust (ES) and Habitable Spaces (HS)

open_kitchen	bathroom	toilet	utility	other	total ES
number	number	number	number	number	number
1	1	1	0	0	3

habitable spaces	
number	total surface area in m²
3	66,00

3. Select BVU-type

BVU-type	1	CENTR.BIDIR.VENT.UNIT VARIABLE FLOWRATE FIXED FLOWRATE RATIO ES & HS
BVU F/c	20%	Measured filter compensation factor according to Annex D EN 13142; if not known a default of 20% is used
BVU Fil	6%	Measured fraction of exhaust air recirculating in supply air, measured acc. to chamber tracer gas method EN 13142; if not known a default of 6% is used

4. Specify maximum MDE (= MDS) capacity to be installed

MDE capacity per ES type					
open_kitchen	bathroom	toilet	utility	other	total MDE
l/s	l/s	l/s	l/s	l/s	l/s
30,00	15,00	10,00			55,00

installed MDS capacity HS (with clean filter and not corrected for Fil)	
l/s	l/s/m²
55,00	0,83

5. Specify minimum MDE (= MDS) capacity

6,00	3,00	2,00		11,00	
Ratio minimum capacity must be identical when MDE-type 1 is selected					

6. MIS- and MIE capacity as % of MDE and MDS acc. Good Practice

MIS capacity				
100%	100%	100%		100%

MIE capacity	
100%	

7. Specify type of control from Exhaust and Habitable Spaces

Controls ES				
MDE kitch.	MDE bathr.	MDE toilet	MDE utility	MDE-other
control type	control type	control type	control type	control type
RH-local	RH-local	PIR		

Controls HS	
MDS habitable spaces	control type
100%	no control

RESULTS

Probability that requested air exch. rate occurs in indiv. spaces

AEP ES				
open_kitchen	bathroom	toilet	utility	other
presence	95%	95%	95%	95%
absence	133%	133%	95%	130%
overall AEP	98%	98%	94%	98%

AEP HS	
presence	32%
absence	119%
overall AEP	32%

Average air exchange rate (AER) over total dwelling @ default occupation

average AER DWELLING			
dm³/s	m³/h	ach	dm³/s/m² A _d
21	75	0,31	0,23

13

4. Calculation sheet

INSTALLED CAPACITY $q_{s,inst} [l/s]$

ES type	ES n	q _{max} [l/s]	q _{inst} [l/s]
open kitchen	1	30	30
bathroom	1	15	15
toilet	1	10	10
total	3		55

OTHER CAPACITY $q_{s,oth} [l/s]$

CAPACITY OVERFLOW COMPONENTS (MIS and MIE) $q_{s,ov} [l/s]$

TYPE OF CONTROL/OPERATION AND RELATED Fc-VALUES

ES type	RH-local	PIR	central	central
open kitchen	1,00			
bathroom	1,00			
toilet	1,00			
total	3,00			

CONTROL FACTOR $f_c [l/s]$

ES type	RH-local	PIR	central	central
open kitchen	0,88			
bathroom	0,88			
toilet	0,88			
total	2,64			

PROBABILITY p_{ch} [%] of control

ES type	MIS and MIE	MDS	MDE
open kitchen	0,88	0,88	0,88
bathroom	0,88	0,88	0,88
toilet	0,88	0,88	0,88
total	0,88	0,88	0,88

PROBABLE AER OVER THE EXHAUST'S HABITABLE SPACES

ES type	q _{s,inst} [l/s]	q _{s,oth} [l/s]	q _{s,ov} [l/s]	AER [l/s]
open kitchen	29,16	0	0	29,16
bathroom	14,58	0	0	14,58
toilet	9,72	0	0	9,72
total	53,46	0	0	53,46

PROBABILITY THAT REFERENCE AER IS ACHIEVED IN HABITABLE ROOMS: AEP

ES type	AEP [%]	AEP [l/s]	AEP [m³/h]
open kitchen	88%	25,65	92,34
bathroom	88%	12,82	46,17
toilet	88%	8,55	30,81
total	88%	47,02	169,32

ESTIMATE TOTAL AIR EXCHANGE DWELLING

Parameter	Value
AER [l/s]	53,46
AER [m³/h]	192,46
Ach	0,31
AER [l/s/m²]	0,23

14

5. Lookup tables






Table 13 : REFERENCE VALUES FOR OCCUPANCY IN ES AND HS

Average occupation Exhaust Spaces				Average occupation Habitable Spaces			
Type ES	Number	% of the day	% of the day	Type HS	%Occ:inhab	% of the day	% Occ:Anab
kitchen	1	9%	9%	all HS	60%	63%	50%
bathroom	1	4%	4%				
toilet	1	1%	1%				
utility	0	1%	0%				
other	0	1%	0%				
		Occupation ES	14%				



Any size of dwelling

Reference dwelling
(source : EU28 Buildings Database)

National Air Exchange Rates
(source: national ventilation standard)

EU Air Exchange Rates
(source: prEN 16798-1)

VU product data
(source: company)

VU product data
(source: company)

Table 8. Parameters of reference dwelling

Total dwellings surface (heated space)	92,40 m ²
Total internal volume	240 m ³
Total surface of habitable spaces	66 m ²
Number of Exhaust Spaces	3 : kitchen, bathroom toilet
Type of kitchen	Open kitchen (combined with dining room)
Number of habitable spaces	3
Airtightness dwelling	N50 = 2.00

17

> ALTER ONLY THE YELLOW CELLS! <

VST 5	EXHAUST SPACES (ES)	HABITABLE SPACES (HS)
SUPPLY PROVISIONS	MIS	MDS
EXHAUST PROVISIONS	MDE	MIE

EVIA
European Ventilation Industry Association

- Dwelling airtightness

airtightness parameter	n50	value:	2,00	air changes per hour
------------------------	-----	--------	------	----------------------
- Specify number of Exhaust (ES) and Habitable Spaces (HS)

open_kitchen						bathroom						toilet						utility						other						total ES					
number		number		number		number		number		number		number		number		number		number		number		number		number											
1		1		1		0		0		0		3																							

habitable spaces	
number	total surface area in m ²
3	66,00
- Select BVU-type

BVU-type	1	CENTR. BIDIR. VENT. UNIT VARIABLE FLOWRATE FIXED FLOWRATE RATIO ES & HS
BVU Ffc	5%	↕ measured filter compensation factor according to Annex D EN 13142; if not known a default value of 20% is used
BVU Fil	1%	↕ Measured fraction of exhaust air recirculating in supply air, measured acc. to chamber tracer gas method EN13142; if not known a default of 6% is used
- Specify maximum MDE (= MDS) capacity to be installed

MDE capacity per ES type						installed MDS capacity HS (with clean filter and not corrected for Fil)	
open_kitchen	bathroom	toilet	utility	other	total MDE	habitable spaces	
l/s	l/s	l/s	l/s	l/s	l/s	l/s	l/s/m ²
20,00	10,00	10,00			40,00	40,00	0,61
4,00	2,00	2,00			8,00	8,00	0,12
20.0%	20.0%	20.0%					
- Specify minimum MDE (= MDS) capacity
Ratio min/max capacity must be identical when MDE-type 1 is selected

MIS capacity				MIE capacity			
open_kitchen	bathroom	toilet	utility	other	total	habitable spaces	
100%	100%	100%			100%	100%	
100%	100%	100%			100%		
- MIS- and MIE capacity as % of MDE and MDS acc. Good Practice
- Specify type of control from Exhaust and Habitable Spaces

Controls ES					Controls HS	
MDE_kitch.	MDE_bathr.	MDE_toilet	MDE_utility	MDE-other	MDS habitable spaces	
cntrl type	cntrl type	cntrl type	cntrl type	cntrl type	% of HS area	cntrl type
RH-centr.	RH-centr.	RH-centr.			85%	CO2-local
					15%	no control

RESULTS

Probability that requested air exch. rate occurs in indiv. spaces							AEP HS		
		open_kitchen	bathroom	toilet	utility	other	average ES	average HS	
presence		84%	84%	84%			84%		
absence		279%	279%	279%			279%		
overall AEP		102%	102%	102%			102%	94%	overall AEP

Average air exchange performance (AEP) and air exchange rate (AER) over total dwelling @ default occupation

combined AEP DWELLING			
95%			
average AER DWELLING			
dm ³ /s	m ³ /h	ach	dm ³ /s/m ² A
25	90	0,38	0,27

18

When selecting the controls for HS, there is a possibility to choose the location and the type of sensor.

Controls HS				
% of HS area	cntrl type	% of HS area	cntrl type	% MDE
100%	manual	60%	CO2-local	100%
		40%	no control	

The % of HS area it affects is determined by this table :

Sensor in

Living room


Master Bedroom

Children's bedroom


% of HS

X	X	X			
X	X		X	X	
X			X		X
100%	85%	60%	40%	25%	15%

6. Label design



6. Label design



21

7. Merged Air Exchange Performance

RESULTS

Probability that requested air exch. rate occurs in indiv. spaces

	AEP ES					average ES
	open_kitchen	bathroom	toilet	utility	other	
presence	72%	31%	31%			57%
absence	171%	95%	95%			119%
overall AEP	79%	30%	30%			59%

AEP HS	
average HS	
33%	presence
89%	absence
32%	overall AEP



Van Holsteijn en Kemna B.V.



GHENT UNIVERSITY

Merged AEP %



Exposure occurs only during presence, so it is valid approach to use occupancy as the dominant weighting factor. According to the occupancy schedule, total occupancy in ES = 14% and in the HS = 63% of the day. This gives the following formula and subsequent classes:

$$\text{AEP}_{\text{dwelling}} = ((\text{AEP-ES}) * 14\% + (\text{AEP-HS}) * 63\%) / 77\%$$

55%	70%	C
70%	85%	B
85%	>100%	A

22

8. Indoor Air Performance label generator

Name or logo (upload)

Supplier's name or trade mark *

Supplier's model identifier *

VPAT score

Sensor(s)	Yes	No
Relative Humidity	<input type="radio"/>	<input type="radio"/>
CO ₂	<input type="radio"/>	<input type="radio"/>
Odour (TVOC)	<input type="radio"/>	<input type="radio"/>
Presence (PIR)	<input type="radio"/>	<input type="radio"/>
People counting sensor (Bidirectional laser)	<input type="radio"/>	<input type="radio"/>

Airflow Control

Filtration

Indoor air performance label

itho daalderop Climate for life HRU ECO LP BAL

Calculation based on average European dwelling size

Sensors

- Relative humidity
- CO₂
- Odour
- Presence PIR
- People counting sensor

Airflow Control

- Central
- Zonal
- Local

Filtration

★★★★☆

9a. Example: VST5 manual control




Manual control

Adaption of the Ventilation effect depends on actions of the user and the air volume change effects all rooms. In most cases, the result is an under or over ventilation which leads to a rather bad **air exchange performance class - D**

9b. Example VST5 zonal demand control

Zonal demand control with 2 sensors

Adaption of the Ventilation effect depends on changes of the measured parameters and the air volume change effects all rooms. This is a quite good approach to get a good indoor air quality and the result is **air exchange performance class - B**



25

10. Example: VST3 without/with demand control

Indoor Air Quality


Aereco Demand Controlled Ventilation

Energy Efficiency

No-Demand Controlled Ventilation

26

11. Example: VST7 Single room unit with heat recovery



Ventilation Performance Assessment Tool

Contact: secretariat@evia.eu

