



Ventilation inspection schemes in France

Adeline Mélois
Cerema, France


Outline

- 1. Regulatory context in France**
- 2. Testers schemes for ductwork airtightness**
- 3. Authorities controls**
- 4. Promevent protocol**


1. Regulatory context in France

Ventilation system characteristics	 RT 2012 Declaration in EP calculation	 Requirements
Ductwork airtightness	Default value Class A Class B or C	<ul style="list-style-type: none">• Class A for Effinergie labels
Airflow at terminal devices	Q total	<ul style="list-style-type: none">• Q_{\min} imposed by ventilation regulation• Q_{\max} calculated to limit energy consumption
Condition of installation of the ventilation system		<ul style="list-style-type: none">• Ventilation regulation• Professional standards

1. Regulatory context in France



1. Regulatory context in France



2. Testers schemes for ductwork airtightness

- **A national qualification for ductwork airtightness testers**
 - Undergo a qualifying State-approved training
 - Pass the training examination
 - Justify a minimum 10 tests performed
 - Yearly follow-up checks
- **Two national documents**
 - Measurements: FD E51-767
 - Checks: Promevent protocol
- **99 qualified testers in march 2019**

3. Authorities controls

■ What for?

- Improve buildings quality
- Inform professional regarding sources and impacts of non-compliance

■ Which buildings?

- new buildings (0-3 years after commissioning)
- In 2017: 670 buildings = 20,505 dwellings



■ By whom?


- Expert civil servants

■ How?

- Documents analysis
- On-site visit (half day) with building's owner and inoccupants
- Official report sent to the prosecutor when there are non-compliances

3. Authorities controls

- 1 Ventilation system
- 2 Bodyguard
- 3 Fire safety
- 4 Thermal properties
- 5 Accessibility
- 6 Acoustics
- 7 Earthquake resistance




3. Authorities controls

1 Ventilation system

Method: national guide includes requirements and method of the Promevent protocol

→ 548 buildings controlled in 2017




4. Promevent protocol



- A shared thought: need of a unique and reliable protocol
- A 3-years on-field research project with 8 partners
- Scope: mechanical ventilation systems in dwellings
- **2 deliverables:**
 - 1 protocol for:
 - visual checks
 - pressure differences and airflow at air vents
 - ductwork airleakage
 - 1 guide

4. Promevent protocol













4. Promevent protocol



- measurement conditions (closed windows and doors, the settings at ventilation unit and at the ATDs)
- measurement principle (types of measuring instrument, minimum duration of the measurement, the position of the instrument)
- relevant corrections to apply
- uncertainty for airflow measurements:
 - **MPE \leq 10%**
total maximum uncertainty = 15%
 - OR total uncertainty precisely evaluated and under 15%
- uncertainty for pressure measurements:
 - **MPE \leq 3%/0.5 Pa**
total maximum uncertainty = 10%/5 Pa
 - OR total uncertainty precisely evaluated and under 10%/5 Pa

4. Promevent protocol

		Extraction		Soufflage		
						
	One-point thermal anemometer + hood	✓	✓	✗	✗	✗
	Checked thermal anemometer + hood	✓	✓	✓	✓	✗
	Pitot tube + powered flow hood	✓	✓	✓	✓	✓
	Propeller anemometer + hood	✓	✓	✓	✓	✗
	Propeller anemometer + hood with extension	✓	✓	✓	✓	✓

4. Promevent protocol

Tableau 9 : Liste des vérifications à réaliser sur les bouches d'extraction (unite filer par extraction et double filer)

Lister TOUTES les pièces laminées du logement	Cuisine	SB	WC	—	N° fiche Guide Promevent	
	Respect (Oui / Non / Commentaires) ou Donnée *Renvoyer la donnée même en absence					
Pré-inspection						
BE: Bouches d'extraction						
BE1	*Matrice et référence				Fiches pré-inspection	
BE2	*Page de fonctionnement pression					
BE3	*Page de fonctionnement débit					
BE4	Les caractéristiques de la bouche respectent la réglementation ou l'avis technique					32
BE5	Présence d'une bouche d'extraction					32
BE6	Absence d'écoulement d'air et de bouches de soufflage (sauf cuisine ouverte)					33
BE7	* Matrice et référence					33
BE8	*Page de fonctionnement pression					
BE9	*Page de fonctionnement débit					
BE10	Les caractéristiques de la bouche respectent les spécifications de conception (à ne remplir que si BE4 = « Oui »)					33
BE11	Les dimensions minimales entre chaque bouche et les parois et le sol sont respectées				34	
BE12	Chaque bouche est accessible et permet sa vérification et son entretien de façon aisée				34	
BE13	Chaque bouche n'est ni caillée, ni entravée, ni obstruée				35	
BE14	Chaque bouche est démontable				35	
BE15	Chaque bouche est raccorder au conduit par une manchette adaptée ou un dispositif équivalent				36	
BE16	Un débit est réservé à chaque bouche				36	
BE17	Le sens du débit est correct				37	
BE18	Le cas échéant, la commande de passage en débit de pointe est accessible et fonctionnelle					
	*Débit mesuré (m ³ /h) en débit de base cuisine (mini/maxi si bouche bi-débit)				Fiches mesures sur bouches	
	*Débit mesuré (m ³ /h) en débit de pointe cuisine (mini/maxi si bouche bi-débit)					
	*Pression mesurée (Pa) en débit de base cuisine (mini/maxi si bouche bi-débit)					
	*Pression mesurée (Pa) en débit de pointe cuisine (mini/maxi si bouche bi-débit)					
	*Débit fenêtres et/ou portes intérieures ouvertes (m ³ /h)					
	*Pression fenêtres et/ou portes intérieures ouvertes (Pa)					

Version d'octobre 2016




www.promevent.fr

4. Promevent protocol




www.promevent.fr



- 2 cards on pre-check
- 40 cards on functional checks
- 4 cards on functional measurement
- 7 cards on ductwork airtightness measurement

4. Promevent protocol

- Recommendations from on-site and laboratory campainings



*errors on the measured
airflow up to 30%.*



*errors on the measured
airflow up to 50%.*

4. Promevent protocol

NEW
March 2019


- Rules to analyze results of a diagnostic for conformity
 - Functional Check:

Check points	Regulatory requirements	Essential points for operational ability of the ventilation system	Other good practices points
Minimum compliance rate	100%	100%	Single house : 70% Multi-family dwellings : 80% (90% bonus COS)

4. Promevent protocol

NEW
March 2019

- Rules to analyze results of a diagnostic for conformity
 - Functional measurements: tolerance/measurement uncertainties




PromevenTertiaire 2018-2021

- Protocol for ventilation systems inspection in non-residential buildings
 - 3 years projects : 9 French partners



- Funding from :



PromevenTertiaire

■ On Site Campaign

- 3 buildings (office buildings and schools) to test protocol application robustness
- 4 different measuring teams

■ Laboratory tests

- Calibration
- Uncertainties evaluation

■ Impact of observed dysfunctions

■ Final result: Protocols + Guidebook

Thank you for your attention

adeline.melois@cerema.fr